

TEGUCIGALPA TONCONTIN, Honduras

WMO: 787200

Lat: 14.061N

Lon: 87.217W

Elev: 3294

StdP: 13.03

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	53.4	55.4	46.1	52.1	74.8	48.4	56.8	72.6	24.0	69.2	22.4	69.2	2.5	0	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	23.1	89.7	67.0	87.9	67.6	86.2	67.5	72.8	81.8	72.0	81.1	71.4	80.4	8.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.2	125.7	75.2	69.8	124.0	74.8	68.9	120.0	73.8	38.8	82.3	38.1	81.1	37.4	80.7	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.5	15.4	DB	47.5	93.6	3.4	1.4	45.1	94.6	43.1	95.5	41.2	96.3	38.7	97.3	(4)
(5)			WB	46.5	77.1	2.9	2.2	44.5	78.7	42.8	80.0	41.2	81.2	39.1	82.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.5	68.5	70.3	72.5	75.2	75.4	74.1	73.7	74.4	74.1	72.4	70.0	68.9	(6)	
	DBStd	3.39	2.95	2.82	2.98	2.64	2.15	1.82	1.72	1.76	1.61	2.41	2.95	2.79	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	19	8	2	1	0	0	0	0	0	0	0	3	5	(9)	
	CDD50	8205	575	568	699	757	789	724	734	755	724	695	599	586	(10)	
	CDD65	2750	118	150	235	307	324	274	269	290	274	230	153	126	(11)	
	CDH74	17376	695	1151	2029	2628	2257	1493	1460	1789	1620	1044	607	603	(12)	
	CDH80	4482	99	272	665	978	720	320	273	455	419	162	58	61	(13)	
(14) Wind	WSAvg	6.5	8.4	7.8	7.7	6.3	5.4	4.9	6.2	5.4	4.3	5.6	8.1	8.3	(14)	
(15) Precipitation	PrecAvg	43.1	0.6	0.4	0.6	1.5	5.7	7.3	4.6	4.8	6.4	7.0	2.0	1.0	(15)	
	PrecMax	55.8	1.7	1.2	2.4	6.9	11.2	16.7	12.0	17.1	13.7	20.3	6.5	3.4	(16)	
	PrecMin	30.1	0.3	0.2	0.1	0.0	2.3	1.5	1.9	0.8	2.9	2.1	0.8	0.5	(17)	
	PrecStd	7.8	0.3	0.2	0.6	1.7	2.7	3.3	2.4	3.7	2.7	3.7	1.2	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.8	89.5	91.3	91.8	91.5	87.5	86.2	88.2	87.9	85.9	84.1	84.4	(19)	
		MCWB	66.3	67.3	67.0	67.5	67.7	70.8	68.3	68.7	68.9	70.2	69.0	67.7	(20)	
	2%	DB	82.5	85.9	88.2	89.6	88.1	85.0	84.4	86.1	86.0	83.8	82.0	81.6	(21)	
		MCWB	65.5	65.4	66.3	66.8	67.9	70.1	68.3	68.7	69.4	69.8	68.3	66.6	(22)	
	5%	DB	80.5	83.6	86.2	87.8	86.2	83.8	82.7	84.4	84.3	82.1	80.0	79.7	(23)	
		MCWB	64.4	64.8	65.3	67.2	68.1	69.7	68.2	68.8	69.6	69.8	67.9	65.9	(24)	
	10%	DB	78.5	80.9	84.1	85.9	84.2	82.1	81.3	82.6	82.5	80.3	77.6	77.4	(25)	
		MCWB	64.2	64.0	64.8	66.6	68.2	69.5	68.2	68.7	69.6	69.4	67.5	65.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	69.7	71.1	73.0	73.3	73.8	72.6	73.2	73.1	73.2	71.9	70.9	(27)	
		MCDB	79.8	83.9	83.7	84.4	82.4	82.1	80.6	82.2	82.0	81.0	79.7	79.1	(28)	
	2%	WB	67.3	67.6	69.4	71.4	72.0	72.4	71.2	71.7	71.9	71.8	70.5	68.9	(29)	
		MCDB	77.3	80.5	80.9	81.9	81.1	81.0	79.6	81.2	81.3	79.9	77.9	76.6	(30)	
	5%	WB	66.3	66.4	68.0	70.2	71.0	71.5	70.3	70.8	71.1	70.9	69.3	67.7	(31)	
		MCDB	75.7	78.3	79.3	80.8	79.9	80.1	78.5	79.9	80.3	78.6	76.2	75.2	(32)	
	10%	WB	65.5	65.5	66.6	69.1	70.1	70.7	69.3	69.9	70.4	70.1	68.5	66.7	(33)	
		MCDB	74.3	76.7	77.8	79.4	78.5	78.6	77.2	78.7	79.1	77.2	74.9	73.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	22.4	24.1	23.1	19.6	17.5	17.2	19.2	19.2	16.6	16.8	18.4	(35)	
		MCDBR	24.8	27.3	28.2	25.8	22.4	19.8	19.2	21.2	21.5	19.4	19.8	22.5	(36)	
	5% WB	MCWBR	10.0	9.8	9.6	8.4	7.2	7.5	6.8	7.4	7.7	7.8	8.4	9.3	(37)	
		MCWBR	20.7	23.8	24.4	22.9	19.3	17.8	16.9	19.0	19.1	17.2	16.6	18.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.331	0.343	0.357	0.441	0.476	0.419	0.422	0.410	0.408	0.378	0.355	0.346	(40)	
		taud	2.575	2.538	2.487	2.228	2.163	2.385	2.356	2.392	2.386	2.509	2.549	2.554	(41)	
	Ebn at Noon		308	307	304	276	262	275	275	281	284	292	297	299	(42)	
		Edh at Noon	31	33	36	46	49	38	40	39	39	34	31	31	(43)	
(44) All-Sky Solar Radiation	RadAvg		1505	1747	1929	1885	1697	1696	1751	1812	1711	1513	1464	1420	(44)	
	RadStd		91	94	113	103	115	89	92	76	96	126	91	89	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page