

TEGUCIGALPA TONCONTIN, Honduras

WMO: 787200

Lat: 14.061N

Lon: 87.217W

Elev: 1004

StdP: 89.83

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.9	13.0	7.9	7.4	23.8	9.1	8.1	22.6	10.7	20.7	10.0	20.7	1.1	0	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	12.8	32.0	19.4	31.0	19.8	30.1	19.7	22.7	27.7	22.2	27.3	21.9	26.9	3.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	18.0	24.0	21.0	17.7	23.8	20.5	17.1	23.2	72.4	28.0	70.7	27.3	69.2	27.1	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.0	7.8	6.9	DB	8.6	34.2	1.9	0.8	7.3	34.8	6.2	35.3	5.1	35.7	3.7	36.3
(5)				WB	8.1	25.1	1.6	1.2	6.9	25.9	6.0	26.6	5.1	27.3	3.9	28.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	20.3	21.3	22.5	24.0	24.1	23.4	23.2	23.5	23.4	22.5	21.1	20.5
	DBStd	1.88	1.64	1.57	1.65	1.46	1.19	1.01	0.95	0.98	0.89	1.34	1.64	1.55
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	11	4	1	1	0	0	0	0	0	0	2	3	
	CDD10.0	4558	319	316	388	421	438	402	408	419	402	386	333	326
	CDD18.3	1528	66	83	131	171	180	152	149	161	152	128	85	70
	CDH23.3	9653	386	639	1127	1460	1254	829	811	994	900	580	337	335
	CDH26.7	2490	55	151	369	543	400	178	152	253	233	90	32	34
Wind	WSAvg	2.9	3.8	3.5	3.4	2.8	2.4	2.2	2.8	2.4	1.9	2.5	3.6	3.7
Precipitation	PrecAvg	1094	14	11	16	39	146	185	116	121	163	178	52	25
	PrecMax	1418	43	31	62	174	285	423	305	435	347	516	166	86
	PrecMin	764	8	6	3	0	58	39	47	21	73	53	20	12
	PrecStd	197	7	5	14	42	69	84	62	94	68	95	31	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.9	32.0	32.9	33.2	33.0	30.8	30.1	31.2	31.1	29.9	28.9	29.1
		MCWB	19.1	19.6	19.5	19.7	19.9	21.5	20.2	20.4	20.5	21.2	20.5	19.8
	2%	DB	28.1	29.9	31.2	32.0	31.2	29.5	29.1	30.1	30.0	28.8	27.8	27.6
		MCWB	18.6	18.6	19.1	19.4	20.0	21.1	20.2	20.4	20.8	21.0	20.2	19.2
	5%	DB	27.0	28.6	30.1	31.0	30.1	28.8	28.2	29.1	29.1	27.8	26.7	26.5
		MCWB	18.0	18.2	18.5	19.6	20.0	21.0	20.1	20.4	20.9	21.0	19.9	18.8
	10%	DB	25.8	27.2	28.9	29.9	29.0	27.8	27.4	28.1	28.1	26.8	25.3	25.2
		MCWB	17.9	17.8	18.2	19.2	20.1	20.8	20.1	20.4	20.9	20.8	19.7	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.0	21.7	22.8	23.0	23.2	22.5	22.9	22.9	22.9	22.2	21.6
		MCDB	26.5	28.8	28.7	29.1	28.0	27.8	27.0	27.9	27.8	27.2	26.5	26.2
	2%	WB	19.6	19.8	20.8	21.9	22.2	22.4	21.8	22.1	22.2	22.1	21.4	20.5
		MCDB	25.2	26.9	27.2	27.7	27.3	27.2	26.4	27.3	27.4	26.6	25.5	24.8
	5%	WB	19.1	19.1	20.0	21.2	21.7	21.9	21.3	21.5	21.7	21.6	20.7	19.8
		MCDB	24.3	25.7	26.3	27.1	26.6	26.7	25.8	26.6	26.8	25.9	24.5	24.0
	10%	WB	18.6	18.6	19.2	20.6	21.2	21.5	20.7	21.1	21.3	21.1	20.3	19.3
		MCDB	23.5	24.8	25.5	26.3	25.9	25.9	25.1	25.9	26.2	25.1	23.8	23.3
Mean Daily Temperature Range	5% DB	MDBR	11.0	12.5	13.4	12.8	10.9	9.7	9.6	10.7	10.7	9.2	9.3	10.2
		MCDBR	13.8	15.2	15.7	14.4	12.5	11.0	10.7	11.8	11.9	10.8	11.0	12.5
		MCWBR	5.6	5.4	5.3	4.7	4.0	4.1	3.8	4.1	4.3	4.3	4.7	5.2
	5% WB	MCDBR	11.5	13.2	13.6	12.7	10.7	9.9	9.4	10.5	10.6	9.6	9.2	10.5
		MCWBR	5.2	5.3	5.1	4.7	4.0	4.2	3.9	4.3	4.3	4.2	4.2	4.7
Clear-Sky Solar Irradiance	taub	0.331	0.343	0.357	0.441	0.476	0.419	0.422	0.410	0.408	0.378	0.355	0.346	
	taud	2.575	2.538	2.487	2.228	2.163	2.385	2.356	2.392	2.386	2.509	2.549	2.554	
	Ebn at Noon	970	968	957	871	827	867	867	887	894	921	937	944	
	Edh at Noon	97	105	113	146	153	121	125	122	123	106	99	97	
All-Sky Solar Radiation	RadAvg	4.74	5.51	6.08	5.94	5.35	5.35	5.52	5.71	5.39	4.77	4.62	4.48	
	RadStd	0.29	0.30	0.35	0.33	0.36	0.28	0.29	0.24	0.30	0.40	0.29	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page