

POINTE-A-PITRE LE RAIZET, Guadeloupe

WMO: 788970

Lat: 16.2639N

Lon: 61.5164W

Elev: 26

StdP: 14.68

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 00401

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	66.1	67.7	61.2	80.7	77.1	62.8	85.6	76.5	20.5	82.2	18.9	82.1	1.0	120	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.6	90.0	77.7	89.7	77.6	89.2	77.5	80.1	86.5	79.8	86.1	79.2	85.5	13.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	149.5	83.7	77.7	144.2	82.9	77.3	142.2	82.5	43.9	87.1	43.3	86.6	42.7	85.8	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	18.0	16.5	63.1	91.7	1.4	1.2	62.1	92.6	61.3	93.3	60.5	94.0	59.5	94.9
			61.8	81.3	1.2	1.1	60.9	82.1	60.2	82.7	59.5	83.3	58.6	84.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.9	76.7	76.8	77.4	79.1	80.9	82.1	82.2	82.3	81.9	81.1	79.6	77.9
	DBStd	2.67	1.72	1.79	2.00	1.87	1.65	1.51	1.43	1.37	1.48	1.48	1.66	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10895	829	751	848	872	958	962	999	1001	958	964	889	864
	CDD65	5420	364	331	383	422	493	512	534	536	508	499	439	399
	CDH74	50565	2484	2255	2897	3623	4933	5590	5864	5925	5352	4869	3802	2971
	CDH80	16055	528	483	731	1037	1588	1938	2077	2195	1956	1651	1144	727
Wind	WSAvg	7.5	7.2	8.2	7.8	8.1	8.5	9.1	8.6	7.5	6.2	5.9	5.8	6.6
Precipitation	PrecAvg	70.0	3.7	2.6	2.9	4.0	4.9	4.5	6.4	8.0	9.3	9.4	8.0	6.4
	PrecMax	103.6	9.5	5.6	9.7	14.4	11.4	11.9	16.2	14.9	17.4	17.0	16.7	20.5
	PrecMin	40.8	0.8	0.8	1.1	0.6	0.6	0.7	2.0	3.2	3.2	3.3	1.3	2.0
	PrecStd	19.4	2.5	1.4	2.2	3.3	3.1	3.2	3.9	3.2	3.5	3.1	4.1	5.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.3	86.4	87.9	88.2	89.9	90.0	90.9	91.5	91.5	90.0	89.5	87.6
		MCWB	74.4	73.7	74.7	75.5	76.3	76.7	77.3	78.2	78.8	78.1	78.2	76.5
	2%	DB	85.4	85.5	86.2	87.5	88.3	89.5	89.7	89.9	89.9	89.4	87.9	86.1
		MCWB	74.0	73.1	73.7	75.2	76.3	76.7	77.1	77.9	78.4	77.9	77.5	75.5
	5%	DB	84.2	84.2	85.1	86.2	87.8	88.2	88.6	89.3	89.3	88.0	86.4	84.7
		MCWB	73.4	72.6	73.2	74.6	76.2	76.7	77.1	77.9	78.3	77.9	76.8	74.8
	10%	DB	82.8	82.8	84.1	85.4	86.4	87.7	87.8	88.0	88.0	87.4	85.9	84.1
		MCWB	73.0	72.1	72.8	74.3	75.8	76.6	77.1	77.7	78.2	77.9	76.6	74.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.0	76.7	77.1	78.9	80.0	80.0	80.1	80.9	81.0	80.6	80.0	78.5
		MCDB	83.2	83.2	83.9	85.0	86.1	86.1	86.3	87.0	87.3	86.8	85.8	83.8
	2%	WB	75.6	75.3	75.7	77.5	78.7	79.1	79.4	80.0	80.1	79.9	79.1	77.4
		MCDB	82.0	81.6	82.5	83.7	84.8	85.4	85.6	86.4	86.8	86.0	84.9	83.3
	5%	WB	74.8	74.4	74.9	76.5	77.9	78.4	78.8	79.4	79.6	79.2	78.3	76.5
		MCDB	81.1	80.8	81.7	82.8	84.1	84.8	85.0	85.7	86.2	85.3	84.1	82.4
	10%	WB	74.2	73.5	74.2	75.6	77.1	77.8	78.2	78.8	79.0	78.7	77.6	75.6
		MCDB	80.4	80.0	81.0	81.9	83.6	84.2	84.4	85.1	85.5	84.7	83.4	81.4
Mean Daily Temperature Range	5% DB	MDBR	13.9	13.7	14.2	13.1	12.0	11.6	11.8	12.6	13.0	12.8	13.3	13.3
		MCDBR	14.8	14.6	15.1	13.9	12.9	12.3	12.7	13.6	14.1	14.0	14.1	14.1
		MCWBR	6.1	5.6	5.5	4.9	4.4	4.0	4.2	4.8	5.2	5.6	5.9	6.0
	5% WB	MCDBR	13.7	13.3	13.6	12.6	11.6	11.2	11.5	12.4	13.1	12.8	13.0	13.1
		MCWBR	6.4	5.9	5.6	5.1	4.7	4.5	4.6	5.2	5.5	5.7	6.0	6.1
Clear-Sky Solar Irradiance	taub	0.369	0.378	0.376	0.420	0.467	0.560	0.540	0.494	0.446	0.392	0.376	0.377	
	taud	2.583	2.544	2.552	2.444	2.312	2.008	2.067	2.231	2.411	2.590	2.624	2.589	
	Ebn at Noon	293	295	297	282	265	239	245	259	272	286	289	287	
	Edh at Noon	30	33	33	37	42	56	53	45	38	31	29	30	
All-Sky Solar Radiation	RadAvg	1571	1796	1979	2022	1971	1961	1973	1975	1853	1677	1518	1469	
	RadStd	54	60	66	77	115	90	89	86	90	95	104	65	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	-0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	+203	+202	

Nomenclature: See separate page