

POINTE-A-PITRE LE RAIZET, Guadeloupe

WMO: 788970

Lat: 16.2639N

Lon: 61.5164W

Elev: 8

StdP: 101.23

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 00401

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.9	19.8	16.2	11.5	25.0	17.1	12.2	24.7	9.1	27.9	8.5	27.8	0.5	120	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	32.2	25.4	32.1	25.3	31.8	25.3	26.7	30.3	26.6	30.1	26.2	29.7	6.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.4	28.7	25.4	20.6	28.3	25.2	20.3	28.1	84.2	30.6	82.9	30.3	81.5	29.9	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	8.0	7.4	DB	17.3	33.2	0.8	0.7	16.7	33.7	16.3	34.1	15.8	34.4	15.3	35.0	(4)
(5)			WB	16.6	27.4	0.7	0.6	16.1	27.8	15.7	28.2	15.3	28.5	14.8	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	24.9	24.9	25.2	26.1	27.2	27.8	27.9	27.9	27.3	26.5	25.5	(6)	
(7)		DBStd	1.48	0.95	1.00	1.11	1.04	0.92	0.84	0.80	0.76	0.82	0.82	0.92	0.96	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6053	461	417	471	484	532	534	555	556	532	536	494	480	(10)
(11)		CDD18.3	3011	202	184	213	234	274	284	297	298	282	277	244	222	(11)
(12)		CDH23.3	28092	1380	1253	1609	2013	2741	3106	3258	3292	2973	2705	2112	1651	(12)
(13)	CDH26.7	8919	293	268	406	576	882	1077	1154	1219	1087	917	636	404	(13)	
(14)	Wind	WSAvg	3.3	3.2	3.6	3.5	3.6	3.8	4.1	3.9	3.4	2.8	2.6	3.0	(14)	
(15)	Precipitation	PrecAvg	1778	95	66	73	101	125	114	162	202	237	239	202	162	(15)
(16)		PrecMax	2631	241	142	246	365	290	303	412	379	442	432	425	521	(16)
(17)		PrecMin	1037	20	21	28	15	15	19	51	82	82	84	34	50	(17)
(18)		PrecStd	494	64	36	55	83	78	81	100	81	90	78	104	126	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.2	30.2	31.1	31.2	32.1	32.2	32.7	33.1	33.1	32.2	31.9	30.9	(19)
(20)			MCWB	23.5	23.2	23.7	24.2	24.6	24.8	25.2	25.6	26.0	25.6	25.7	24.7	(20)
(21)		2%	DB	29.7	29.7	30.1	30.8	31.3	32.0	32.1	32.2	32.2	31.9	31.1	30.1	(21)
(22)			MCWB	23.3	22.8	23.2	24.0	24.6	24.8	25.1	25.5	25.8	25.5	25.3	24.2	(22)
(23)		5%	DB	29.0	29.0	29.5	30.1	31.0	31.2	31.4	31.9	31.8	31.1	30.2	29.3	(23)
(24)			MCWB	23.0	22.6	22.9	23.7	24.6	24.8	25.1	25.5	25.7	25.5	24.9	23.8	(24)
(25)		10%	DB	28.2	28.2	28.9	29.7	30.2	30.9	31.0	31.1	31.1	30.8	29.9	28.9	(25)
(26)			MCWB	22.8	22.3	22.7	23.5	24.3	24.8	25.1	25.4	25.7	25.5	24.8	23.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	24.8	25.1	26.0	26.7	26.7	27.1	27.2	27.0	26.7	25.8	(27)	
(28)			MCDWB	28.4	28.4	28.8	29.4	30.1	30.1	30.2	30.5	30.7	30.4	29.9	28.8	(28)
(29)		2%	WB	24.2	24.0	24.3	25.3	25.9	26.2	26.3	26.6	26.7	26.6	26.1	25.2	(29)
(30)			MCDWB	27.8	27.6	28.1	28.7	29.3	29.7	29.8	30.2	30.4	30.0	29.4	28.5	(30)
(31)		5%	WB	23.8	23.5	23.8	24.7	25.5	25.8	26.0	26.3	26.4	26.2	25.7	24.7	(31)
(32)			MCDWB	27.3	27.1	27.6	28.2	29.0	29.3	29.5	29.9	30.1	29.6	28.9	28.0	(32)
(33)		10%	WB	23.4	23.1	23.4	24.2	25.1	25.4	25.6	26.0	26.1	25.9	25.3	24.2	(33)
(34)			MCDWB	26.9	26.7	27.2	27.7	28.7	29.0	29.1	29.5	29.7	29.3	28.5	27.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.7	7.6	7.9	7.3	6.7	6.4	6.6	7.0	7.2	7.1	7.4	7.4	(35)
(36)			MCDBR	8.2	8.1	8.4	7.7	7.2	6.8	7.1	7.5	7.9	7.8	7.8	7.8	(36)
(37)			MCWBR	3.4	3.1	3.1	2.7	2.4	2.2	2.3	2.7	2.9	3.1	3.3	3.3	(37)
(38)		5% WB	MCDBR	7.6	7.4	7.5	7.0	6.4	6.2	6.4	6.9	7.3	7.1	7.2	7.3	(38)
(39)			MCWBR	3.6	3.3	3.1	2.8	2.6	2.5	2.6	2.9	3.1	3.2	3.3	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.378	0.376	0.420	0.467	0.560	0.540	0.494	0.446	0.392	0.376	0.377	(40)	
(41)		taud	2.583	2.544	2.552	2.444	2.312	2.008	2.067	2.231	2.411	2.590	2.624	2.589	(41)	
(42)		Ebn at Noon	924	929	937	889	836	754	771	815	859	903	910	905	(42)	
(43)		Edh at Noon	95	103	105	117	132	177	167	143	119	97	91	93	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.95	5.66	6.24	6.38	6.21	6.18	6.22	6.23	5.84	5.29	4.78	4.63	(44)	
(45)		RadStd	0.17	0.19	0.21	0.24	0.36	0.28	0.28	0.27	0.28	0.30	0.33	0.21	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	-0.48	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	+113	+112	(47)

Nomenclature: See separate page