

CALI, Colombia

WMO: 802590

Lat: 3.543N

Lon: 76.382W

Elev: 964

StdP: 90.27

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	17.7	18.0	15.2	12.1	25.9	16.0	12.8	24.8	7.4	26.6	6.6	26.7	0.7	80	0.255

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	32.8	22.2	32.0	22.1	31.1	22.0	23.5	29.7	23.0	29.4	22.7	29.1	3.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	18.7	25.9	21.2	17.9	25.0	21.0	17.7	24.7	75.5	30.0	73.8	29.7	72.6	29.4	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.7	6.0	5.3	DB	14.7	34.3	2.1	1.2	13.1	35.2	11.9	35.8	10.7	36.5	9.2	37.3	(4)
			WB	14.0	25.7	1.8	1.1	12.7	26.5	11.7	27.2	10.7	27.8	9.4	28.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	24.5	24.8	24.7	24.5	24.4	24.3	24.6	24.8	24.7	24.2	24.0	24.2
	DBStd	1.13	1.16	1.16	1.26	1.11	1.07	0.98	0.95	1.03	1.16	1.17	1.04	1.10
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5280	449	414	454	434	447	429	452	459	440	439	421	441
	CDD18.3	2238	191	181	196	184	188	179	193	201	190	181	171	183
	CDH23.3	14683	1276	1260	1293	1122	1141	1159	1383	1527	1358	1092	956	1116
	CDH26.7	4657	412	437	429	333	326	334	461	559	475	318	244	328
Wind	WSAvg	1.9	1.9	2.0	1.8	1.7	1.7	1.7	2.0	2.2	2.2	2.0	1.8	1.8
Precipitation	PrecAvg	947	51	64	94	141	102	59	33	39	63	115	105	69
	PrecMax	1395	163	171	191	373	204	173	105	119	163	222	342	155
	PrecMin	516	0	1	16	20	17	4	0	0	2	38	22	3
	PrecStd	199	32	43	41	66	48	42	23	33	36	45	56	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	33.0	32.9	32.1	31.8	31.9	32.9	33.7	33.2	32.1	31.2	32.1
		MCWB	22.6	22.9	22.8	22.7	23.1	22.2	21.9	21.2	21.7	22.1	22.3	22.5
	2%	DB	31.2	31.7	31.5	30.9	30.6	30.8	31.2	32.1	31.9	30.9	30.1	30.9
		MCWB	22.1	22.3	22.4	22.5	22.6	22.1	21.9	21.4	21.7	22.0	22.1	22.1
	5%	DB	30.1	30.7	30.2	29.9	29.8	29.8	30.2	31.0	30.8	29.8	29.1	29.9
		MCWB	22.0	22.0	22.2	22.3	22.4	22.1	21.8	21.6	21.7	21.9	21.9	22.0
	10%	DB	29.1	29.6	29.1	28.9	28.8	28.9	29.2	29.9	29.7	28.7	28.1	28.8
		MCWB	21.7	21.8	21.9	22.1	22.2	22.0	21.7	21.6	21.7	21.6	21.6	21.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.3	23.5	23.7	24.0	23.6	23.7	23.4	23.1	23.0	23.1	23.1
		MCDB	30.3	30.7	30.3	29.3	30.0	28.9	29.3	29.8	30.1	29.5	29.2	29.7
	2%	WB	22.6	22.7	22.8	23.0	23.2	22.7	22.7	22.5	22.5	22.4	22.5	22.6
		MCDB	29.5	29.8	29.5	29.0	29.0	28.7	29.1	29.5	29.6	28.9	28.5	29.0
	5%	WB	22.2	22.3	22.4	22.6	22.6	22.3	22.2	22.1	22.0	22.0	22.1	22.2
		MCDB	28.9	29.2	28.9	28.3	28.3	28.2	28.8	29.2	29.3	28.5	28.0	28.5
	10%	WB	21.8	21.9	22.0	22.2	22.2	22.0	21.8	21.6	21.6	21.6	21.7	21.8
		MCDB	28.1	28.3	28.3	27.7	27.6	27.9	28.1	28.3	28.3	27.5	27.1	27.6
Mean Daily Temperature Range	5% DB	MDBR	10.4	10.7	10.3	9.8	9.6	10.0	10.9	11.6	11.1	10.0	9.6	9.8
		MCDBR	11.7	12.0	11.6	10.9	10.8	11.2	12.0	13.2	12.7	11.4	10.6	11.3
		MCWBR	4.0	3.9	3.9	3.8	3.9	3.9	4.0	4.2	4.0	3.8	3.8	3.9
	5% WB	MCDBR	10.9	11.1	10.8	10.2	10.1	10.3	11.1	11.7	11.6	10.5	9.9	10.3
	MCWBR	3.9	3.8	3.9	3.8	4.0	4.0	4.1	4.1	4.0	3.8	3.7	3.8	
Clear-Sky Solar Irradiance	taub	0.412	0.451	0.453	0.425	0.398	0.373	0.384	0.406	0.418	0.407	0.408	0.406	
	taud	2.401	2.280	2.289	2.378	2.466	2.553	2.507	2.424	2.381	2.435	2.430	2.434	
	Ebn at Noon	911	880	876	883	886	898	891	888	893	910	908	911	
	Edh at Noon	122	140	139	125	111	100	106	118	125	119	118	117	
All-Sky Solar Radiation	RadAvg	4.20	4.18	4.04	4.14	4.05	4.01	4.13	4.21	4.30	4.15	3.94	3.98	
	RadStd	0.24	0.28	0.17	0.15	0.13	0.13	0.20	0.21	0.21	0.15	0.15	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page