

LETICIA, Colombia

WMO: 803980

Lat: 4.193S

Lon: 69.943W

Elev: 277

StdP: 14.55

Time Zone: -5.00 (W05)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	67.0	69.6	62.9	86.8	70.6	66.4	98.2	72.7	10.4	75.7	9.1	74.8	2.4	180	0.232

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.7	93.2	81.1	91.7	80.7	91.0	80.5	83.2	90.0	82.5	89.0	81.8	88.1	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	162.7	87.8	80.7	161.0	87.5	80.2	158.2	86.7	47.4	91.0	46.6	89.6	45.9	88.8	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.5	6.7	DB	63.0	95.7	3.2	1.5	60.7	96.7	58.8	97.6	57.0	98.4	54.7	99.5	(4)
(5)			WB	61.7	84.8	3.1	0.8	59.5	85.4	57.7	85.9	55.9	86.3	53.7	86.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	80.4	80.2	80.6	80.2	80.0	79.1	78.6	79.9	81.0	81.1	81.5	80.7	
	DBStd	2.40	2.29	2.21	2.12	2.12	1.87	2.73	2.77	2.43	2.34	2.14	2.07	1.97	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11056	943	846	949	907	930	874	888	928	931	965	944	951	
	CDD65	5581	478	426	484	457	465	424	423	463	481	500	494	486	
	CDH74	43018	3551	3142	3764	3529	3455	3006	2953	3641	4026	4082	4193	3676	
	CDH80	14402	1067	933	1178	1068	962	917	967	1432	1656	1559	1524	1139	
Wind	WSAvg	1.8	1.7	1.8	2.0	2.0	1.6	1.8	1.8	1.9	2.1	1.9	1.7	1.8	
Precipitation	PrecAvg	129.3	15.0	12.6	13.9	13.1	11.2	7.6	6.1	5.8	8.3	10.3	11.4	12.8	
	PrecMax	151.3	25.7	20.3	22.2	20.3	21.5	14.9	12.5	14.4	16.0	22.5	21.3	24.2	
	PrecMin	93.0	1.1	3.4	1.6	8.2	0.7	0.4	0.7	1.8	2.7	3.5	0.9	2.4	
	PrecStd	15.2	5.2	3.6	4.5	3.0	4.5	3.2	3.0	2.7	3.4	4.4	4.4	4.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.8	91.7	91.8	91.4	91.0	90.6	91.5	93.2	94.8	94.1	93.5	91.8	
		MCWB	82.2	81.2	81.3	80.2	81.2	80.2	78.3	79.9	80.0	81.6	81.7	81.5	
	2%	DB	89.9	89.8	89.9	89.6	88.2	88.4	89.3	91.4	92.9	92.2	91.6	90.0	
		MCWB	80.9	80.4	80.6	80.3	80.3	79.7	78.3	79.5	80.6	81.2	81.2	80.7	
	5%	DB	88.0	88.0	88.2	87.9	87.4	87.3	87.6	89.6	91.2	90.6	89.9	88.2	
		MCWB	80.5	80.2	80.2	79.9	80.0	79.4	78.3	79.0	80.0	80.7	80.7	80.5	
	10%	DB	86.1	86.0	86.4	86.1	85.6	85.6	85.8	87.8	89.3	88.2	88.0	86.3	
		MCWB	79.6	79.6	79.5	79.3	79.4	78.6	77.8	78.9	79.4	80.2	80.4	79.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.7	83.2	83.7	82.7	82.2	81.8	81.0	82.0	83.4	83.5	84.0	83.4
			MCDB	90.2	89.6	89.4	88.2	87.7	87.2	87.1	89.6	90.9	91.5	91.4	90.0
2%		WB	82.1	81.8	82.2	81.6	81.0	80.8	80.0	81.0	82.0	82.4	82.6	82.0	
		MCDB	87.9	87.8	87.6	87.1	86.5	86.5	85.9	88.4	90.0	90.3	89.2	88.1	
5%		WB	80.8	80.6	81.0	80.6	80.3	79.9	79.1	80.0	80.9	81.4	81.5	80.9	
		MCDB	86.3	86.2	86.5	86.0	85.5	85.3	84.7	87.1	88.7	88.6	87.8	86.5	
10%		WB	79.7	79.6	80.0	79.7	79.5	79.0	78.4	79.1	79.8	80.3	80.5	80.0	
		MCDB	84.6	84.4	84.9	84.4	83.9	83.8	83.8	85.7	87.0	86.8	86.6	85.1	
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.8	13.3	12.9	12.4	13.4	14.6	16.7	16.7	15.6	14.7	13.2	
		MCDBR	15.3	15.6	15.5	15.1	14.6	15.7	17.3	19.2	19.4	18.8	17.0	15.6	
		MCWBR	7.6	7.7	7.4	7.4	7.0	7.9	8.1	9.1	8.9	8.9	8.4	8.2	
	5% WB	MCDBR	14.3	14.2	14.5	13.9	13.4	14.5	15.1	17.6	17.8	17.3	16.0	14.6	
		MCWBR	7.7	7.6	7.7	7.4	7.0	7.8	8.0	8.9	9.0	9.0	8.6	8.1	
Clear-Sky Solar Irradiance	taub	0.397	0.398	0.392	0.387	0.389	0.386	0.397	0.487	0.507	0.447	0.432	0.408		
	taud	2.519	2.514	2.542	2.556	2.540	2.552	2.508	2.213	2.160	2.343	2.393	2.471		
	Ebn at Noon	298	297	295	289	280	277	275	257	259	279	285	293		
	Edh at Noon	35	36	34	33	32	31	33	45	49	42	40	37		
All-Sky Solar Radiation	RadAvg	1379	1362	1410	1400	1319	1327	1401	1509	1587	1538	1508	1393		
	RadStd	73	80	55	56	75	77	91	89	82	62	76	74		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page