

LETICIA, Colombia

WMO: 803980

Lat: 4.193S

Lon: 69.943W

Elev: 84

StdP: 100.32

Time Zone: -5.00 (W05)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	20.9	17.2	12.4	21.5	19.1	14.0	22.6	4.7	24.3	4.1	23.8	1.1	180	0.232

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.1	34.0	27.3	33.2	27.0	32.8	26.9	28.5	32.2	28.0	31.7	27.6	31.2	1.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.2	31.0	27.0	23.0	30.8	26.8	22.6	30.4	92.3	32.8	90.5	32.0	88.8	31.5	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.9	3.4	3.0	DB	17.2	35.4	1.8	0.8	15.9	36.0	14.9	36.4	13.9	36.9	12.6	37.5	(4)
(5)			WB	16.5	29.4	1.7	0.4	15.3	29.7	14.3	29.9	13.3	30.2	12.0	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	26.9	26.8	27.0	26.8	26.7	26.2	25.9	26.6	27.2	27.3	27.5	27.0	
	DBStd	1.33	1.27	1.23	1.18	1.18	1.04	1.51	1.54	1.35	1.30	1.19	1.15	1.10	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6142	524	470	527	504	517	486	493	516	517	536	524	528	
	CDD18.3	3101	266	237	269	254	258	236	235	257	267	278	274	270	
	CDH23.3	23899	1973	1746	2091	1961	1919	1670	1641	2023	2237	2268	2329	2042	
	CDH26.7	8001	593	518	654	593	534	509	537	796	920	866	847	633	
Wind	WSAvg	0.8	0.7	0.8	0.9	0.9	0.7	0.8	0.8	0.9	1.0	0.9	0.8	0.8	
Precipitation	PrecAvg	3283	381	321	353	334	285	194	156	148	212	261	290	325	
	PrecMax	3843	653	516	565	516	545	378	317	365	407	571	540	615	
	PrecMin	2363	29	86	41	209	19	11	19	45	69	89	24	62	
	PrecStd	387	132	92	115	77	115	81	76	69	86	113	111	117	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	33.2	33.2	33.0	32.8	32.5	33.0	34.0	34.9	34.5	34.2	33.2	
		MCWB	27.9	27.3	27.4	26.8	27.3	26.8	25.7	26.6	26.7	27.6	27.6	27.5	
	2%	DB	32.2	32.1	32.2	32.0	31.2	31.4	31.9	33.0	33.9	33.4	33.1	32.2	
		MCWB	27.2	26.9	27.0	26.8	26.8	26.5	25.7	26.4	27.0	27.3	27.3	27.1	
	5%	DB	31.1	31.1	31.2	31.1	30.8	30.7	30.9	32.0	32.9	32.6	32.2	31.2	
		MCWB	26.9	26.8	26.8	26.6	26.7	26.3	25.7	26.1	26.7	27.0	27.0	26.9	
	10%	DB	30.0	30.0	30.2	30.1	29.8	29.8	29.9	31.0	31.9	31.2	31.1	30.2	
		MCWB	26.4	26.4	26.4	26.3	26.3	25.9	25.4	26.0	26.3	26.8	26.9	26.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.7	28.4	28.7	28.2	27.9	27.7	27.2	27.8	28.5	28.6	28.9	28.6
			MCDB	32.3	32.0	31.9	31.2	31.0	30.7	30.6	32.0	32.7	33.1	33.0	32.2
2%		WB	27.8	27.6	27.9	27.6	27.2	27.1	26.6	27.2	27.8	28.0	28.1	27.8	
		MCDB	31.0	31.0	30.9	30.6	30.3	30.3	29.9	31.3	32.2	32.4	31.8	31.2	
5%		WB	27.1	27.0	27.2	27.0	26.8	26.6	26.2	26.7	27.2	27.4	27.5	27.2	
		MCDB	30.2	30.1	30.3	30.0	29.7	29.6	29.3	30.6	31.5	31.4	31.0	30.3	
10%		WB	26.5	26.5	26.6	26.5	26.4	26.1	25.8	26.2	26.6	26.9	27.0	26.7	
		MCDB	29.2	29.1	29.4	29.1	28.8	28.8	28.8	29.8	30.5	30.5	30.3	29.5	
Mean Daily Temperature Range		5% DB	MDBR	7.0	7.1	7.4	7.2	6.9	7.4	8.1	9.3	9.3	8.7	8.1	7.3
			MCDBR	8.5	8.7	8.6	8.4	8.1	8.7	9.6	10.7	10.8	10.5	9.4	8.7
	MCWBR		4.2	4.3	4.1	4.1	3.9	4.4	4.5	5.0	4.9	5.0	4.6	4.5	
	5% WB	MCDBR	7.9	7.9	8.1	7.7	7.5	8.1	8.4	9.8	9.9	9.6	8.9	8.1	
		MCWBR	4.3	4.2	4.3	4.1	3.9	4.3	4.4	5.0	5.0	5.0	4.8	4.5	
Clear-Sky Solar Irradiance	taub	0.397	0.398	0.392	0.387	0.389	0.386	0.397	0.487	0.507	0.447	0.432	0.408		
	taud	2.519	2.514	2.542	2.556	2.540	2.552	2.508	2.213	2.160	2.343	2.393	2.471		
	Ebn at Noon	939	936	930	911	884	872	868	811	817	880	899	924		
	Edh at Noon	111	113	108	103	101	97	103	143	156	132	125	116		
All-Sky Solar Radiation	RadAvg	4.35	4.29	4.44	4.41	4.16	4.18	4.42	4.76	5.00	4.85	4.75	4.39		
	RadStd	0.23	0.25	0.17	0.18	0.23	0.24	0.29	0.28	0.26	0.20	0.24	0.23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page