

SAN ANTONIO DEL TACHIRA, Venezuela

WMO: 804470

Lat: 7.841N

Lon: 72.440W

Elev: 400

StdP: 96.61

Time Zone: -4.00 (W04)

Period: 90-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.9	20.8	12.8	9.7	27.7	13.8	10.4	27.5	10.7	30.7	9.5	31.2	0.5	180	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	9.8	35.2	23.5	34.8	23.4	34.0	23.2	25.9	31.3	25.3	30.9	24.9	30.6	5.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.8	27.5	24.1	19.9	27.0	23.5	19.3	26.6	82.7	31.6	80.1	30.8	78.3	30.7	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.4	9.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	26.2	26.6	26.7	27.4	27.8	27.9	27.7	28.4	28.5	28.0	27.1	26.4
	DBStd	1.64	1.45	1.59	1.94	1.67	1.49	1.43	1.32	1.30	1.21	1.43	1.23	1.20
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6353	502	465	518	523	553	536	549	569	556	558	514	508
	CDD18.3	3312	244	232	259	273	295	286	291	311	306	300	264	250
	CDH23.3	31714	1978	2048	2282	2591	3003	2972	2956	3323	3301	2988	2281	1991
(14) Wind	WSAvg	3.3	1.9	2.0	2.0	2.1	3.7	5.5	5.7	5.1	4.4	2.9	1.9	2.0
	PrecAvg	728	39	39	45	96	75	32	27	30	47	104	113	76
	PrecMax	1168	202	170	180	384	253	189	125	207	192	245	281	282
	PrecMin	388	0	0	1	4	6	2	0	4	7	23	8	2
	PrecStd	188	49	35	40	82	65	32	21	31	38	60	76	69
	DB	34.1	35.0	36.0	36.0	35.2	34.8	35.0	35.9	36.2	36.0	34.8	34.0	34.0
	MCWB	22.4	22.7	24.2	24.7	23.5	23.1	23.1	23.6	23.4	23.4	23.8	23.1	23.1
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	33.0	33.9	33.9	34.2	34.1	33.5	33.4	34.4	35.0	34.5	33.3	32.9	32.9
	2% MCWB	22.8	22.8	23.6	23.8	23.4	23.0	22.7	23.1	23.4	23.3	23.7	23.2	23.2
	5% DB	32.0	32.7	32.7	33.0	33.1	32.8	32.5	33.2	34.0	33.8	32.4	31.9	31.9
	5% MCWB	22.7	22.7	23.3	23.5	23.1	22.7	22.5	22.9	23.2	23.3	23.6	23.1	23.1
	10% DB	31.0	31.2	31.2	31.9	32.0	31.8	31.6	32.2	33.0	32.7	31.3	30.9	30.9
	10% MCWB	22.6	22.6	22.9	23.2	22.8	22.4	22.3	22.5	22.8	23.1	23.2	23.1	23.1
	WB	25.2	24.9	26.0	26.6	26.2	25.6	25.4	25.6	25.9	26.0	26.1	25.7	25.7
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	31.0	31.8	31.4	32.3	31.4	30.2	30.9	32.2	31.7	31.8	31.7	30.7	30.7
	2% WB	24.2	24.1	25.1	25.6	25.2	24.5	24.2	24.6	24.8	25.0	25.1	25.0	25.0
	2% MCDB	30.1	30.3	30.8	31.0	29.9	30.1	30.2	31.5	31.5	31.2	30.8	30.4	30.4
	5% WB	23.6	23.6	24.3	24.9	24.7	23.7	23.4	23.9	24.1	24.4	24.5	24.3	24.3
	5% MCDB	29.4	29.4	29.6	30.1	29.2	29.8	29.8	30.3	30.6	30.3	29.8	29.1	29.1
	10% WB	23.1	23.2	23.7	24.2	24.0	23.1	22.8	23.3	23.5	23.9	24.0	23.7	23.7
	10% MCDB	28.7	28.6	28.7	28.8	28.8	29.4	29.4	29.9	30.1	29.5	28.8	28.2	28.2
(35) Mean Daily Temperature Range	MDBR	9.8	9.4	8.9	9.0	8.8	7.9	8.0	8.8	9.8	9.8	9.6	9.2	9.2
	5% DB	11.3	11.5	10.7	10.5	10.3	9.4	9.5	10.1	11.0	10.9	10.8	10.8	10.8
	5% WB	5.0	4.7	4.2	4.5	4.5	4.1	3.9	4.2	4.4	4.4	4.5	4.8	4.8
	MCDBR	10.3	10.0	9.5	9.8	9.5	8.6	8.6	9.6	10.3	10.1	10.2	9.6	9.6
	MCWBR	4.9	4.5	4.4	4.8	4.8	4.5	4.3	4.6	4.8	4.5	4.7	4.6	4.6
(40) Clear-Sky Solar Irradiance	taub	0.430	0.472	0.532	0.566	0.468	0.446	0.444	0.462	0.440	0.473	0.425	0.443	0.443
	taud	2.341	2.206	2.038	1.952	2.266	2.337	2.337	2.275	2.335	2.249	2.395	2.326	2.326
	Ebn at Noon	883	856	806	769	830	837	843	841	871	844	882	862	862
	Edh at Noon	127	149	179	192	137	125	126	137	131	141	120	127	127
(44) All-Sky Solar Radiation	RadAvg	4.42	4.50	4.01	3.96	4.41	4.47	4.59	4.91	5.01	4.74	4.25	4.21	4.21
	RadStd	0.47	0.47	0.54	0.31	0.18	0.20	0.19	0.20	0.20	0.18	0.22	0.33	0.33

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page