

TIMEHRI, Guyana

WMO: 810020

Lat: 6.500N

Lon: 58.250W

Elev: 98

StdP: 14.64

Time Zone: -4.00 (W04)

Period: 96-19

WBAN: 10502

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.5	70.5	67.5	101.5	78.6	68.0	103.3	78.2	22.8	84.8	20.0	84.4	1.3	250	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	17.2	92.4	78.5	91.5	78.3	90.0	77.9	80.4	87.0	80.0	86.5	79.6	86.1	10.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.9	83.4	78.5	148.3	82.9	77.4	143.2	82.1	44.1	87.8	43.6	87.1	43.2	86.7	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	16.5	14.5	DB	66.7	95.2	1.6	1.5	65.6	96.3	64.6	97.2	63.7	98.0	62.6	99.1	
			WB	66.1	82.9	1.4	1.2	65.0	83.8	64.2	84.4	63.4	85.1	62.3	85.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	78.5	78.6	79.5	80.4	80.2	80.1	80.3	81.2	82.0	81.9	81.1	79.5
	DBStd	1.87	1.50	1.57	1.74	1.56	1.73	1.52	1.39	1.39	1.43	1.45	1.55	1.56
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11053	885	801	915	913	937	903	938	968	959	988	932	914
	CDD65	5578	420	381	450	463	472	453	473	503	509	523	482	449
	CDH74	45984	2993	2726	3720	4040	3903	3543	3718	4300	4649	4795	4200	3397
	CDH80	16130	886	810	1337	1429	1192	1038	1218	1636	1964	2003	1567	1050
(14) Wind	WSAvg	5.2	5.5	6.2	6.3	6.1	5.5	4.8	4.4	4.5	4.8	4.8	4.8	5.0
(15) Precipitation	PrecAvg	90.7	9.9	5.2	4.0	6.5	12.8	13.0	10.7	7.6	4.0	3.8	6.5	9.8
	PrecMax	116.5	32.4	18.4	11.7	14.1	20.1	21.4	17.2	18.7	7.0	6.6	15.1	19.5
	PrecMin	64.9	0.9	0.7	1.0	1.5	5.7	5.0	6.0	2.9	1.0	1.7	1.7	3.0
	PrecStd	14.2	7.3	4.3	2.6	4.0	3.9	4.2	2.8	3.5	1.7	1.3	3.2	4.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.3	89.6	91.2	91.6	91.1	90.0	91.0	92.1	93.6	93.6	92.6	89.9
		MCWB	75.8	76.6	76.9	77.4	77.8	78.0	78.2	78.6	78.8	78.7	78.3	77.7
	2%	DB	87.7	87.8	89.5	89.9	89.5	89.2	89.5	91.1	91.8	92.3	91.2	88.2
		MCWB	76.0	76.0	76.5	77.0	77.6	78.0	77.9	78.5	78.6	78.5	78.2	77.6
	5%	DB	86.2	86.2	88.0	88.7	87.9	87.6	87.9	89.7	91.2	91.2	89.6	87.5
		MCWB	75.9	75.6	76.4	76.9	77.8	78.3	78.2	78.3	78.5	78.4	78.0	77.5
	10%	DB	85.0	84.8	86.4	87.5	86.2	85.9	86.3	88.1	89.6	89.6	88.0	85.9
		MCWB	75.8	75.4	76.0	76.9	77.7	78.1	78.2	78.5	78.3	78.2	78.3	77.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.1	79.0	79.4	80.0	80.1	80.1	80.1	80.8	81.0	80.7	80.5	79.9
		MCDB	83.9	84.5	86.2	85.6	85.3	85.4	86.1	87.6	88.5	88.2	86.8	85.1
	2%	WB	78.2	78.0	78.3	79.1	79.5	79.4	79.4	79.9	80.1	80.0	79.8	79.1
		MCDB	83.1	83.6	85.0	84.9	84.7	84.8	85.5	86.9	87.8	87.5	86.2	84.6
	5%	WB	77.5	77.2	77.6	78.4	79.0	79.0	79.0	79.3	79.7	79.4	79.2	78.6
		MCDB	82.6	83.0	84.6	84.4	84.2	84.4	85.1	86.3	87.4	87.0	85.7	84.1
	10%	WB	76.8	76.5	76.9	77.9	78.4	78.4	78.4	78.8	79.1	79.0	78.8	78.0
		MCDB	82.1	82.0	83.9	84.0	83.5	83.7	84.3	85.9	86.8	86.5	85.4	83.4
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	13.7	15.4	14.5	12.8	13.0	14.4	15.8	17.3	17.2	15.4	13.5
		MCDBR	15.9	15.8	17.3	16.9	15.4	15.2	15.9	17.3	18.8	19.0	17.3	15.9
		MCWBR	6.5	6.2	6.5	5.9	5.7	6.2	6.5	6.7	7.1	6.9	6.5	6.5
	5% WB	MCDBR	13.2	13.2	15.3	14.0	12.7	13.3	14.6	16.0	17.5	17.3	15.6	13.7
		MCWBR	6.3	6.1	6.5	5.9	5.9	6.1	6.6	6.9	7.4	7.1	6.7	6.4
(40) Clear-Sky Solar Irradiance	taub		0.410	0.432	0.462	0.499	0.461	0.429	0.429	0.412	0.414	0.412	0.400	0.432
	taud		2.477	2.394	2.293	2.176	2.324	2.438	2.429	2.468	2.451	2.476	2.513	2.417
	Ebn at Noon		288	284	275	260	265	270	271	280	284	286	289	279
	Edh at Noon		36	39	44	49	41	36	36	36	37	36	34	37
(44) All-Sky Solar Radiation	RadAvg		1420	1483	1581	1525	1394	1426	1541	1724	1774	1666	1484	1348
	RadStd		106	106	80	89	100	64	48	61	70	83	84	102

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page