

TIMEHRI, Guyana

WMO: 810020

Lat: 6.500N

Lon: 58.250W

Elev: 30

StdP: 100.97

Time Zone: -4.00 (W04)

Period: 96-19

WBAN: 10502

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	21.4	19.7	14.5	25.9	20.0	14.8	25.7	10.2	29.3	8.9	29.1	0.6	250	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.5	33.6	25.8	33.0	25.7	32.2	25.5	26.9	30.5	26.6	30.3	26.4	30.1	4.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.6	28.6	25.8	21.2	28.3	25.2	20.5	27.8	84.7	31.0	83.5	30.6	82.6	30.4	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.4	6.5	DB	19.3	35.1	0.9	0.8	18.6	35.7	18.1	36.2	17.6	36.7	17.0	37.3	(4)
(5)			WB	18.9	28.3	0.8	0.6	18.4	28.8	17.9	29.1	17.4	29.5	16.9	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	25.9	25.9	26.4	26.9	26.8	26.7	26.8	27.3	27.8	27.7	27.3	26.4	(6)
(7)		DBStd	1.04	0.83	0.87	0.97	0.87	0.96	0.84	0.77	0.77	0.79	0.80	0.86	0.87	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6141	492	445	508	507	521	502	521	538	533	549	518	508	(10)
(11)		CDD18.3	3099	233	212	250	257	262	252	263	279	283	291	268	249	(11)
(12)		CDH23.3	25547	1663	1514	2067	2244	2168	1968	2066	2389	2583	2664	2333	1887	(12)
(13)		CDH26.7	8961	492	450	743	794	662	577	677	909	1091	1113	871	583	(13)
(14)	Wind	WSAvg	2.3	2.5	2.8	2.8	2.7	2.5	2.2	2.0	2.0	2.1	2.2	2.1	2.2	(14)
(15)	Precipitation	PrecAvg	2304	252	131	101	165	325	329	271	192	101	97	165	249	(15)
(16)		PrecMax	2960	824	467	298	358	511	544	436	474	178	167	383	495	(16)
(17)		PrecMin	1648	22	17	26	37	144	126	152	74	26	42	44	75	(17)
(18)		PrecStd	361	186	110	66	101	99	107	70	88	42	34	82	109	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	32.0	32.9	33.1	32.8	32.2	32.8	33.4	34.2	34.2	33.7	32.2	(19)
(20)			MCWB	24.3	24.8	25.0	25.2	25.4	25.6	25.6	25.9	26.0	26.0	25.7	25.4	(20)
(21)		2%	DB	30.9	31.0	32.0	32.2	32.0	31.8	31.9	32.8	33.2	33.5	32.9	31.2	(21)
(22)			MCWB	24.4	24.5	24.7	25.0	25.3	25.6	25.5	25.8	25.9	25.9	25.7	25.3	(22)
(23)		5%	DB	30.1	30.1	31.1	31.5	31.1	30.9	31.1	32.0	32.9	32.9	32.0	30.8	(23)
(24)			MCWB	24.4	24.2	24.7	24.9	25.4	25.7	25.7	25.7	25.8	25.8	25.5	25.3	(24)
(25)		10%	DB	29.4	29.3	30.2	30.9	30.1	30.0	30.2	31.1	32.0	32.0	31.1	29.9	(25)
(26)			MCWB	24.3	24.1	24.4	24.9	25.4	25.6	25.6	25.8	25.7	25.7	25.7	25.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.1	26.3	26.7	26.7	26.7	26.7	27.1	27.2	27.1	27.0	26.6	(27)
(28)			MCDWB	28.8	29.2	30.1	29.8	29.6	29.7	30.1	30.9	31.4	31.2	30.5	29.5	(28)
(29)		2%	WB	25.7	25.6	25.7	26.2	26.4	26.4	26.3	26.6	26.7	26.7	26.6	26.2	(29)
(30)			MCDWB	28.4	28.7	29.4	29.4	29.3	29.3	29.7	30.5	31.0	30.8	30.1	29.2	(30)
(31)		5%	WB	25.3	25.1	25.3	25.8	26.1	26.1	26.1	26.3	26.5	26.4	26.2	25.9	(31)
(32)			MCDWB	28.1	28.3	29.2	29.1	29.0	29.1	29.5	30.2	30.8	30.6	29.8	29.0	(32)
(33)		10%	WB	24.9	24.7	24.9	25.5	25.8	25.8	25.8	26.0	26.2	26.1	26.0	25.6	(33)
(34)			MCDWB	27.8	27.8	28.8	28.9	28.6	28.7	29.1	29.9	30.4	30.3	29.6	28.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	7.6	8.6	8.1	7.1	7.2	8.0	8.8	9.6	9.5	8.6	7.5	(35)
(36)			MCDBR	8.8	8.8	9.6	9.4	8.5	8.5	8.8	9.6	10.5	10.6	9.6	8.9	(36)
(37)			MCWBR	3.6	3.4	3.6	3.3	3.2	3.4	3.6	3.7	4.0	3.8	3.6	3.6	(37)
(38)		5% WB	MCDWB	7.3	7.3	8.5	7.8	7.0	7.4	8.1	8.9	9.7	9.6	8.7	7.6	(38)
(39)			MCWBR	3.5	3.4	3.6	3.3	3.3	3.4	3.7	3.8	4.1	3.9	3.7	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.410	0.432	0.462	0.499	0.461	0.429	0.429	0.412	0.414	0.412	0.400	0.432	(40)	
(41)		taud	2.477	2.394	2.293	2.176	2.324	2.438	2.429	2.468	2.451	2.476	2.513	2.417	(41)	
(42)		Ebn at Noon	907	894	866	821	834	851	855	884	896	902	910	878	(42)	
(43)		Edh at Noon	112	124	139	153	129	113	115	113	117	113	107	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.48	4.68	4.98	4.81	4.40	4.50	4.86	5.43	5.59	5.25	4.68	4.25	(44)	
(45)		RadStd	0.33	0.33	0.25	0.28	0.31	0.20	0.15	0.19	0.22	0.26	0.27	0.32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page