

CAYENNE MATOURY, French GuianaWMO: **814050**Lat: **4.820N**Lon: **52.360W**Elev: **26**StdP: **14.68**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	70.9	71.4	68.0	102.8	82.1	69.4	108.1	80.2	18.8	82.8	17.9	83.1	0.7	240	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	17.2	91.2	77.4	90.0	77.3	89.6	77.3	80.1	86.3	79.7	85.9	79.2	85.4	10.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	149.5	82.5	77.7	144.2	81.8	77.3	142.4	81.5	43.7	87.0	43.2	86.0	42.7	85.6	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.1	15.9	14.4	68.2	93.1	1.9	1.0	66.8	93.8	65.7	94.4	64.7	95.0	63.3	95.7		
(5)			67.4	81.4	2.5	1.1	65.6	82.2	64.1	82.9	62.7	83.5	60.9	84.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	79.1	79.3	79.9	80.2	80.1	79.9	80.1	80.8	81.3	81.4	80.9	80.0
	DBStd	1.55	1.62	1.66	1.65	1.68	1.53	1.37	1.16	1.11	1.07	1.05	1.12	1.37
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11043	903	819	927	907	932	897	933	955	940	974	926	930
	CDD65	5568	438	399	462	457	467	447	468	490	490	509	476	465
	CDH74	48974	3470	3239	4062	4024	3826	3432	3764	4489	4927	5181	4572	3988
CDH80	15863	733	657	974	1069	987	1030	1314	1776	2116	2262	1781	1164	
Wind	WSAvg	5.4	6.5	7.4	7.4	6.3	4.9	3.8	3.7	4.3	4.9	5.0	5.1	5.8
Precipitation	PrecAvg	142.3	16.4	12.9	13.7	16.8	23.5	16.5	10.0	5.9	2.7	2.8	5.5	14.3
	PrecMax	213.7	35.7	30.8	34.8	34.5	40.2	31.5	17.5	11.2	8.4	11.8	17.5	25.4
	PrecMin	93.4	3.1	0.9	1.6	3.8	9.4	8.7	4.8	0.9	0.2	0.1	0.7	3.0
	PrecStd	22.6	8.9	6.9	7.5	8.1	6.7	5.0	3.0	2.1	1.8	2.4	3.2	5.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.6	87.7	88.0	88.2	89.3	89.5	89.9	91.4	91.8	91.8	91.2	89.7
		MCWB	77.2	77.8	77.3	77.9	78.8	77.6	77.0	77.1	77.6	77.4	77.2	77.0
	2%	DB	86.1	86.1	86.4	87.7	87.8	88.0	88.8	89.9	91.0	91.2	89.8	88.1
		MCWB	76.7	76.7	76.9	77.8	78.2	77.8	77.3	77.5	77.5	77.4	77.3	77.4
	5%	DB	84.6	84.6	86.0	86.3	86.3	87.4	87.9	89.2	89.8	90.0	89.3	87.3
		MCWB	76.5	76.3	76.7	77.3	77.8	77.7	77.5	77.6	77.3	77.2	77.3	77.5
	10%	DB	84.1	84.0	84.5	85.7	85.6	85.9	86.4	87.9	89.3	89.5	88.0	85.9
		MCWB	76.4	76.1	76.4	77.2	77.6	77.5	77.4	77.7	77.3	77.2	77.6	77.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.4	79.4	79.5	80.7	80.4	80.0	79.9	80.2	80.2	80.1	80.0	79.8
		MCDB	83.4	83.9	84.3	85.0	85.6	85.9	86.5	87.7	88.1	87.9	86.7	85.0
	2%	WB	78.6	78.5	78.6	79.5	79.6	79.1	79.0	79.5	79.5	79.3	79.2	79.0
		MCDB	82.8	83.0	83.6	84.1	84.6	85.0	85.8	87.0	87.4	87.1	86.0	84.6
	5%	WB	78.0	77.9	78.0	78.8	79.0	78.5	78.3	78.9	78.9	78.8	78.9	78.5
		MCDB	82.3	82.3	83.0	83.5	83.8	84.3	85.0	86.4	86.8	86.7	85.6	84.0
	10%	WB	77.3	77.2	77.4	78.2	78.3	78.0	77.8	78.2	78.3	78.2	78.3	78.0
		MCDB	81.6	81.6	82.3	82.8	82.9	83.5	84.3	85.5	86.0	85.9	84.9	83.4
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.7	10.3	10.7	10.9	12.8	14.6	16.1	17.1	17.2	15.5	12.2
		MCDBR	11.4	10.9	11.7	12.2	12.5	14.5	15.8	17.0	17.7	17.9	16.9	14.7
		MCWBR	4.7	4.4	4.4	4.6	5.0	5.6	6.3	6.7	6.5	6.5	6.3	5.7
	5% WB	MCDBR	10.2	9.8	10.2	11.0	11.2	13.1	14.8	16.1	16.9	17.0	15.2	12.5
		MCWBR	4.9	4.7	4.5	4.8	5.1	5.7	6.4	6.8	6.8	6.6	6.2	5.5
Clear-Sky Solar Irradiance	taub	0.431	0.464	0.473	0.476	0.450	0.431	0.427	0.428	0.436	0.412	0.409	0.443	
	taud	2.438	2.319	2.288	2.290	2.396	2.462	2.459	2.438	2.397	2.480	2.495	2.393	
	Ebn at Noon	283	275	272	266	267	269	271	276	278	287	287	277	
	Edh at Noon	37	43	44	43	38	35	35	37	39	36	35	38	
All-Sky Solar Radiation	RadAvg	1350	1376	1505	1454	1336	1478	1655	1875	1989	1906	1701	1394	
	RadStd	102	128	114	121	113	82	73	84	66	78	97	117	