

CAYENNE MATOURY, French GuianaWMO: **814050**Lat: **4.820N**Lon: **52.360W**Elev: **8**StdP: **101.23**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	21.9	20.0	14.7	27.8	20.8	15.4	26.8	8.4	28.2	8.0	28.4	0.3	240	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.6	32.9	25.2	32.2	25.2	32.0	25.2	26.7	30.1	26.5	29.9	26.2	29.7	4.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	28.1	25.4	20.6	27.7	25.2	20.3	27.5	83.9	30.6	82.6	30.0	81.5	29.8	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.6	7.1	6.4	20.1	34.0	1.1	0.5	19.4	34.4	18.7	34.7	18.1	35.0	17.4	35.4
			19.7	27.5	1.4	0.6	18.7	27.9	17.8	28.3	17.1	28.6	16.0	29.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	26.2	26.3	26.6	26.8	26.7	26.6	26.7	27.1	27.4	27.5	27.1	26.7
	DBStd	0.86	0.90	0.92	0.91	0.94	0.85	0.76	0.64	0.61	0.59	0.58	0.62	0.76
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6135	502	455	515	504	518	498	518	531	522	541	514	517
	CDD18.3	3093	243	222	257	254	259	248	260	272	272	283	264	258
	CDH23.3	27208	1928	1799	2257	2236	2126	1907	2091	2494	2737	2878	2540	2216
	CDH26.7	8813	407	365	541	594	548	572	730	987	1176	1257	989	647
Wind	WSAvg	2.4	2.9	3.3	3.3	2.8	2.2	1.7	1.6	1.9	2.2	2.3	2.3	2.6
Precipitation	PrecAvg	3614	417	327	347	426	597	420	255	150	69	72	140	363
	PrecMax	5429	906	783	883	877	1020	800	444	284	214	300	445	644
	PrecMin	2373	78	24	41	97	239	222	122	24	4	2	19	75
	PrecStd	575	225	176	191	206	171	126	75	53	46	60	81	130
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.9	30.9	31.1	31.2	31.8	32.0	32.2	33.0	33.2	33.2	32.9	32.1
		MCWB	25.1	25.4	25.2	25.5	26.0	25.3	25.0	25.0	25.3	25.2	25.1	25.0
	2%	DB	30.1	30.0	30.2	30.9	31.0	31.1	31.5	32.1	32.8	32.9	32.1	31.2
		MCWB	24.9	24.9	24.9	25.4	25.6	25.4	25.2	25.3	25.3	25.2	25.2	25.2
	5%	DB	29.2	29.2	30.0	30.2	30.2	30.8	31.0	31.8	32.1	32.2	31.8	30.7
		MCWB	24.7	24.6	24.9	25.2	25.4	25.4	25.3	25.3	25.2	25.1	25.2	25.3
	10%	DB	28.9	28.9	29.2	29.8	29.8	30.0	30.2	31.1	31.8	31.9	31.1	29.9
		MCWB	24.7	24.5	24.6	25.1	25.3	25.3	25.2	25.4	25.2	25.1	25.3	25.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	26.3	26.4	27.0	26.9	26.6	26.6	26.8	26.8	26.7	26.7	26.6
		MCDB	28.5	28.9	29.1	29.5	29.8	29.9	30.3	30.9	31.2	31.0	30.4	29.5
	2%	WB	25.9	25.8	25.9	26.4	26.5	26.2	26.1	26.4	26.4	26.3	26.2	26.1
		MCDB	28.2	28.3	28.7	28.9	29.2	29.4	29.9	30.6	30.8	30.6	30.0	29.2
	5%	WB	25.5	25.5	25.6	26.0	26.1	25.9	25.7	26.0	26.1	26.0	26.0	25.8
		MCDB	27.9	28.0	28.3	28.6	28.8	29.1	29.4	30.2	30.4	30.4	29.8	28.9
	10%	WB	25.2	25.1	25.2	25.7	25.7	25.5	25.4	25.7	25.7	25.7	25.7	25.6
		MCDB	27.6	27.6	27.9	28.2	28.3	28.6	29.1	29.7	30.0	30.0	29.4	28.6
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.4	5.7	5.9	6.0	7.1	8.1	8.9	9.5	9.6	8.6	6.8
		MCDBR	6.3	6.1	6.5	6.8	7.0	8.1	8.8	9.5	9.8	9.9	9.4	8.2
		MCWBR	2.6	2.4	2.5	2.6	2.8	3.1	3.5	3.7	3.6	3.6	3.5	3.2
	5% WB	MCDBR	5.7	5.4	5.7	6.1	6.2	7.3	8.2	8.9	9.4	9.5	8.4	6.9
		MCWBR	2.7	2.6	2.5	2.7	2.8	3.2	3.5	3.8	3.8	3.7	3.4	3.1
Clear-Sky Solar Irradiance	taub	0.431	0.464	0.473	0.476	0.450	0.431	0.427	0.428	0.436	0.412	0.409	0.443	
	taud	2.438	2.319	2.288	2.290	2.396	2.462	2.459	2.438	2.397	2.480	2.495	2.393	
	Ebn at Noon	891	867	858	839	842	847	855	869	877	904	906	872	
	Edh at Noon	117	135	140	137	119	110	111	116	123	113	110	121	
All-Sky Solar Radiation	RadAvg	4.26	4.34	4.74	4.58	4.21	4.66	5.22	5.91	6.27	6.01	5.36	4.40	
	RadStd	0.32	0.40	0.36	0.38	0.35	0.26	0.23	0.27	0.21	0.25	0.31	0.37	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.23	+0.06	N/A	+0.23	N/A	N/A	N/A	N/A	+98	+97
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page