

SALVADOR, Brazil

WMO: 832480

Lat: 12.911S

Lon: 38.331W

Elev: 20

StdP: 101.09

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.8	21.2	16.1	11.5	24.1	17.0	12.2	24.1	9.7	23.7	8.8	24.4	2.4	180	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.7	32.2	26.6	31.9	26.5	31.2	26.1	27.4	30.8	27.0	30.5	26.6	30.1	5.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	29.5	26.1	21.5	29.4	25.7	21.1	29.1	87.1	31.1	85.2	30.8	83.5	30.4	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	8.1	7.4	DB	18.8	33.3	1.3	2.0	17.9	34.7	17.1	35.9	16.4	37.0	15.4	38.5	(4)
(5)			WB	17.5	28.1	1.5	1.0	16.4	28.8	15.5	29.4	14.7	29.9	13.6	30.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	27.8	28.0	28.0	27.4	26.4	25.6	25.0	24.9	25.5	26.3	26.9	27.4	(6)	
	DBStd	1.64	1.17	1.20	1.28	1.25	1.35	1.33	1.29	1.15	1.16	1.16	1.22	1.08	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6050	552	504	557	522	509	467	464	463	464	505	506	538	(10)	
	CDD18.3	3008	294	271	298	272	251	217	206	204	214	247	256	280	(11)	
	CDH23.3	29334	3325	3166	3549	3017	2406	1751	1432	1367	1624	2194	2518	2985	(12)	
	CDH26.7	7769	1113	1131	1296	943	555	255	160	136	228	431	647	875	(13)	
(14) Wind	WSAvg	4.1	4.2	4.0	3.8	3.5	3.6	3.9	4.1	4.2	4.5	4.7	4.6	4.4	(14)	
(15) Precipitation	PrecAvg	1657	69	80	106	256	284	214	171	116	88	79	117	62	(15)	
	PrecMax	2332	329	286	269	534	598	371	449	302	203	199	256	210	(16)	
	PrecMin	1008	6	11	12	62	155	108	65	42	24	7	36	8	(17)	
	PrecStd	308	65	68	69	138	118	71	75	53	48	62	64	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	33.1	33.2	32.6	31.9	30.2	30.0	29.9	30.2	31.1	31.9	32.2	(19)	
		MCWB	26.7	26.9	27.2	26.8	26.8	25.9	25.7	25.5	25.3	26.1	26.3	26.5	(20)	
	2%	DB	32.0	32.1	32.2	31.3	30.6	29.2	29.0	28.8	29.2	30.1	31.0	31.2	(21)	
		MCWB	26.3	26.5	26.8	26.3	26.2	24.7	24.5	24.4	24.7	25.4	25.9	26.1	(22)	
	5%	DB	31.1	31.2	31.8	30.8	29.9	28.9	28.1	28.0	28.8	29.2	30.1	30.8	(23)	
		MCWB	26.0	26.1	26.5	26.0	25.4	24.3	23.5	23.5	24.3	24.7	25.4	25.8	(24)	
	10%	DB	30.2	30.9	30.9	30.1	29.1	28.1	27.5	27.2	28.0	28.9	29.3	30.0	(25)	
		MCWB	25.5	25.9	25.9	25.4	24.8	23.8	23.2	23.0	23.7	24.5	24.9	25.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.8	28.1	27.5	27.2	26.5	25.7	25.6	25.9	26.5	26.9	27.2	(27)	
		MCDB	30.8	31.0	31.6	30.8	30.3	29.3	28.8	28.7	29.1	30.0	30.3	30.7	(28)	
	2%	WB	26.9	27.1	27.4	26.8	26.5	25.7	25.2	25.0	25.3	25.9	26.3	26.6	(29)	
		MCDB	30.4	30.8	31.0	30.1	29.6	28.4	27.9	27.8	28.4	29.2	29.8	30.2	(30)	
	5%	WB	26.5	26.7	26.8	26.5	26.0	25.2	24.7	24.4	24.7	25.4	25.9	26.2	(31)	
		MCDB	30.0	30.3	30.4	29.7	28.9	27.7	27.2	27.0	27.8	28.6	29.3	29.7	(32)	
	10%	WB	26.1	26.3	26.4	26.1	25.5	24.7	24.1	23.9	24.3	24.9	25.5	25.8	(33)	
		MCDB	29.6	29.7	29.9	29.2	28.3	27.1	26.5	26.4	27.2	27.9	28.7	29.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	5.5	5.7	5.2	5.0	4.8	4.9	4.9	5.0	4.8	5.2	5.3	(35)	
		MCDBR	5.8	5.9	6.2	5.7	5.6	5.3	5.4	5.4	5.6	5.3	5.8	5.9	(36)	
	5% WB	MCWBR	2.7	2.7	2.8	2.6	2.8	2.8	2.9	2.9	2.9	2.6	2.7	2.8	(37)	
		MCWBR	5.8	5.6	5.9	5.4	5.3	5.0	5.3	5.1	5.3	5.2	5.5	5.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.393	0.390	0.394	0.390	0.388	0.376	0.373	0.382	0.422	0.425	0.415	0.408	(40)	
		taud	2.514	2.532	2.527	2.552	2.552	2.567	2.563	2.507	2.381	2.393	2.441	2.459	(41)	
	Ebn at Noon		950	946	924	895	865	860	872	890	884	902	922	934	(42)	
		Edh at Noon	114	111	109	101	95	91	93	104	124	126	121	120	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.52	6.33	5.92	5.14	4.39	4.13	4.37	4.95	5.55	6.02	6.20	6.41	(44)	
	RadStd		0.46	0.40	0.34	0.37	0.30	0.19	0.20	0.23	0.27	0.34	0.40	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.19	N/A	-0.43	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page