

CUIABA, Brazil

WMO: 833620

Lat: 15.653S

Lon: 56.117W

Elev: 188

StdP: 99.09

Time Zone: -4.00 (SAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 13.1	(c) 15.0	(d) 4.8	(e) 5.5	(f) 28.1	(g) 6.4	(h) 6.1	(i) 27.9	(j) 8.2	(k) 27.1	(l) 7.2	(m) 27.0	(n) 3.3	(o) 200	(p) 0.345

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 12.5	(c) 38.4	(d) 21.8	(e) 37.4	(f) 22.0	(g) 36.6	(h) 22.4	(i) 27.9	(j) 31.5	(k) 27.1	(l) 30.9	(m) 26.3	(n) 30.6	(o) 3.4	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.3	29.6	26.1	22.0	28.8	25.2	20.8	28.2	90.7	31.3	86.9	30.4	83.2	30.5	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.6	(b) 6.4	(c) 5.6	(e) 10.9	(f) 40.0	(g) 2.0	(h) 0.9	(i) 9.5	(j) 40.6	(k) 8.4	(l) 41.2	(m) 7.3	(n) 41.7	(o) 5.8	(p) 42.4		
			DB													
			WB													
				8.8	27.8	2.2	1.5	7.2	28.9	5.9	29.8	4.6	30.7	3.0	31.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	28.0	28.0	28.3	27.9	25.9	25.2	24.9	27.1	28.9	29.2	28.6	28.3
	DBStd	3.02	1.65	1.66	1.66	2.51	3.09	3.16	3.64	3.67	3.68	2.38	2.00	1.56
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	12	0	0	0	1	1	2	6	2	1	0	0	0
	CDD10.0	6392	558	506	566	536	492	456	463	531	566	596	557	566
	CDD18.3	3362	300	272	308	287	234	208	210	274	317	338	307	308
	CDH23.3	35871	2879	2620	3009	2874	2197	2022	2263	3400	4137	4001	3362	3107
	CDH26.7	17236	1162	1060	1261	1293	993	991	1172	1950	2388	2087	1574	1304
(14) Wind	WSAvg	2.4	2.7	2.4	2.2	2.0	2.1	2.1	2.3	2.5	2.7	2.7	2.8	2.7
(15) Precipitation	PrecAvg	1396	229	228	194	128	49	13	12	15	53	126	179	202
	PrecMax	2116	442	507	366	302	143	79	91	102	194	306	447	427
	PrecMin	999	42	35	0	18	1	0	0	0	0	26	37	88
	PrecStd	225	85	95	79	57	38	19	20	24	43	55	77	77
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.2	36.0	36.8	36.8	36.0	36.0	36.2	38.9	40.0	39.8	37.1	36.1
		MCWB	25.5	25.7	25.8	25.3	25.0	22.2	21.5	21.3	20.7	23.6	24.7	25.0
	2%	DB	34.9	34.2	35.0	35.2	34.3	34.2	35.0	37.8	38.9	38.0	36.0	34.8
		MCWB	25.1	25.3	25.4	25.0	23.4	21.5	20.6	20.5	21.3	23.3	24.7	24.7
	5%	DB	33.3	33.2	33.8	34.1	33.2	33.2	34.1	36.8	37.9	36.4	34.9	33.8
		MCWB	25.0	25.0	25.3	24.8	23.1	21.4	20.3	20.3	21.3	23.6	24.4	24.6
	10%	DB	32.1	32.1	32.2	32.9	32.1	32.2	33.0	35.7	36.7	35.0	33.5	32.4
		MCWB	24.7	24.7	24.9	24.6	23.0	21.2	20.1	20.1	21.7	23.7	24.3	24.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.7	28.6	27.5	27.5	26.6	24.9	24.3	24.6	26.5	27.7	28.5	28.3
		MCDB	32.1	32.2	31.5	32.6	31.9	30.5	31.8	32.7	33.2	32.6	32.9	32.1
	2%	WB	27.1	27.5	26.6	26.6	25.5	23.8	23.2	23.3	25.3	26.5	27.2	26.9
		MCDB	29.9	30.3	31.1	31.4	30.4	30.0	30.9	32.0	32.4	31.2	30.8	29.9
	5%	WB	26.0	26.2	26.0	25.8	24.8	23.1	22.4	22.5	24.3	25.5	25.7	25.7
		MCDB	30.0	29.8	30.7	30.4	30.0	29.7	29.9	31.0	32.1	31.5	30.8	30.1
	10%	WB	25.2	25.4	25.4	25.3	24.1	22.5	21.6	21.7	23.5	24.6	24.9	25.1
		MCDB	30.1	29.8	30.3	30.3	29.2	29.0	28.8	30.2	31.7	31.4	31.0	30.3
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	8.6	8.7	9.4	10.2	11.7	13.2	14.0	12.5	10.8	9.5	8.8
		MCDBR	10.2	10.0	10.2	10.6	11.7	13.5	14.8	15.4	14.5	12.9	11.2	10.3
		MCWBR	3.2	3.2	3.1	3.2	3.4	3.7	4.0	3.9	3.6	3.2	3.2	3.1
	5% WB	MCDBR	9.2	8.9	9.1	9.7	10.2	11.6	12.7	12.9	11.6	11.1	9.9	9.1
		MCWBR	3.5	3.5	3.4	3.6	3.5	4.0	4.4	4.2	3.6	3.5	3.5	3.3
(40) Clear-Sky Solar Irradiance	taub		0.414	0.418	0.401	0.392	0.381	0.393	0.382	0.471	0.671	0.564	0.453	0.434
	taud		2.430	2.421	2.477	2.473	2.475	2.428	2.428	2.140	1.665	1.962	2.289	2.360
	Ebn at Noon		931	919	914	887	862	831	852	801	681	785	889	912
	Edh at Noon		124	124	114	108	101	102	104	148	252	194	142	133
(44) All-Sky Solar Radiation	RadAvg		5.34	5.37	5.28	5.11	4.59	4.51	4.81	5.33	5.10	5.27	5.52	5.49
	RadStd		0.50	0.36	0.34	0.30	0.30	0.23	0.33	0.31	0.40	0.33	0.36	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	-1.95	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page