

BRASILIA, Brazil

WMO: 833780

Lat: 15.863S

Lon: 47.913W

Elev: 1060

StdP: 89.22

Time Zone: -3.00 (SAB)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	11.2	1.0	4.6	27.0	2.9	5.3	25.7	8.9	21.5	8.0	21.8	0.6	270	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	11.5	32.8	17.4	31.8	17.6	30.9	18.1	22.2	26.5	21.7	26.1	21.4	25.9	3.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	18.0	23.5	20.7	17.5	23.2	20.1	16.9	22.8	71.0	26.9	69.1	25.9	67.6	25.8	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.5	5.9	DB	8.0	34.3	1.1	1.1	7.2	35.1	6.5	35.7	5.9	36.3	5.1	37.1	(4)
(5)			WB	6.3	23.6	1.1	1.3	5.5	24.5	4.9	25.2	4.3	25.9	3.5	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	23.3	23.4	23.1	22.7	21.0	19.5	19.3	20.8	23.1	24.0	23.2	23.2
	DBStd	2.16	1.37	1.22	1.20	1.23	1.68	1.49	1.53	1.68	1.79	1.76	1.59	1.41
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	16	0	0	0	0	2	6	8	1	0	0	0	0
	CDD10.0	4462	411	374	407	381	342	286	289	336	394	435	396	411
	CDD18.3	1437	153	141	149	131	85	42	38	78	144	177	147	152
	CDH23.3	10582	893	855	803	813	636	440	511	956	1478	1536	837	826
CDH26.7	2919	240	227	183	168	101	40	63	260	581	618	230	208	
Wind	WSAvg	2.3	2.4	2.3	2.2	2.2	2.0	2.1	2.3	2.5	2.6	2.5	2.5	2.4
Precipitation	PrecAvg	1506	226	197	202	131	37	6	7	15	46	158	236	246
	PrecMax	1994	602	460	399	376	178	44	95	93	119	526	449	467
	PrecMin	1006	21	37	20	11	0	0	0	0	0	8	74	22
	PrecStd	234	122	97	91	73	35	11	17	23	34	97	85	89
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	31.8	31.1	30.7	30.0	29.0	29.2	32.0	33.8	34.1	32.8	31.6
		MCWB	19.6	19.8	20.0	19.8	18.3	16.7	15.9	16.4	16.9	17.4	18.3	19.4
	2%	DB	30.2	30.2	29.9	29.3	28.9	27.9	28.1	30.2	32.2	32.9	30.8	30.1
		MCWB	19.5	19.7	19.9	19.4	18.3	17.0	15.8	15.8	16.6	17.4	19.0	19.7
	5%	DB	29.2	29.2	28.8	28.7	27.9	26.9	27.2	29.2	31.2	31.8	29.1	29.0
		MCWB	19.4	19.6	20.0	19.4	18.5	16.6	15.7	15.6	16.7	17.6	19.4	19.8
	10%	DB	28.0	28.1	27.7	27.7	26.9	26.0	26.2	28.1	30.1	30.2	27.9	27.8
		MCWB	19.8	19.9	20.1	19.6	18.1	16.4	15.5	15.4	16.7	18.0	19.8	20.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	22.5	22.6	22.2	21.6	19.6	18.7	19.1	20.7	21.7	22.2	22.5
		MCDB	26.6	26.5	26.8	26.5	26.2	25.2	25.5	27.1	26.9	27.0	26.6	26.7
	2%	WB	21.9	21.7	21.7	21.6	20.7	18.7	17.6	17.7	19.8	21.0	21.4	21.7
		MCDB	26.0	26.1	26.3	26.1	25.4	24.9	24.9	25.8	25.9	26.5	26.0	26.1
	5%	WB	21.4	21.2	21.2	21.0	19.9	17.9	16.9	17.0	19.1	20.4	20.9	21.2
		MCDB	25.4	25.7	25.9	25.8	24.9	24.4	24.8	25.4	25.2	25.7	25.4	25.5
	10%	WB	20.8	20.7	20.7	20.5	19.2	17.3	16.3	16.4	18.5	19.8	20.5	20.7
		MCDB	24.8	25.1	25.2	25.1	24.4	23.8	24.2	25.3	25.2	25.1	24.7	24.8
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.7	9.4	10.3	11.9	13.4	14.2	14.8	13.6	11.5	9.1	8.8
		MCDBR	11.7	11.7	11.3	11.7	12.9	14.5	15.5	16.2	15.7	14.5	11.5	11.2
	5% WB	MCWBR	3.8	3.8	3.9	4.2	4.8	5.7	5.7	5.2	4.8	4.1	3.5	3.7
		MCWBR	9.2	9.5	9.4	9.8	10.8	12.8	13.6	13.9	11.4	10.1	9.0	8.9
Clear-Sky Solar Irradiance	taub	0.372	0.373	0.364	0.354	0.334	0.310	0.311	0.348	0.460	0.442	0.400	0.382	
	taud	2.494	2.478	2.532	2.517	2.549	2.622	2.585	2.440	2.132	2.235	2.390	2.452	
	Ebn at Noon	972	961	950	924	910	918	925	916	846	887	938	961	
	Edh at Noon	116	117	108	103	93	83	89	109	158	148	128	121	
All-Sky Solar Radiation	RadAvg	5.72	5.82	5.47	5.38	5.00	4.83	5.11	5.77	5.98	5.89	5.29	5.48	
	RadStd	0.67	0.48	0.41	0.35	0.24	0.18	0.19	0.32	0.47	0.63	0.44	0.51	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page