

BAURU, Brazil

WMO: 837220

Lat: 22.345S

Lon: 49.054W

Elev: 2025

StdP: 13.65

Time Zone: -3.00 (SAB)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	49.8	52.3	39.5	38.3	61.7	43.1	44.2	63.5	25.9	58.6	23.3	59.0	11.1	120	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.8	95.1	73.8	93.1	73.1	91.3	73.1	78.7	87.7	77.8	86.5	76.9	85.4	7.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.7	150.3	83.7	75.4	143.6	81.9	74.9	141.2	81.3	44.0	87.8	42.8	87.0	41.9	86.0	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.9	20.7	18.0	DB	43.5	98.1	3.8	2.6	40.8	99.9	38.6	101.4	36.4	102.9	33.7	104.7	(4)
(5)			WB	41.9	80.9	3.8	1.9	39.2	82.2	36.9	83.3	34.8	84.4	32.0	85.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	77.8	78.9	77.7	74.8	69.7	68.3	68.2	71.2	73.9	75.3	76.2	77.5	(6)	
	DBStd	6.08	4.16	3.80	3.56	4.11	5.32	5.32	5.97	5.75	6.07	5.20	3.97	3.68	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	115	0	0	0	2	20	29	40	17	6	1	0	0	(9)	
	CDD50	8795	863	809	858	744	609	550	564	658	718	784	785	853	(10)	
	CDD65	3436	398	389	393	296	164	129	140	210	274	320	335	388	(11)	
	CDH74	28456	3184	3380	3181	2229	1018	737	975	1859	2731	3001	2888	3273	(12)	
	CDH80	10737	1275	1387	1204	698	221	118	209	643	1227	1331	1142	1282	(13)	
(14) Wind	WSAvg	8.3	7.5	7.1	8.1	8.3	7.7	7.3	8.5	9.1	9.6	9.4	8.5	7.9	(14)	
(15) Precipitation	PrecAvg	53.2	9.3	8.6	6.3	2.8	2.7	1.7	1.1	1.0	3.1	4.4	4.8	7.1	(15)	
	PrecMax	61.9	15.1	16.6	9.9	6.5	5.0	5.9	2.6	3.1	6.8	7.0	7.7	11.9	(16)	
	PrecMin	37.6	3.5	4.8	2.8	0.1	0.2	0.2	0.0	0.0	0.0	1.1	2.2	0.6	(17)	
	PrecStd	7.2	3.4	3.6	2.2	1.8	1.2	1.6	0.8	1.1	2.0	1.6	2.0	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.1	96.5	93.3	90.0	87.8	86.0	87.4	92.8	96.9	98.3	94.3	94.9	(19)	
		MCWB	77.8	75.1	76.2	73.3	73.1	69.5	65.5	66.9	69.8	72.9	74.2	75.5	(20)	
	2%	DB	92.8	93.1	91.2	88.1	84.5	82.8	84.5	89.3	93.3	94.8	91.4	91.7	(21)	
		MCWB	76.4	74.8	75.9	72.7	70.5	67.9	65.7	66.1	68.6	72.8	73.4	74.2	(22)	
	5%	DB	89.8	90.4	89.2	86.3	82.4	80.8	82.4	86.2	91.0	91.3	89.4	89.6	(23)	
		MCWB	75.7	75.1	75.1	72.3	69.3	67.1	65.3	65.3	67.7	72.0	72.4	73.7	(24)	
	10%	DB	87.4	87.9	86.4	84.3	80.2	78.6	80.2	83.9	87.6	87.6	86.4	87.0	(25)	
		MCWB	75.2	74.6	74.5	71.9	68.1	66.4	64.4	64.9	67.6	71.4	72.2	73.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.4	79.4	79.6	77.9	76.1	73.7	71.0	70.8	75.6	77.8	78.2	79.2	(27)	
		MCDB	91.6	88.0	88.1	84.6	83.7	80.5	80.0	84.5	87.2	89.6	88.0	87.9	(28)	
	2%	WB	78.4	78.0	78.1	76.3	73.1	71.4	68.5	68.8	73.3	75.8	76.7	77.6	(29)	
		MCDB	88.0	86.5	86.5	83.1	81.2	78.8	78.0	82.4	83.3	88.1	85.5	86.2	(30)	
	5%	WB	77.3	77.0	77.0	75.0	71.1	69.7	67.0	67.4	71.5	74.2	75.4	76.4	(31)	
		MCDB	85.9	85.4	85.1	82.1	78.7	76.2	77.1	80.7	83.0	85.5	84.1	84.7	(32)	
	10%	WB	76.2	76.0	75.8	73.7	69.6	68.0	65.8	66.1	70.0	72.8	74.3	75.3	(33)	
		MCDB	84.2	84.2	83.3	80.5	77.0	74.7	76.0	79.2	81.2	83.3	82.8	83.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	16.8	16.8	17.7	16.9	17.2	19.6	21.7	21.7	20.4	19.3	17.6	(35)	
		MCDBR	20.6	20.0	19.6	19.5	19.0	19.5	21.4	24.2	25.4	26.0	23.2	21.6	(36)	
	5% WB	MCWBR	7.9	7.3	7.3	7.6	8.2	8.4	8.3	9.0	8.6	8.9	9.1	8.2	(37)	
		MCWBR	18.3	17.7	17.5	16.9	17.2	16.3	18.9	22.5	22.1	21.8	18.7	17.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.394	0.395	0.388	0.374	0.349	0.353	0.359	0.403	0.496	0.450	0.413	0.399	(40)	
		taud	2.445	2.424	2.445	2.457	2.495	2.479	2.446	2.288	2.026	2.226	2.340	2.405	(41)	
	Ebn at Noon		302	297	291	281	276	268	270	268	255	278	294	300	(42)	
		Edh at Noon	39	39	36	33	30	29	31	39	55	47	43	40	(43)	
(44) All-Sky Solar Radiation	RadAvg		1772	1846	1727	1571	1278	1179	1251	1511	1659	1821	1913	1924	(44)	
	RadStd		229	136	139	108	88	99	107	112	148	139	123	136	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page