

IQUITOS, Peru

WMO: 843770

Lat: 3.785S

Lon: 73.309W

Elev: 93

StdP: 100.21

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	20.8	17.8	12.9	21.3	19.0	13.9	22.6	5.9	25.9	4.9	26.1	0.9	170	0.255

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.3	34.2	26.3	33.8	26.3	33.1	26.2	27.2	32.4	27.0	32.1	26.7	31.5	2.7	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.5	31.1	25.3	20.7	30.3	25.2	20.6	30.1	87.2	32.9	85.7	32.6	84.4	32.2	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.4	3.9	17.0	35.7	2.5	0.7	15.2	36.3	13.8	36.7	12.4	37.1	10.6	37.6		
(5)			16.2	28.3	2.2	1.0	14.6	29.0	13.3	29.6	12.1	30.2	10.4	31.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	27.1	27.0	26.9	26.8	26.5	26.1	26.0	26.7	27.1	27.3	27.3	27.1	(6)	
	DBStd	1.37	1.28	1.21	1.15	1.32	1.28	1.47	1.55	1.33	1.42	1.21	1.25	1.11	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6139	529	476	525	503	512	483	495	516	514	537	519	529	(10)	
	CDD18.3	3097	271	242	267	253	253	233	237	258	264	279	269	271	(11)	
	CDH23.3	24469	2175	1932	2098	1974	1890	1631	1691	2078	2238	2349	2242	2171	(12)	
	CDH26.7	9170	808	694	739	679	611	530	601	867	983	973	887	797	(13)	
(14) Wind	WSAvg	1.2	1.3	1.3	1.3	1.2	1.2	1.1	1.1	1.2	1.3	1.3	1.4	1.4	(14)	
(15) Precipitation	PrecAvg	2820	292	263	306	292	270	196	185	173	191	243	274	312	(15)	
	PrecMax	4298	645	581	706	532	753	376	462	469	344	638	638	908	(16)	
	PrecMin	1543	8	63	32	96	111	61	24	60	60	0	75	63	(17)	
	PrecStd	597	158	121	145	112	134	82	87	84	81	126	138	154	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.5	34.2	33.9	33.5	33.1	33.0	33.0	34.1	35.1	35.0	34.8	34.0	(19)	
		MCWB	26.2	25.9	26.7	26.6	26.3	26.1	25.9	26.0	25.8	26.6	26.8	26.5	(20)	
	2%	DB	33.2	33.1	32.8	32.4	32.1	31.9	32.0	33.1	34.0	34.0	33.7	33.0	(21)	
		MCWB	26.3	26.0	26.4	26.2	26.0	26.0	25.6	25.7	26.1	26.4	26.6	26.3	(22)	
	5%	DB	32.2	32.0	31.9	31.8	31.1	30.9	31.1	32.2	33.1	32.9	32.8	32.0	(23)	
		MCWB	26.2	26.0	26.1	26.1	25.9	25.8	25.4	25.7	26.0	26.2	26.4	26.1	(24)	
	10%	DB	31.0	30.9	30.8	30.6	30.1	29.9	30.1	31.2	32.0	31.8	31.4	31.0	(25)	
		MCWB	26.0	25.9	25.9	25.9	25.6	25.4	25.2	25.6	25.8	26.0	26.1	26.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.2	27.2	27.3	27.1	26.9	26.9	27.2	27.4	27.6	27.6	27.2	(27)	
		MCDB	33.0	32.2	32.2	32.0	31.6	31.4	31.6	32.3	32.9	33.3	33.0	32.2	(28)	
	2%	WB	26.9	26.7	26.7	26.7	26.5	26.4	26.4	26.7	26.9	27.0	27.0	26.7	(29)	
		MCDB	31.9	31.3	31.3	31.1	30.7	30.5	30.6	31.6	32.2	32.4	32.3	31.4	(30)	
	5%	WB	26.4	26.2	26.3	26.2	26.1	26.0	26.0	26.2	26.4	26.5	26.6	26.4	(31)	
		MCDB	30.9	30.5	30.5	30.4	30.1	29.9	29.9	30.9	31.6	31.6	31.4	30.8	(32)	
	10%	WB	26.0	25.9	25.9	25.9	25.7	25.5	25.4	25.8	26.0	26.1	26.1	26.0	(33)	
		MCDB	30.0	29.8	29.9	29.8	29.4	29.1	29.2	30.2	30.9	30.8	30.6	30.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.3	8.1	8.0	7.7	7.9	8.7	9.6	9.9	9.3	8.9	8.4	(35)	
		MCDBR	10.0	9.8	9.7	9.4	9.1	9.3	10.1	11.0	11.5	11.0	10.5	9.9	(36)	
	5% WB	MCWBR	4.3	4.2	4.3	4.2	4.1	4.3	4.8	4.9	4.8	4.8	4.6	4.4	(37)	
		MCWBR	9.3	9.0	9.0	8.8	8.4	8.6	9.3	10.2	10.6	10.2	9.7	9.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.399	0.402	0.396	0.391	0.377	0.382	0.404	0.471	0.496	0.440	0.433	0.405	(40)	
		taud	2.510	2.497	2.524	2.529	2.588	2.565	2.484	2.262	2.193	2.366	2.389	2.482	(41)	
	Ebn at Noon		936	932	927	908	896	877	863	824	826	886	897	926	(42)	
		Edh at Noon	112	115	110	106	96	96	105	137	151	129	126	114	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.39	4.37	4.35	4.30	4.10	4.06	4.19	4.63	4.96	4.86	4.67	4.48	(44)	
	RadStd		0.32	0.31	0.21	0.20	0.21	0.25	0.27	0.23	0.30	0.17	0.26	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	+0.17	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	+65	+65	
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page