

TALARA, Peru

WMO: 843900

Lat: 4.577S

Lon: 81.254W

Elev: 282

StdP: 14.55

Time Zone: -5.00 (W05)

Period: 90-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	60.4	60.7	55.9	67.3	61.9	56.8	69.6	62.6	41.5	65.8	34.6	66.4	12.5	170	0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.4	89.5	75.8	88.0	75.4	86.9	74.9	79.4	84.4	78.6	83.6	77.5	82.8	10.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.4	148.8	83.0	77.1	142.6	81.8	75.6	135.6	80.9	43.3	84.8	42.3	83.9	41.1	81.7	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.3	29.6	23.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	55.9	79.6	3.8	2.5	53.2	81.4	51.0	82.9	48.9	84.3	46.1	86.1	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	78.3	80.5	80.6	78.7	76.8	73.1	70.7	69.6	70.0	70.6	72.4	75.3
	DBStd	4.90	2.44	1.89	2.03	2.37	2.95	3.26	3.38	3.05	3.12	2.77	3.15	3.25
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD50	9003	877	854	948	861	829	693	640	607	600	637	672	785
	CDD65	3529	412	434	483	411	364	243	176	142	150	172	222	320
	CDH74	19865	2721	3479	3906	2763	2045	877	464	308	366	433	811	1692
	CDH80	5197	786	1093	1217	814	490	120	55	33	52	46	125	366
Wind	WSAvg	12.1	11.9	9.7	8.9	11.3	12.7	13.7	13.7	13.2	12.4	13.2	12.7	12.2
Precipitation	PrecAvg	0.4	0.0	0.1	0.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecMax	5.2	1.3	1.5	4.8	1.6	1.6	0.9	0.0	0.0	0.0	0.3	0.1	0.0
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.1	0.2	0.3	0.8	0.3	0.3	0.2	0.0	0.0	0.0	0.0	0.0	0.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	90.7	91.2	89.6	88.2	85.6	84.2	82.7	84.4	83.8	86.4	88.2
		MCWB	76.2	75.6	76.4	76.0	75.3	73.7	73.2	72.1	73.5	71.8	74.2	77.0
	2%	DB	87.7	89.3	89.5	87.8	86.3	82.8	81.3	80.6	80.8	81.0	84.0	86.1
		MCWB	74.9	75.3	75.8	75.3	74.1	71.9	71.1	70.9	71.5	70.1	73.1	75.6
	5%	DB	86.1	87.7	87.8	86.3	84.6	80.9	78.6	77.1	77.3	78.5	80.5	83.9
		MCWB	74.0	75.0	75.5	74.5	73.3	70.8	69.1	68.3	68.4	68.6	70.0	72.9
	10%	DB	84.4	86.1	86.2	85.2	82.7	78.9	76.6	75.1	75.4	76.4	78.4	82.1
		MCWB	73.2	74.5	75.2	73.9	72.0	69.8	68.0	66.9	66.8	67.4	68.8	71.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	80.7	80.6	79.2	77.0	74.5	73.4	72.8	74.1	72.5	75.1	78.9
		MCDB	85.4	85.4	85.8	84.9	86.1	83.6	83.3	81.6	83.7	81.7	85.0	86.1
	2%	WB	78.6	79.5	79.2	77.8	75.4	72.9	71.9	71.3	72.3	70.7	73.4	77.3
		MCDB	83.5	83.7	84.3	83.9	84.4	80.6	79.5	79.5	79.9	79.0	82.4	83.6
	5%	WB	77.2	78.4	78.3	76.7	74.2	71.9	70.3	69.6	69.9	69.4	71.9	75.6
		MCDB	81.3	82.6	83.5	83.3	82.3	78.7	76.4	75.4	73.4	77.1	78.2	81.0
	10%	WB	75.4	76.7	77.0	75.4	73.2	70.7	68.9	68.0	68.4	68.0	70.0	73.5
		MCDB	81.6	82.1	82.5	82.1	80.5	77.7	75.4	73.9	75.0	75.0	77.1	79.4
Mean Daily Temperature Range	5% DB	MDBR	14.6	13.4	13.3	14.3	14.2	12.8	12.9	12.8	13.6	13.7	13.8	14.4
		MCDBR	14.9	14.7	14.9	15.0	14.9	13.8	13.9	13.9	14.6	14.6	14.7	15.2
		MCWBR	6.1	5.9	6.3	6.5	6.6	6.3	6.2	6.8	6.9	6.6	6.4	6.7
	5% WB	MCDBR	11.9	10.4	11.5	12.5	14.0	13.2	13.4	13.4	14.1	14.3	14.1	12.9
		MCWBR	5.7	5.3	5.5	5.8	6.6	6.3	6.3	6.6	6.4	6.6	6.2	6.3
Clear-Sky Solar Irradiance	taub	0.430	0.423	0.422	0.448	0.461	0.457	0.459	0.488	0.514	0.459	0.458	0.454	
	taud	2.396	2.427	2.433	2.355	2.305	2.314	2.311	2.199	2.114	2.293	2.280	2.308	
	Ebn at Noon	288	290	286	271	259	255	257	257	257	276	278	279	
	Edh at Noon	40	39	38	40	40	39	40	46	52	44	45	43	
All-Sky Solar Radiation	RadAvg	1918	1850	1910	1928	1749	1595	1592	1716	1898	1983	2040	2004	
	RadStd	126	76	115	62	92	105	99	110	96	77	89	79	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page