

CHICLAYO, Peru

WMO: 844520

Lat: 6.787S

Lon: 79.828W

Elev: 97

StdP: 14.64

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	58.8	59.4	55.0	64.6	62.5	55.3	65.2	62.4	23.5	68.9	22.4	68.7	8.8	170	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.8	89.9	75.5	88.2	74.8	87.3	74.4	78.1	85.6	76.8	84.5	75.5	84.5	11.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.6	134.3	82.6	74.5	129.5	82.3	72.8	122.1	81.3	41.5	84.9	40.4	84.5	39.1	84.6	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.3	21.7	20.2	DB	57.7	92.4	2.2	2.7	56.2	94.4	54.9	95.9	53.7	97.5	52.2	99.4	(4)
(5)			WB	55.6	78.8	2.2	2.5	54.0	80.6	52.7	82.1	51.4	83.5	49.8	85.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	77.5	79.9	79.5	76.1	73.2	70.5	68.8	68.2	68.4	69.1	70.7	73.8	(6)	
	DBStd	4.95	2.84	2.26	2.62	2.91	3.09	3.16	2.73	2.55	2.54	2.30	2.52	2.80	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	2	0	0	0	0	0	0	1	1	0	0	0	0	(9)	
	CDD50	8372	853	836	914	784	719	614	584	565	553	592	621	737	(10)	
	CDD65	2900	388	416	449	334	254	164	120	100	104	128	171	272	(11)	
	CDH74	15192	2469	3149	3368	1912	1091	470	243	182	212	281	533	1282	(12)	
	CDH80	4259	775	1148	1205	541	193	55	20	15	20	15	42	230	(13)	
(14) Wind	WSAvg	11.2	11.1	9.6	9.4	10.9	11.9	11.0	10.6	11.0	12.0	12.3	12.1	12.2	(14)	
(15) Precipitation	PrecAvg	0.8	0.1	0.1	0.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(15)	
	PrecMax	2.9	1.3	0.6	2.7	0.4	1.4	0.5	0.2	0.4	0.4	0.3	0.9	0.2	(16)	
	PrecMin	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	0.6	0.2	0.1	0.5	0.1	0.2	0.1	0.0	0.1	0.1	0.1	0.2	0.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.1	91.7	91.8	89.8	86.4	84.5	82.7	82.3	82.7	82.2	84.0	87.7	(19)	
		MCWB	76.7	76.1	76.1	75.2	72.9	72.8	71.5	71.2	71.4	69.8	72.3	75.1	(20)	
	2%	DB	88.1	89.8	89.8	87.6	84.3	81.0	78.8	78.0	78.4	78.8	80.8	84.4	(21)	
		MCWB	74.5	75.6	75.6	74.1	71.9	70.8	68.7	68.1	67.9	67.4	69.3	71.9	(22)	
	5%	DB	86.2	88.2	88.1	85.6	82.3	78.8	76.7	75.5	76.2	77.0	78.9	82.5	(23)	
		MCWB	73.5	74.8	75.0	72.8	70.8	69.0	67.3	66.5	66.5	66.7	68.1	71.1	(24)	
	10%	DB	84.4	86.4	86.3	83.1	80.2	76.7	74.9	73.7	74.8	75.3	77.1	80.6	(25)	
		MCWB	72.7	74.2	74.3	71.7	69.9	68.0	66.4	65.5	65.8	65.7	67.2	70.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.7	79.7	79.2	77.1	74.3	73.5	72.0	71.8	71.7	70.1	72.6	76.2	(27)	
		MCDB	88.9	86.7	86.9	86.8	85.0	83.5	81.3	80.5	81.8	80.6	82.1	84.8	(28)	
	2%	WB	76.8	78.3	77.8	75.1	72.7	71.8	69.8	69.6	69.3	68.2	70.3	74.1	(29)	
		MCDB	84.4	84.9	85.4	84.8	82.6	79.3	76.7	76.4	76.3	77.3	78.5	81.8	(30)	
	5%	WB	75.0	76.9	76.6	73.6	71.5	70.4	68.1	67.5	67.4	67.1	68.9	71.9	(31)	
		MCDB	83.9	84.0	84.5	83.4	80.4	76.9	75.3	74.9	74.8	75.8	77.3	80.9	(32)	
	10%	WB	73.4	75.3	75.4	72.3	70.2	68.7	66.6	65.6	65.8	66.0	67.7	70.4	(33)	
		MCDB	83.2	85.0	84.3	81.7	77.7	75.2	73.9	73.2	73.8	74.3	76.3	79.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.8	15.8	15.9	16.0	14.6	12.9	12.8	13.1	14.1	14.4	14.7	15.2	(35)	
		MCDBR	16.8	16.9	17.0	17.6	16.2	14.8	14.5	14.7	15.3	15.5	15.9	16.5	(36)	
	5% WB	MCWBR	6.8	6.7	7.0	7.5	7.1	6.9	6.8	7.1	7.2	7.2	7.4	7.1	(37)	
		MCWBR	15.9	15.0	15.1	16.7	14.9	13.4	13.6	14.3	14.6	15.0	15.3	15.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.431	0.427	0.433	0.452	0.449	0.431	0.426	0.462	0.499	0.461	0.456	0.447	(40)	
		taud	2.404	2.421	2.411	2.346	2.343	2.405	2.414	2.282	2.170	2.299	2.298	2.343	(41)	
	Ebn at Noon	Ebn at Noon	288	289	283	269	261	261	265	262	261	276	279	283	(42)	
		Edh at Noon	40	39	39	40	38	35	36	42	49	44	44	42	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1825	1754	1764	1791	1613	1382	1405	1518	1724	1863	1949	1900	(44)	
	RadStd	RadStd	131	95	94	88	150	171	137	120	104	102	128	119	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page