

TRUJILLO, Peru

WMO: 845010

Lat: 8.081S

Lon: 79.109W

Elev: 106

StdP: 14.64

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	57.9	58.7	54.6	63.7	59.8	55.1	64.9	60.0	16.4	66.0	15.5	65.7	6.8	160	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.4	82.5	74.6	80.9	73.8	79.2	72.7	75.5	80.7	74.4	79.9	73.3	79.0	10.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.6	125.6	79.4	72.0	118.7	79.0	71.3	115.8	78.5	39.0	80.6	38.0	80.2	37.0	79.2	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	14.1	13.3	DB	56.3	83.0	3.0	2.2	54.1	84.6	52.4	85.9	50.7	87.1	48.5	88.6	(4)
(5)			WB	54.7	74.0	2.8	2.6	52.7	75.9	51.0	77.5	49.5	78.9	47.4	80.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.9	71.7	73.3	72.8	69.5	68.2	67.0	65.4	64.4	64.3	64.5	66.1	68.4	(6)	
	DBStd	4.47	3.52	3.55	3.68	3.08	3.10	3.50	3.23	3.14	3.04	2.56	2.56	3.37	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	209	0	0	0	2	7	18	31	47	48	41	12	3	(9)	
	CDD50	6542	672	652	706	585	564	509	478	446	428	450	482	570	(10)	
	CDD65	1276	207	232	241	137	105	77	44	28	26	26	45	108	(11)	
	CDH74	2748	539	831	839	167	58	56	31	23	11	7	26	160	(12)	
	CDH80	227	47	88	83	6	0	0	0	0	0	0	0	3	(13)	
(14) Wind	WSAvg	8.1	7.8	7.5	7.7	8.1	8.3	7.8	8.0	8.3	8.8	8.8	8.3	8.1	(14)	
(15) Precipitation	PrecAvg	1.4	0.2	0.3	0.4	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	(15)	
	PrecMax	3.8	1.5	0.7	1.6	0.2	0.5	0.2	0.2	0.0	0.2	0.1	0.4	1.7	(16)	
	PrecMin	0.6	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	0.7	0.3	0.2	0.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.6	84.3	84.3	80.8	77.3	77.6	76.9	76.4	75.5	75.2	76.9	80.4	(19)	
		MCWB	74.2	75.5	76.4	73.1	68.9	68.6	68.2	68.4	68.4	66.8	69.1	72.7	(20)	
	2%	DB	81.4	82.6	82.2	78.0	75.5	75.6	74.5	74.2	73.2	73.0	74.3	77.9	(21)	
		MCWB	73.5	74.9	74.8	71.2	68.6	68.3	67.7	67.7	67.1	66.9	67.9	71.1	(22)	
	5%	DB	79.1	80.8	80.6	75.6	74.0	73.6	72.0	72.0	70.9	70.2	71.7	75.6	(23)	
		MCWB	72.4	74.1	74.0	69.6	68.0	67.6	66.2	66.6	65.8	65.0	66.0	69.6	(24)	
	10%	DB	77.1	79.0	78.7	73.9	72.8	71.9	69.9	68.4	68.4	68.3	70.0	73.4	(25)	
		MCWB	71.0	73.3	72.9	68.6	67.4	66.8	64.6	63.2	63.6	63.6	64.5	67.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.2	76.8	77.5	73.5	70.2	70.1	69.0	69.0	69.0	68.1	69.3	72.9	(27)	
		MCDB	81.2	81.7	82.4	79.7	75.1	74.7	75.7	74.9	74.5	73.3	76.0	79.3	(28)	
	2%	WB	73.9	75.5	76.0	72.0	69.2	68.7	67.9	68.0	67.7	67.0	68.0	71.5	(29)	
		MCDB	80.3	80.8	80.7	77.1	73.9	73.8	74.0	73.9	72.9	72.0	73.8	77.4	(30)	
	5%	WB	72.8	74.6	74.3	70.4	68.5	67.8	66.8	66.9	66.2	65.7	66.8	69.9	(31)	
		MCDB	78.8	80.0	79.6	74.6	73.0	73.1	72.1	72.5	70.4	70.1	71.4	74.7	(32)	
	10%	WB	71.3	73.6	73.2	69.2	67.8	67.1	64.8	63.8	63.8	63.9	65.1	68.5	(33)	
		MCDB	76.2	78.9	78.5	73.0	72.1	71.8	68.9	67.6	68.0	67.6	69.3	72.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	7.4	7.4	7.2	6.9	6.3	6.3	6.2	6.3	6.8	7.2	7.2	(35)	
		MCDBR	7.8	7.9	8.6	8.2	7.6	7.8	8.7	8.5	8.2	8.4	7.5	6.9	(36)	
	5% WB	MCWBR	3.7	4.0	4.2	4.1	3.7	3.8	4.3	4.1	4.1	4.1	3.4	3.4	(37)	
		MCWBR	6.8	7.4	8.0	7.8	7.4	6.9	8.1	7.4	8.2	9.0	6.9	6.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.447	0.447	0.457	0.470	0.453	0.432	0.423	0.456	0.498	0.477	0.467	0.457	(40)	
		taud	2.376	2.383	2.360	2.304	2.336	2.409	2.433	2.310	2.183	2.262	2.282	2.330	(41)	
	Ebn at Noon		284	283	276	264	259	260	265	264	261	272	276	280	(42)	
		Edh at Noon	41	41	41	42	38	35	35	41	48	46	45	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		1896	1838	1782	1792	1602	1365	1389	1491	1630	1776	1903	1888	(44)	
	RadStd		121	79	95	83	135	130	114	102	111	118	147	121	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page