

PUCALLPA, Peru

WMO: 845150

Lat: 8.378S

Lon: 74.574W

Elev: 513

StdP: 14.43

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	64.6	67.6	59.3	76.9	67.6	62.8	87.1	70.0	15.3	73.9	12.9	74.3	4.1	140	0.274

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	17.7	94.7	79.2	93.3	79.0	92.1	78.7	80.7	90.7	80.1	89.9	79.7	89.3	6.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.0	148.1	85.4	77.3	144.9	84.8	77.1	143.6	84.6	44.8	91.2	44.2	90.8	43.6	89.8	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.9	11.7	9.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			60.7	96.9	2.9	1.7	58.7	98.1	57.0	99.1	55.4	100.1	53.3	101.3
			58.9	82.6	2.7	1.4	57.0	83.6	55.4	84.5	53.9	85.3	52.0	86.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	80.9	80.4	80.4	80.7	80.1	79.1	79.1	80.7	81.6	81.7	81.5	81.1	(6)
	DBStd	3.07	2.82	2.68	2.43	2.71	2.75	3.34	3.61	3.17	3.38	2.85	2.94	2.50	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	(9)
	CDD50	11175	958	852	943	921	933	873	902	953	948	983	946	963	(10)
	CDD65	5700	493	432	478	471	468	423	437	488	498	518	496	498	(11)
	CDH74	50634	4343	3595	3853	4083	3924	3452	3816	4720	4895	4864	4675	4414	(12)
	CDH80	19643	1579	1198	1249	1466	1413	1255	1553	2141	2251	2036	1876	1626	(13)
(14) Wind	WSAvg	3.1	3.6	3.4	2.9	2.8	2.6	2.7	2.5	3.1	3.1	3.4	3.5	3.7	(14)
(15) Precipitation	PrecAvg	61.6	6.2	6.7	8.0	6.1	3.7	3.1	1.6	2.2	3.8	6.0	6.7	6.1	(15)
	PrecMax	83.1	13.9	19.8	19.6	21.1	10.2	9.1	6.1	6.9	13.9	17.1	15.8	17.2	(16)
	PrecMin	29.8	0.8	0.8	1.3	0.7	0.4	0.2	0.0	0.0	0.7	0.1	0.4	0.3	(17)
	PrecStd	14.0	3.5	3.7	4.2	3.7	2.3	2.6	1.2	1.7	2.5	3.7	3.8	3.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	93.1	92.1	92.9	92.8	91.6	93.2	95.1	96.5	95.4	94.8	93.4	(19)
		MCWB	79.5	79.4	79.5	79.7	79.2	78.6	78.4	78.9	79.4	79.1	79.9	79.4	(20)
	2%	DB	91.7	90.8	90.0	91.1	91.0	89.9	91.2	93.3	94.8	93.4	93.0	91.5	(21)
		MCWB	79.0	78.8	78.7	78.9	78.6	78.0	77.7	78.3	79.1	79.1	79.5	78.8	(22)
	5%	DB	89.9	89.2	88.3	89.5	89.4	88.6	89.6	91.7	93.1	91.6	91.4	89.8	(23)
		MCWB	78.5	78.4	78.3	78.4	78.2	77.6	77.4	77.9	78.8	78.7	78.9	78.4	(24)
	10%	DB	87.9	87.1	86.4	87.7	87.6	87.1	87.9	90.0	91.2	89.7	89.5	88.1	(25)
		MCWB	78.0	77.9	77.8	77.9	77.8	77.2	76.9	77.4	78.3	78.1	78.5	78.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.7	80.5	80.6	80.8	80.3	80.0	80.0	80.1	81.0	80.9	81.0	80.6	(27)
		MCDB	90.5	89.5	89.1	89.6	89.4	88.8	90.6	91.7	93.3	91.6	91.0	89.6	(28)
	2%	WB	79.7	79.5	79.6	79.8	79.3	79.0	79.0	79.5	80.0	79.9	80.1	79.7	(29)
		MCDB	89.1	88.1	87.8	88.2	88.1	88.0	89.0	91.0	91.9	90.4	90.1	88.7	(30)
	5%	WB	79.0	78.8	78.9	79.0	78.8	78.3	78.2	78.8	79.3	79.1	79.4	79.0	(31)
		MCDB	87.9	87.1	86.9	87.1	87.4	86.8	87.6	90.1	90.9	89.5	89.0	88.1	(32)
	10%	WB	78.3	78.1	78.1	78.3	78.1	77.6	77.4	78.0	78.5	78.5	78.8	78.3	(33)
		MCDB	86.3	85.5	85.2	85.7	85.9	85.4	86.3	88.4	89.5	88.2	88.1	86.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	12.8	12.9	13.9	14.6	15.1	17.0	18.2	17.7	15.9	15.0	14.1	(35)
		MCDBR	16.5	15.7	15.6	16.5	17.3	17.2	19.2	20.2	20.5	18.7	17.9	16.7	(36)
	5% WB	MCWBR	6.1	6.0	6.1	6.3	6.9	7.1	8.1	7.8	7.7	6.7	6.6	6.4	(37)
		MCWBR	15.4	14.7	14.7	15.3	15.9	16.3	18.2	19.4	19.6	17.6	16.6	15.7	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.397	0.402	0.394	0.395	0.380	0.373	0.382	0.458	0.524	0.437	0.433	0.406	(40)
		taud	2.500	2.484	2.524	2.486	2.534	2.564	2.511	2.261	2.097	2.360	2.373	2.466	(41)
	Ebn at Noon	Ebn at Noon	299	297	294	285	280	278	277	263	254	283	286	296	(42)
		Edh at Noon	36	37	35	35	31	30	32	43	53	41	41	37	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1462	1335	1341	1409	1366	1376	1477	1617	1602	1567	1530	1464	(44)
	RadStd	RadStd	115	68	68	84	80	73	110	69	116	95	78	91	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page