

CUSCO, Peru

WMO: 846860

Lat: 13.536S

Lon: 71.939W

Elev: 10860

StdP: 9.77

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 32.4	(c) 34.1	(d) 5.7	(e) 11.1	(f) 59.8	(g) 11.6	(h) 15.0	(i) 59.5	(j) 18.2	(k) 62.9	(l) 16.3	(m) 63.0	(n) 0.5	(o) 290	(p) 0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	23.7	73.6	47.5	72.0	47.4	71.3	47.3	53.0	65.8	52.2	65.0	51.6	64.2	7.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.4	76.0	55.8	47.8	74.3	55.3	46.7	71.3	54.4	26.6	66.0	26.1	65.1	25.5	64.2	58.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.5	(b) 14.3	(c) 12.4	(e) 28.5	(f) 77.4	(g) 2.0	(h) 1.8	(i) 27.0	(j) 78.8	(k) 25.8	(l) 79.8	(m) 24.7	(n) 80.8	(o) 23.2	(p) 82.2		
(4) 16.5	(5) 14.3	(6) 12.4	(7) 28.5	(8) 77.4	(9) 2.0	(10) 1.8	(11) 27.0	(12) 78.8	(13) 25.8	(14) 79.8	(15) 24.7	(16) 80.8	(17) 23.2	(18) 82.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	56.9	56.7	56.7	56.0	53.8	51.8	51.2	53.2	55.5	57.2	58.2	57.2
	DBStd	3.14	2.28	2.32	2.15	2.12	2.00	2.04	2.23	2.46	2.42	2.38	2.07	2.19
	HDD50	25	0	0	0	0	1	7	13	4	0	0	0	0
	HDD65	3516	252	232	256	271	348	395	427	366	284	242	203	240
	CDD50	1986	213	189	209	179	118	62	51	103	166	224	247	225
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	34	1	2	1	1	0	0	0	2	4	9	10	4
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.6	3.6	3.6	3.4	3.2	3.0	3.0	3.2	3.7	4.2	4.3	4.4	3.9
Precipitation	PrecAvg	26.5	6.0	5.0	4.1	1.7	0.3	0.1	0.2	0.2	0.8	1.9	2.8	4.6
	PrecMax	37.6	14.2	10.0	7.5	3.5	0.9	1.1	1.2	1.4	2.0	4.3	7.1	9.8
	PrecMin	16.7	0.3	2.5	1.9	0.3	0.0	0.0	0.0	0.0	0.0	0.2	0.0	1.2
	PrecStd	5.1	2.3	1.7	1.4	0.9	0.2	0.2	0.2	0.3	0.5	0.9	1.4	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.8	72.5	72.3	73.2	72.6	71.8	71.9	73.6	73.8	75.3	75.4	73.8
		MCWB	51.5	51.5	51.4	48.8	46.6	44.9	44.2	44.9	46.5	47.6	48.4	48.7
	2%	DB	69.8	69.6	69.8	70.2	70.3	69.9	70.0	71.5	71.8	72.6	73.2	71.3
		MCWB	51.0	51.4	51.0	49.1	46.7	44.8	43.7	44.3	46.3	47.8	48.2	49.6
	5%	DB	67.7	67.1	67.7	68.4	69.2	68.2	68.2	69.6	69.9	70.2	71.3	68.4
		MCWB	50.7	50.9	50.6	49.2	46.6	44.5	43.4	44.2	46.1	48.0	48.8	49.7
	10%	DB	64.8	64.6	64.8	66.4	67.2	66.3	66.2	67.6	67.8	68.1	68.4	66.2
		MCWB	50.3	50.7	50.3	49.0	46.6	44.7	43.5	44.5	46.4	48.0	49.0	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	54.2	53.7	52.8	50.7	48.7	47.8	48.5	49.8	51.3	52.5	53.1
		MCDB	66.6	67.0	66.9	66.5	66.4	66.1	65.2	66.8	67.3	67.1	67.4	66.3
	2%	WB	52.5	52.8	52.6	51.5	49.5	47.6	46.6	47.4	48.7	50.3	51.4	51.9
		MCDB	64.7	65.0	65.3	65.1	65.0	65.0	63.6	65.3	65.8	66.0	66.7	65.4
	5%	WB	51.6	51.9	51.7	50.6	48.7	46.7	45.7	46.5	48.0	49.4	50.6	51.1
		MCDB	63.5	63.7	64.0	63.8	64.2	63.7	62.7	64.2	64.7	64.7	65.7	63.9
	10%	WB	50.9	51.1	50.9	49.8	47.8	45.8	44.8	45.7	47.2	48.7	49.8	50.3
		MCDB	62.0	62.0	62.4	62.6	63.0	62.5	62.0	63.0	63.3	63.4	64.5	62.4
Mean Daily Temperature Range	5% DB	MDBR	19.1	18.8	19.8	23.7	29.1	31.5	31.9	30.5	27.1	24.2	23.7	20.7
		MCDBR	22.3	22.1	23.0	26.6	32.1	34.0	35.0	34.0	30.2	27.8	27.2	24.3
		MCWBR	7.8	8.3	8.6	10.3	12.7	13.7	14.1	13.1	10.7	9.1	8.6	8.5
	5% WB	MCDBR	19.3	19.2	20.1	23.4	27.7	30.6	30.8	30.0	26.6	24.2	23.6	20.5
		MCWBR	7.6	7.8	8.0	9.4	11.5	12.9	12.9	11.7	9.7	8.3	8.2	7.9
Clear-Sky Solar Irradiance	taub	0.304	0.292	0.291	0.276	0.270	0.265	0.269	0.313	0.352	0.329	0.313	0.305	
	taud	2.575	2.650	2.652	2.705	2.685	2.707	2.661	2.461	2.350	2.444	2.509	2.568	
	Ebn at Noon	330	331	325	320	312	309	310	303	301	315	325	329	
	Edh at Noon	34	31	30	27	26	25	26	34	40	38	36	34	
All-Sky Solar Radiation	RadAvg	1503	1456	1471	1517	1555	1518	1547	1641	1630	1655	1736	1560	
	RadStd	87	91	80	93	99	88	113	91	126	98	113	95	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-1.08	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page