

PISCO, Peru

WMO: 846910

Lat: 13.745S

Lon: 76.220W

Elev: 39

StdP: 14.68

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	53.6	55.2	49.9	53.3	54.0	51.5	56.5	55.6	24.4	68.6	21.0	67.3	3.2	100	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.6	84.3	74.0	82.6	73.1	80.9	72.3	74.9	82.4	73.8	80.9	72.8	79.6	13.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	118.5	80.0	71.4	116.0	79.4	70.1	110.7	78.3	38.5	82.7	37.3	80.9	36.5	80.0	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.0	20.6	18.4	50.4	86.7	1.2	1.8	49.5	88.1	48.8	89.1	48.1	90.2	47.2	91.5		
			48.8	76.5	0.9	1.4	48.1	77.5	47.6	78.3	47.0	79.1	46.4	80.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.3	74.3	76.0	75.0	71.4	66.9	64.1	63.0	62.7	63.8	65.1	67.1	70.7
	DBStd	5.27	2.50	2.27	2.38	2.56	2.72	2.74	2.58	2.32	2.19	2.09	2.21	2.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	290	0	0	0	0	13	48	73	79	47	24	6	0
	CDD50	6678	754	727	774	642	523	424	404	393	415	468	513	641
	CDD65	1494	289	307	309	192	71	23	12	7	12	27	69	176
	CDH74	4954	1106	1493	1290	521	84	28	10	5	7	8	56	346
	CDH80	573	128	230	167	31	1	0	0	0	0	0	0	16
(14) Wind	WSAvg	7.7	9.0	8.9	8.6	8.0	6.4	5.8	6.1	6.5	7.3	8.0	8.6	9.0
(15) Precipitation	PrecAvg	0.4	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecMax	0.9	0.6	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecMin	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.9	86.4	85.8	82.7	78.8	77.1	75.3	74.1	75.2	75.2	77.4	82.2
		MCWB	75.3	75.8	74.6	72.9	70.2	68.9	68.8	67.6	68.5	67.5	69.1	72.7
	2%	DB	82.8	84.4	83.8	80.6	76.5	73.8	71.8	71.3	71.9	73.3	75.5	79.2
		MCWB	73.3	74.3	73.5	71.7	68.9	66.5	65.1	64.6	64.9	66.0	67.8	70.5
	5%	DB	80.9	82.6	82.1	78.8	74.4	71.5	69.8	69.2	70.1	71.6	73.7	77.3
		MCWB	72.2	73.4	72.7	70.5	67.7	65.2	63.6	63.2	63.7	65.0	66.7	69.4
	10%	DB	79.1	80.9	80.4	77.1	72.8	69.6	68.0	67.7	68.4	70.0	72.3	75.5
		MCWB	71.3	72.5	72.0	69.8	66.8	63.9	62.5	62.1	62.7	63.9	65.9	68.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.1	76.9	75.9	74.0	70.6	69.4	69.1	68.0	68.7	68.1	70.0	72.9
		MCDB	84.2	85.6	84.0	81.8	77.1	76.1	74.9	73.9	74.5	74.2	76.8	80.9
	2%	WB	74.2	75.2	74.2	71.9	69.2	67.1	65.5	65.1	65.5	66.2	68.2	71.1
		MCDB	81.5	82.7	81.6	79.2	75.3	73.3	70.9	70.1	70.8	72.3	74.6	78.4
	5%	WB	72.9	74.1	73.0	70.9	68.0	65.3	63.9	63.3	63.9	65.1	67.1	69.8
		MCDB	79.6	81.2	80.0	77.7	73.6	70.8	69.0	68.3	69.4	71.0	73.4	76.4
	10%	WB	71.9	72.9	72.1	69.8	67.0	64.0	62.8	62.1	63.0	63.9	65.9	68.9
		MCDB	78.3	79.7	79.1	76.2	72.1	68.6	67.3	66.8	68.2	69.4	71.8	75.1
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.6	12.6	12.8	11.9	10.7	10.6	10.8	11.2	11.8	12.5	12.1
		MCDBR	13.4	13.7	13.8	14.3	14.2	13.8	13.5	13.2	12.9	13.1	13.7	13.3
		MCWBR	7.5	7.4	7.5	8.5	9.3	9.5	9.3	9.0	8.7	8.7	8.8	7.8
	5% WB	MCDBR	12.8	13.3	13.0	13.8	13.4	13.2	12.5	12.3	12.5	12.7	13.4	12.8
		MCWBR	7.6	7.5	7.6	8.6	9.2	9.6	9.1	8.8	8.8	8.8	8.9	7.9
(40) Clear-Sky Solar Irradiance	taub		0.452	0.449	0.451	0.465	0.423	0.420	0.415	0.435	0.461	0.440	0.445	0.454
	taud		2.309	2.329	2.330	2.251	2.310	2.295	2.310	2.242	2.169	2.250	2.256	2.267
	Ebn at Noon		284	283	276	261	262	257	262	266	269	282	284	283
	Edh at Noon		44	43	42	43	38	37	38	43	49	46	46	46
(44) All-Sky Solar Radiation	RadAvg		2160	2076	2021	1908	1631	1304	1260	1449	1762	2045	2226	2159
	RadStd		125	109	64	64	97	92	88	82	115	96	120	130

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.54	+1.06	+1.94	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page