

PISCO, Peru

WMO: 846910

Lat: 13.745S

Lon: 76.220W

Elev: 12

StdP: 101.18

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	12.9	10.0	7.6	12.2	10.8	8.1	13.1	10.9	20.3	9.4	19.6	1.4	100	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.0	29.0	23.3	28.1	22.8	27.2	22.4	23.8	28.0	23.2	27.2	22.6	26.5	6.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	16.9	26.7	21.9	16.6	26.3	21.1	15.8	25.7	71.7	28.2	69.0	27.2	67.0	26.7	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	9.2	8.2	10.2	30.4	0.7	1.0	9.7	31.1	9.3	31.7	8.9	32.3	8.4	33.1
			9.3	24.7	0.5	0.8	9.0	25.3	8.7	25.7	8.4	26.2	8.0	26.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	23.5	24.4	23.9	21.9	19.4	17.9	17.2	17.0	17.7	18.4	19.5	21.5
	DBStd	2.93	1.39	1.26	1.32	1.42	1.51	1.52	1.43	1.29	1.21	1.16	1.23	1.36
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	161	0	0	0	0	7	27	41	44	26	13	3	0
	CDD10.0	3710	419	404	430	357	291	236	224	218	231	260	285	356
	CDD18.3	830	161	171	172	107	39	13	7	4	7	15	38	98
	CDH23.3	2752	614	829	717	289	47	16	6	3	4	4	31	192
	CDH26.7	318	71	128	93	17	1	0	0	0	0	0	0	9
(14) Wind	WSAvg	3.4	4.0	4.0	3.8	3.6	2.9	2.6	2.7	2.9	3.3	3.6	3.9	4.0
(15) Precipitation	PrecAvg	11	2	4	2	0	0	0	0	0	0	0	0	1
	PrecMax	24	16	5	3	1	1	1	1	1	1	1	1	2
	PrecMin	5	0	2	1	0	0	0	0	0	0	0	0	0
	PrecStd	4	3	1	1	0	0	0	0	0	0	0	0	0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.0	30.2	29.9	28.2	26.0	25.0	24.1	23.4	24.0	24.0	25.2	27.9
		MCWB	24.1	24.3	23.7	22.7	21.2	20.5	20.4	19.8	20.3	19.7	20.6	22.6
	2%	DB	28.2	29.1	28.8	27.0	24.7	23.2	22.1	21.8	22.2	22.9	24.1	26.2
		MCWB	22.9	23.5	23.1	22.1	20.5	19.2	18.4	18.1	18.3	18.9	19.9	21.4
	5%	DB	27.2	28.1	27.9	26.0	23.6	21.9	21.0	20.7	21.2	22.0	23.2	25.2
		MCWB	22.3	23.0	22.6	21.4	19.8	18.5	17.6	17.3	17.6	18.3	19.3	20.8
	10%	DB	26.2	27.2	26.9	25.0	22.7	20.9	20.0	19.9	20.2	21.1	22.4	24.2
		MCWB	21.8	22.5	22.2	21.0	19.3	17.7	17.0	16.7	17.1	17.7	18.8	20.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.5	24.9	24.4	23.3	21.5	20.8	20.6	20.0	20.4	20.1	21.1	22.7
		MCDB	29.0	29.8	28.9	27.6	25.1	24.5	23.8	23.3	23.6	23.5	24.9	27.2
	2%	WB	23.4	24.0	23.5	22.2	20.7	19.5	18.6	18.4	18.6	19.0	20.1	21.7
		MCDB	27.5	28.2	27.6	26.2	24.0	22.9	21.6	21.2	21.6	22.4	23.7	25.8
	5%	WB	22.7	23.4	22.8	21.6	20.0	18.5	17.7	17.4	17.7	18.4	19.5	21.0
		MCDB	26.5	27.3	26.7	25.4	23.1	21.6	20.6	20.1	20.8	21.7	23.0	24.7
	10%	WB	22.1	22.7	22.3	21.0	19.4	17.8	17.1	16.7	17.2	17.7	18.9	20.5
		MCDB	25.7	26.5	26.2	24.6	22.3	20.4	19.6	19.3	20.1	20.8	22.1	23.9
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	7.0	7.0	7.1	6.6	6.0	5.9	6.0	6.2	6.5	6.9	6.7
		MCDBR	7.4	7.6	7.7	8.0	7.9	7.7	7.5	7.3	7.2	7.3	7.6	7.4
		MCWBR	4.2	4.1	4.2	4.7	5.1	5.3	5.2	5.0	4.8	4.8	4.9	4.3
	5% WB	MCDBR	7.1	7.4	7.2	7.7	7.4	7.3	7.0	6.8	7.0	7.0	7.4	7.1
		MCWBR	4.2	4.2	4.2	4.8	5.1	5.3	5.1	4.9	4.9	4.9	5.0	4.4
(40) Clear-Sky Solar Irradiance	taub		0.452	0.449	0.451	0.465	0.423	0.420	0.415	0.435	0.461	0.440	0.445	0.454
	taud		2.309	2.329	2.330	2.251	2.310	2.295	2.310	2.242	2.169	2.250	2.256	2.267
	Ebn at Noon		896	891	870	823	826	810	825	838	848	888	895	893
	Edh at Noon		140	136	132	136	120	118	119	135	153	145	146	145
(44) All-Sky Solar Radiation	RadAvg		6.81	6.54	6.37	6.01	5.14	4.11	3.97	4.57	5.55	6.45	7.02	6.81
	RadStd		0.39	0.34	0.20	0.20	0.31	0.29	0.28	0.26	0.36	0.30	0.38	0.41

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.30	+0.59	+1.08	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page