

LA PAZ EL ALTO, Bolivia

WMO: 852010

Lat: 16.513S

Lon: 68.192W

Elev: 4062

StdP: 61.15

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-5.0	-3.9	-20.8	1.0	6.0	-18.1	1.3	7.3	11.5	10.7	9.8	10.5	2.1	20	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	12.7	18.1	5.7	17.1	5.6	16.2	5.5	9.1	13.8	8.6	13.3	8.2	12.8	4.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
7.2	10.5	10.0	6.9	10.3	9.8	6.2	9.8	9.2	39.1	13.9	37.8	13.4	36.4	13.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	7.4	6.6	DB	-8.0	20.2	0.8	1.2	-8.5	21.0	-9.0	21.7	-9.4	22.4	-10.0	23.3
			WB	-10.6	10.4	0.9	0.9	-11.2	11.1	-11.7	11.7	-12.2	12.2	-12.9	12.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	9.2	9.2	8.9	8.2	6.5	5.4	5.1	6.1	7.4	8.7	9.5	9.6		
	DBStd	2.08	1.33	1.23	1.23	1.18	1.37	1.38	1.42	1.44	1.42	1.36	1.28	1.33		
	HDD10.0	841	32	29	37	56	108	139	151	122	79	43	23	23		
	HDD18.3	3841	283	257	291	305	366	389	409	381	328	298	263	270		
	CDD10.0	41	6	6	4	1	0	0	0	0	1	3	9	11		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	3.1	3.1	3.1	3.0	2.8	2.9	3.0	3.2	3.2	3.4	3.4	3.4	3.3		
(15) Precipitation	PrecAvg	535	119	90	76	30	10	6	4	12	30	36	47	86		
	PrecMax	798	220	170	179	70	38	42	27	62	87	110	114	160		
	PrecMin	355	13	11	14	0	0	0	0	0	1	3	7	29		
	PrecStd	118	46	39	41	17	10	9	6	14	21	24	27	32		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	17.2	17.9	17.1	16.9	16.1	16.2	17.1	18.0	18.2	19.2	19.0		
		MCWB	7.0	7.7	7.4	5.4	4.4	3.4	3.2	3.4	4.5	4.9	5.5	5.9		
	2%	DB	16.0	15.9	16.1	16.0	15.8	15.1	15.1	16.0	16.6	17.1	18.0	17.2		
		MCWB	7.4	7.8	7.3	5.9	4.1	3.2	3.0	3.5	4.3	5.0	5.5	6.5		
	5%	DB	14.8	14.2	14.9	15.0	14.9	14.1	14.1	15.0	15.5	16.1	16.9	16.0		
		MCWB	7.6	7.8	7.4	5.8	3.9	3.0	2.7	3.4	4.1	5.1	5.7	7.0		
	10%	DB	13.2	13.1	13.5	14.0	13.9	13.1	13.0	14.0	14.2	15.0	15.8	14.6		
		MCWB	7.5	7.7	7.2	5.8	3.8	2.6	2.4	3.0	4.1	5.3	5.9	6.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	9.7	9.2	8.8	7.5	6.1	5.6	6.3	7.6	8.1	8.7	9.1		
		MCDB	14.1	14.5	14.2	13.5	13.0	12.7	12.5	12.8	13.5	14.0	14.5	14.3		
	2%	WB	8.9	9.0	8.7	8.0	6.6	5.0	4.6	5.5	6.6	7.4	8.1	8.5		
		MCDB	13.3	13.5	13.5	12.9	12.2	11.9	11.6	12.3	12.6	13.3	13.8	13.4		
	5%	WB	8.3	8.5	8.1	7.5	5.8	4.2	3.9	4.7	6.1	6.9	7.6	8.0		
		MCDB	12.6	12.7	12.8	12.3	11.6	11.1	11.1	11.7	12.1	12.7	13.3	12.9		
	10%	WB	7.9	8.0	7.7	7.0	5.0	3.6	3.2	4.1	5.5	6.4	7.0	7.6		
		MCDB	11.9	11.9	12.1	11.7	11.0	10.6	10.5	11.0	11.4	12.0	12.8	12.3		
(35) Mean Daily Temperature Range	MDBR		9.1	9.1	10.0	12.3	15.5	16.4	16.4	16.4	14.6	13.2	12.7	10.7		
	5% DB	MCDBR	11.1	10.9	12.3	14.3	17.0	17.7	18.1	18.2	16.7	15.3	15.3	13.0		
		MCWBR	4.7	4.9	5.4	6.5	8.4	9.1	9.2	8.8	7.7	6.5	6.2	5.3		
	5% WB	MCDBR	9.3	9.4	10.1	11.2	13.8	15.6	15.8	15.4	13.3	12.4	11.8	10.2		
		MCWBR	4.7	4.7	5.0	5.7	7.3	8.4	8.5	8.0	6.6	5.8	5.3	4.8		
(40) Clear-Sky Solar Irradiance	taub		0.274	0.270	0.263	0.248	0.239	0.234	0.240	0.274	0.323	0.294	0.277	0.278		
	taud		2.636	2.672	2.704	2.753	2.717	2.746	2.681	2.514	2.364	2.481	2.561	2.590		
	Ebn at Noon		1072	1066	1052	1035	1014	1003	1003	991	974	1028	1061	1067		
	Edh at Noon		101	96	90	80	77	72	79	100	125	115	108	105		
(44) All-Sky Solar Radiation	RadAvg		5.54	5.55	5.52	5.41	5.25	4.97	5.09	5.57	5.84	6.21	6.50	5.87		
	RadStd		0.32	0.26	0.32	0.29	0.26	0.25	0.25	0.27	0.45	0.41	0.40	0.32		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) +0.38	(e) N/A	(f) -2.66	(g) +0.76	(h) N/A	(i) N/A	(j) -105	(k) -128	(l) +20	(m) N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page