

CURICO, Chile

WMO: 856290

Lat: 34.9664S

Lon: 71.2167W

Elev: 23

StdP: 101.05

Time Zone: -4.00 (CHL)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.7	0.6	-1.2	3.4	0.9	-0.2	3.7	2.1	10.1	10.4	8.2	11.1	1.1	60	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.5	31.9	18.9	30.7	18.7	29.5	18.4	20.3	29.3	19.6	28.7	19.0	28.0	3.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.5	11.8	25.0	15.8	11.2	24.1	15.0	10.7	22.9	58.3	29.5	56.0	29.1	53.9	28.0	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	5.9	5.3	-2.7	34.0	1.1	1.1	-3.5	34.9	-4.2	35.5	-4.8	36.2	-5.6	37.0		
			-2.8	22.8	1.1	2.3	-3.6	24.4	-4.2	25.8	-4.8	27.1	-5.6	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	21.2	21.0	18.3	13.9	10.5	8.6	7.7	9.4	11.4	14.2	17.3	20.0	(6)
(7)		DBStd	5.34	1.87	2.02	2.23	2.34	2.75	2.86	2.62	2.60	2.21	2.42	2.44	2.28	(7)
(8)		HDD10.0	226	0	0	0	2	28	61	79	43	11	2	0	0	(8)
(9)		HDD18.3	1706	2	4	28	135	242	293	329	278	208	129	47	11	(9)
(10)		CDD10.0	1838	348	309	258	117	44	18	8	23	53	132	219	309	(10)
(11)		CDD18.3	279	92	79	27	1	0	0	0	0	0	2	16	62	(11)
(12)		CDH23.3	3671	1133	951	406	37	1	0	0	0	3	42	288	810	(12)
(13)		CDH26.7	1178	412	354	90	4	0	0	0	0	4	59	253		(13)
(14)	Wind	WSAvg	2.3	2.7	2.5	2.2	1.9	1.9	2.1	2.1	2.2	2.4	2.5	2.8	2.9	(14)
(15)	Precipitation	PrecAvg	683	2	4	12	43	115	166	130	106	53	28	13	10	(15)
(16)		PrecMax	1170	30	42	101	189	383	594	333	328	202	111	40	121	(16)
(17)		PrecMin	233	0	0	1	7	14	22	30	17	6	2	2	0	(17)
(18)		PrecStd	223	6	10	20	40	90	125	65	71	50	28	10	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.9	31.0	26.8	21.8	17.8	16.8	21.1	23.5	27.0	30.4	32.9	(19)
(20)		MCWB	18.8	19.4	18.5	16.9	15.0	13.5	12.5	14.8	15.1	17.6	18.3	18.7		(20)
(21)		2%	DB	31.8	31.8	28.9	24.1	19.0	15.9	15.0	17.9	20.7	24.2	28.2	30.9	(21)
(22)		MCWB	19.0	19.0	17.8	15.9	13.9	12.5	11.4	12.8	14.3	16.0	17.5	18.4		(22)
(23)		5%	DB	30.5	30.3	27.5	22.1	17.2	14.5	13.6	16.0	18.7	22.4	26.6	29.5	(23)
(24)		MCWB	18.8	18.8	17.4	15.0	13.4	12.0	10.8	11.9	13.1	14.9	16.9	18.2		(24)
(25)		10%	DB	29.1	29.0	25.9	20.0	15.7	13.1	12.2	14.2	16.8	20.8	24.8	27.9	(25)
(26)		MCWB	18.4	18.6	16.9	14.1	12.6	11.1	10.1	10.9	12.1	14.2	16.0	17.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.2	19.9	17.6	16.1	14.5	13.2	15.2	16.1	18.2	19.5	20.6	(27)
(28)		MDCB	29.5	30.0	28.0	24.2	18.5	16.1	15.3	20.0	21.5	25.4	28.5	29.2		(28)
(29)		2%	WB	20.3	20.2	18.9	16.5	14.7	13.1	12.1	13.4	14.7	16.5	18.2	19.5	(29)
(30)		MDCB	29.2	29.8	27.2	22.5	17.8	15.0	14.2	17.0	19.8	23.0	27.2	28.7		(30)
(31)		5%	WB	19.6	19.5	18.0	15.6	13.8	12.3	11.1	12.3	13.5	15.4	17.2	18.8	(31)
(32)		MDCB	28.6	29.0	25.9	20.7	16.7	13.9	13.0	15.2	17.6	21.3	25.5	27.9		(32)
(33)		10%	WB	18.8	18.8	17.2	14.6	12.8	11.4	10.3	11.4	12.5	14.5	16.3	18.0	(33)
(34)		MDCB	27.8	28.0	24.7	18.9	15.1	12.9	12.0	13.8	16.0	19.9	23.9	26.9		(34)
(35)	Mean Daily Temperature Range	MDBR	16.5	16.7	15.2	12.5	9.5	7.8	8.1	9.8	10.9	12.2	14.4	15.7		(35)
(36)		5% DB	MCDBR	18.1	18.4	17.8	16.6	12.4	9.5	10.0	12.5	14.5	15.5	17.4	18.0	(36)
(37)		MCWBR	7.5	8.0	8.1	9.0	7.7	6.3	6.7	7.8	8.3	8.0	8.1	7.6		(37)
(38)		5% WB	MCDBR	16.7	17.3	16.2	14.6	10.6	7.8	8.5	11.4	13.1	14.2	16.5	17.0	(38)
(39)		MCWBR	7.8	8.2	8.1	8.4	7.0	5.5	6.0	7.3	7.8	7.8	8.1	7.9		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.349	0.346	0.338	0.343	0.353	0.339	0.326	0.343	0.359	0.345	0.330	0.339		(40)
(41)		taud	2.428	2.449	2.463	2.433	2.392	2.457	2.466	2.410	2.345	2.402	2.460	2.452		(41)
(42)		Ebn at Noon	987	968	937	870	796	784	820	857	899	957	999	1001		(42)
(43)		Edh at Noon	122	115	105	96	88	78	81	97	117	119	118	120		(43)
(44)	All-Sky Solar Radiation	RadAvg	8.61	7.65	6.11	4.12	2.48	1.95	2.19	2.94	4.33	5.75	7.52	8.48		(44)
(45)		RadStd	0.40	0.28	0.32	0.38	0.27	0.28	0.26	0.35	0.41	0.42	0.43	0.38		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.39	+0.51	N/A	+0.62	N/A	N/A	N/A	-84	+187	+105

Nomenclature: See separate page