

RIVERA, Uruguay

WMO: 863500

Lat: 30.8965S

Lon: 55.5427W

Elev: 796

StdP: 14.28

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.1	38.8	28.1	22.7	45.3	30.7	25.7	44.1	24.9	58.4	22.1	60.6	5.3	230	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.9	94.2	73.4	91.5	72.9	88.8	71.8	77.1	87.9	75.7	85.9	74.5	84.0	9.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.1	130.9	82.0	72.9	125.7	80.7	71.8	120.9	79.4	41.2	88.0	39.8	86.0	38.7	84.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	18.6	16.4	31.8	99.0	1.8	2.3	30.4	100.7	29.4	102.1	28.3	103.4	27.0	105.1		
(5)			30.4	79.4	1.8	1.9	29.1	80.7	28.1	81.8	27.1	82.9	25.7	84.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	76.4	74.9	72.0	65.8	60.2	55.7	54.8	57.6	59.9	65.2	69.7	74.0		
	DBStd	9.86	4.68	4.80	5.19	6.30	6.59	7.43	8.12	8.46	7.22	5.75	5.59	5.45		
	HDD50	98	0	0	0	0	6	26	40	20	6	0	0	0		
	HDD65	1411	0	1	7	63	176	293	332	262	186	68	19	4		
	CDD50	5747	819	697	683	475	322	197	190	257	302	470	592	743		
	CDD65	1587	355	279	225	88	28	15	17	33	32	73	161	281		
	CDH74	13047	3341	2281	1654	537	120	42	70	246	267	510	1350	2629		
	CDH80	4661	1396	828	508	135	16	1	5	61	81	140	434	1056		
(14) Wind	WSAvg	7.4	7.5	7.1	6.8	6.5	6.3	7.0	7.5	7.9	8.6	8.4	8.0	7.4		
(15) Precipitation	PrecAvg	58.7	4.8	6.2	4.6	7.0	5.0	3.7	3.4	3.0	4.3	6.1	5.1	5.5		
	PrecMax	98.4	13.1	12.4	15.0	20.9	14.9	7.9	9.1	8.2	11.6	12.8	19.1	18.9		
	PrecMin	38.5	0.5	0.9	0.8	0.4	0.0	0.5	0.1	0.3	0.0	0.8	1.1	0.0		
	PrecStd	13.9	3.0	3.1	3.5	4.9	3.2	1.9	2.2	1.9	2.4	2.7	3.7	4.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.3	95.2	94.7	89.1	82.2	78.7	80.0	86.0	88.3	89.2	92.6	97.1		
		MCWB	74.0	75.3	74.0	72.9	70.3	68.1	66.5	68.3	70.2	70.9	70.8	73.1		
	2%	DB	94.3	91.6	88.9	83.9	77.1	74.4	75.7	81.1	81.1	83.9	88.4	92.9		
		MCWB	73.3	74.3	72.4	70.3	67.3	66.6	65.4	66.4	67.8	70.5	70.4	72.2		
	5%	DB	91.3	88.3	85.4	80.0	73.6	70.8	71.5	75.9	76.1	79.4	85.1	89.4		
		MCWB	72.8	72.8	71.8	68.1	65.7	65.0	63.8	64.3	65.0	67.3	69.1	70.9		
	10%	DB	88.1	85.2	82.5	76.5	70.3	67.1	67.1	71.4	71.6	75.8	81.7	86.2		
		MCWB	72.2	71.6	70.4	67.2	64.1	62.3	61.2	62.8	62.6	65.3	67.6	70.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.3	78.8	77.6	75.3	72.3	70.0	68.9	70.1	72.4	74.8	75.6	77.8		
		MCDB	90.2	89.6	87.8	84.2	79.3	75.8	75.8	81.9	83.1	86.2	86.4	89.2		
	2%	WB	76.5	76.9	75.6	72.9	69.2	67.7	66.5	67.5	69.1	72.0	73.2	75.8		
		MCDB	87.6	87.4	84.2	80.9	74.3	72.6	73.3	77.0	78.1	80.0	83.3	86.7		
	5%	WB	75.2	75.3	73.8	70.8	67.0	65.6	64.5	65.4	66.9	69.4	71.5	73.9		
		MCDB	85.8	84.2	81.7	76.4	71.6	69.8	69.8	74.2	73.8	76.6	79.9	84.6		
	10%	WB	74.0	73.7	72.3	68.8	64.8	63.5	62.2	63.5	64.5	67.5	69.8	72.2		
		MCDB	84.2	81.2	79.5	73.6	69.1	67.0	66.9	70.3	69.9	73.3	77.5	82.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.9	18.0	17.9	17.4	15.2	14.5	15.5	17.2	17.0	17.4	19.6	20.4		
		MCDBR	24.2	22.2	21.6	22.3	19.3	17.4	19.5	22.5	22.8	23.5	24.9	25.3		
		MCWBR	8.1	8.1	8.7	10.4	9.9	9.6	10.0	10.5	11.4	11.7	10.4	9.6		
		MCDBR	19.9	17.9	17.8	17.0	15.2	15.0	16.3	20.2	19.3	19.0	18.9	20.8		
	5% WB	MCWBR	8.4	8.2	8.3	9.1	9.0	8.9	9.5	10.7	10.6	10.6	10.0	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.409	0.397	0.386	0.376	0.359	0.371	0.374	0.464	0.495	0.437	0.389	0.405		
	taud		2.357	2.399	2.415	2.396	2.421	2.380	2.341	2.030	1.971	2.200	2.365	2.340		
	Ebn at Noon		296	293	285	271	259	246	250	237	247	278	300	298		
	Edh at Noon		42	39	36	33	29	29	31	47	55	47	41	43		
(44) All-Sky Solar Radiation	RadAvg		2176	1939	1657	1261	900	760	855	1082	1344	1699	2101	2217		
	RadStd		178	126	151	158	89	78	86	104	133	220	259	172		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	-1.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page