

SALTO, Uruguay

WMO: 863600

Lat: 31.4381S

Lon: 57.9810W

Elev: 42

StdP: 100.82

Time Zone: -3.00 (W03)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.9	2.6	-1.8	3.3	6.0	-0.6	3.6	7.0	10.1	13.7	9.3	16.3	1.1	120	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	35.7	23.7	34.2	23.3	32.8	22.8	25.9	32.1	25.1	31.3	24.3	30.1	4.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.1	29.4	23.3	18.2	28.2	22.6	17.4	27.2	80.6	32.2	76.9	31.2	73.7	30.1	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.5	8.3	7.5	DB	-1.6	38.6	1.4	1.6	-2.6	39.8	-3.3	40.7	-4.1	41.6	-5.1	42.7	(4)
(5)			WB	-1.9	28.2	1.3	1.4	-2.8	29.2	-3.6	30.0	-4.4	30.7	-5.4	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	25.6	24.5	22.9	19.0	15.5	13.4	12.7	14.4	16.1	19.2	21.5	24.3	(6)
(7)		DBStd	5.76	2.78	2.62	3.00	3.60	4.03	4.22	4.65	4.77	4.15	3.36	3.15	3.01	(7)
(8)		HDD10.0	52	0	0	0	0	3	13	23	10	2	1	0	0	(8)
(9)		HDD18.3	761	0	1	3	33	108	157	186	144	92	29	9	1	(9)
(10)		CDD10.0	3359	483	405	401	271	173	116	106	147	184	287	344	442	(10)
(11)		CDD18.3	1026	225	172	145	54	19	9	11	22	24	57	103	184	(11)
(12)		CDH23.3	9614	2450	1572	1249	386	113	24	47	176	239	479	986	1894	(12)
(13)	CDH26.7	3901	1177	642	475	104	22	2	7	47	71	141	358	856	(13)	
(14)	Wind	WSAvg	3.1	2.9	2.8	2.8	2.6	2.8	3.1	3.4	3.7	3.6	3.5	3.2	(14)	
(15)	Precipitation	PrecAvg	1272	120	123	142	146	96	84	75	62	96	126	126	111	(15)
(16)		PrecMax	1816	559	449	418	509	376	370	260	336	257	306	381	372	(16)
(17)		PrecMin	696	3	6	12	16	0	6	7	1	8	5	22	13	(17)
(18)		PrecStd	273	100	96	98	107	78	72	55	54	59	74	74	84	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.0	35.5	35.2	32.1	29.3	25.8	27.6	30.8	32.1	32.5	35.0	37.8	(19)
(20)			MCWB	24.2	23.6	25.3	23.2	22.5	20.6	21.0	21.5	21.9	22.2	22.9	23.8	(20)
(21)		2%	DB	35.9	33.8	32.8	29.6	26.1	23.7	24.6	27.7	28.7	30.1	32.2	35.2	(21)
(22)			MCWB	23.6	23.3	23.4	21.9	20.9	19.9	19.6	19.8	19.9	21.4	21.7	23.3	(22)
(23)		5%	DB	34.2	32.2	31.1	27.4	24.1	21.7	22.2	25.1	26.1	28.0	30.4	33.2	(23)
(24)			MCWB	23.6	23.0	22.6	20.8	19.7	18.8	17.9	18.5	18.9	20.0	20.7	22.1	(24)
(25)		10%	DB	32.6	30.7	29.4	25.5	22.1	20.0	20.1	22.3	23.6	26.0	28.7	31.2	(25)
(26)			MCWB	22.9	22.7	22.0	19.9	18.3	17.5	16.5	16.9	17.3	19.2	20.2	21.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	26.9	26.6	24.8	23.3	22.0	21.7	22.1	23.2	24.3	25.2	26.5	(27)
(28)			MCD B	34.0	32.8	32.7	30.2	27.7	24.4	25.6	29.0	28.8	29.6	32.4	33.6	(28)
(29)		2%	WB	25.5	25.7	25.4	23.4	22.0	20.6	19.8	20.4	21.2	22.8	23.5	25.1	(29)
(30)			MCD B	32.7	31.4	30.5	27.6	24.8	22.4	23.4	26.7	27.1	28.1	29.5	32.4	(30)
(31)		5%	WB	24.7	24.6	24.1	22.3	20.5	19.3	18.7	19.1	19.8	21.5	22.3	24.1	(31)
(32)			MCD B	31.3	29.6	29.1	25.7	23.2	21.1	22.0	24.1	24.8	26.3	27.8	30.8	(32)
(33)		10%	WB	23.9	23.5	23.1	21.2	18.9	18.2	17.2	17.7	18.4	20.4	21.3	23.0	(33)
(34)			MCD B	30.2	28.3	27.1	24.0	21.3	20.1	19.5	21.3	21.9	24.3	26.2	28.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.5	11.3	11.3	10.5	10.3	9.5	10.4	11.3	11.6	11.4	12.5	12.6	(35)
(36)			MCDBR	14.6	13.7	13.8	13.0	11.9	10.0	11.5	13.9	14.6	14.4	15.2	15.5	(36)
(37)			MCWBR	5.6	5.4	5.8	6.4	6.6	6.4	6.7	7.0	7.3	7.0	6.6	6.3	(37)
(38)		5% WB	MCD BR	12.4	11.1	11.4	10.4	10.0	8.1	10.1	11.8	11.7	12.0	12.3	12.3	(38)
(39)			MCWBR	5.7	5.7	5.4	5.7	6.4	5.8	6.4	6.2	6.8	6.6	6.6	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.415	0.403	0.388	0.383	0.365	0.377	0.373	0.448	0.497	0.444	0.400	0.408	(40)	
(41)		taud	2.343	2.393	2.417	2.387	2.410	2.363	2.346	2.088	1.970	2.190	2.340	2.342	(41)	
(42)		Ebn at Noon	926	917	896	844	807	763	787	760	777	868	934	936	(42)	
(43)		Edh at Noon	134	124	113	105	92	91	96	139	174	150	134	135	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.02	6.13	5.27	3.96	2.86	2.45	2.71	3.49	4.50	5.50	6.80	7.12	(44)	
(45)		RadStd	0.60	0.43	0.46	0.50	0.26	0.25	0.28	0.32	0.45	0.64	0.62	0.50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page