

MELO, Uruguay

WMO: 864400

Lat: 32.338S

Lon: 54.217W

Elev: 374

StdP: 14.50

Time Zone: -3.00 (W03)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.2	34.8	29.0	23.3	37.6	31.1	25.7	39.3	22.7	51.1	19.4	59.3	0.3	N/A	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	92.7	72.6	89.7	72.1	87.0	71.6	76.8	85.6	75.3	83.9	73.9	82.3	7.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.3	130.1	81.5	73.0	124.0	79.2	71.6	118.2	77.5	40.6	85.5	39.1	84.2	37.8	82.0	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.9	16.2	13.6	DB	27.6	97.8	2.2	1.7	26.0	99.0	24.7	100.0	23.5	101.0	21.9	102.2
			WB	26.9	80.8	2.4	3.5	25.2	83.4	23.9	85.4	22.5	87.4	20.8	90.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	74.5	73.6	71.4	64.1	58.2	54.0	52.1	55.3	57.8	63.1	67.1	70.7	(6)
	DBStd	9.82	4.88	4.90	4.99	6.35	6.56	6.71	7.74	7.72	6.57	5.63	6.07	5.09	(7)
	HDD50	143	0	0	0	0	10	32	67	25	9	0	0	0	(8)
	HDD65	1786	2	2	6	91	228	336	406	321	231	104	47	12	(9)
	CDD50	5046	760	661	664	422	263	152	133	189	243	405	513	641	(10)
	CDD65	1214	297	243	204	64	16	6	7	20	15	44	110	188	(11)
	CDH74	10034	2825	1994	1508	446	93	22	35	150	118	350	887	1606	(12)
	CDH80	3348	1131	703	464	115	16	0	3	32	34	84	253	513	(13)
(14) Wind	WSAvg	5.1	5.7	5.3	5.0	3.8	3.9	4.2	4.5	5.7	5.8	5.5	6.0	5.8	(14)
(15) Precipitation	PrecAvg	52.0	3.2	5.7	4.1	5.7	4.5	4.2	4.1	3.5	4.3	4.8	4.1	3.7	(15)
	PrecMax	80.9	7.6	18.5	12.3	16.5	13.9	9.2	13.0	8.3	11.4	10.2	14.7	11.7	(16)
	PrecMin	34.3	0.5	1.1	0.4	0.0	0.2	0.3	0.6	0.7	1.7	0.3	0.6	1.1	(17)
	PrecStd	10.7	1.8	4.0	3.2	4.1	3.3	2.2	3.4	2.0	2.4	2.4	2.9	2.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.7	95.4	93.4	88.2	82.1	77.7	78.8	83.8	84.9	87.1	90.6	92.7	(19)
		MCWB	75.2	75.0	73.8	72.6	70.7	68.2	67.2	67.6	71.0	72.9	73.0	70.7	(20)
	2%	DB	92.9	91.6	88.3	82.8	75.6	70.5	72.3	78.0	76.5	81.7	86.6	88.9	(21)
		MCWB	72.9	73.7	71.6	68.6	65.6	65.2	64.0	65.9	65.4	69.3	70.6	70.6	(22)
	5%	DB	89.7	87.6	84.8	78.9	71.8	66.4	67.8	72.6	72.3	77.3	82.8	85.4	(23)
		MCWB	72.3	72.5	71.2	67.4	63.8	62.3	61.7	63.4	62.6	66.6	69.0	69.8	(24)
	10%	DB	86.3	84.2	81.6	75.4	68.4	63.8	63.4	67.7	68.7	73.9	79.3	82.5	(25)
		MCWB	71.9	71.2	70.0	66.6	62.5	60.5	58.2	61.1	60.6	64.8	67.7	68.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.8	78.8	79.1	74.4	71.7	69.3	69.1	69.5	70.8	75.0	75.6	76.0	(27)
		MCDB	89.0	90.9	88.6	83.6	79.4	75.3	75.7	77.7	80.9	84.7	85.3	85.1	(28)
	2%	WB	76.1	76.7	76.0	71.9	67.5	65.9	65.1	66.5	67.2	71.3	73.2	74.0	(29)
		MCDB	86.8	84.8	82.4	79.3	72.7	69.8	71.8	76.1	75.1	78.5	82.7	82.6	(30)
	5%	WB	74.5	74.9	74.0	70.3	65.6	63.7	62.1	64.3	64.4	68.6	71.2	72.5	(31)
		MCDB	85.2	82.1	79.3	75.6	69.5	65.8	66.2	70.6	69.2	75.1	79.3	80.4	(32)
	10%	WB	73.3	73.2	72.1	68.1	63.9	61.3	59.7	61.8	62.2	66.5	69.2	70.9	(33)
		MCDB	83.5	79.6	77.7	72.4	67.0	63.2	62.6	67.0	66.2	71.4	75.8	78.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.6	20.3	20.0	21.8	19.7	16.7	18.5	18.8	18.3	19.8	20.5	21.7	(35)
		MCDBR	27.5	25.1	25.3	27.6	25.5	19.4	22.9	26.4	24.6	25.0	25.7	26.8	(36)
	5% WB	MCWBR	10.5	9.1	10.3	13.7	14.6	12.1	13.2	13.7	13.2	13.2	11.4	10.6	(37)
		MCWBR	23.0	19.0	18.0	18.8	18.9	15.3	20.0	23.3	19.6	20.6	20.3	20.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.416	0.403	0.398	0.381	0.361	0.369	0.378	0.466	0.487	0.434	0.405	0.407	(40)
		taud	2.322	2.377	2.371	2.372	2.404	2.377	2.314	2.014	1.979	2.187	2.299	2.322	(41)
	Ebn at Noon		293	291	280	267	255	243	246	233	248	278	294	297	(42)
		Edh at Noon	43	40	37	34	29	28	31	47	55	48	44	43	(43)
(44) All-Sky Solar Radiation	RadAvg		2199	1926	1624	1232	881	745	806	1015	1314	1688	2115	2242	(44)
	RadStd		177	142	139	144	78	70	69	102	119	188	226	158	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page