

TREINTA Y TRES, Uruguay

WMO: 865000

Lat: 33.217S

Lon: 54.383W

Elev: 151

StdP: 14.62

Time Zone: -3.00 (W03)

Period: 90-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.8	35.3	29.6	23.7	38.4	31.8	26.3	39.6	23.3	52.7	18.8	52.8	0.4	290	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.3	91.8	72.9	89.1	72.1	86.2	71.9	76.4	85.9	75.3	83.9	74.1	81.6	6.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.0	127.4	79.9	72.8	122.4	78.8	71.8	118.1	77.9	40.0	86.0	38.9	84.2	37.8	81.8	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	14.4	12.2	DB	28.0	99.5	1.5	3.0	26.9	101.7	26.1	103.4	25.2	105.1	24.1	107.2	(4)
(5)			WB	28.1	79.4	2.4	2.0	26.4	80.8	25.0	82.0	23.7	83.1	22.0	84.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	74.6	72.8	70.3	64.8	58.6	52.9	51.8	55.3	57.1	63.1	67.1	71.5	(6)	
	DBStd	9.86	5.22	5.17	5.20	5.61	6.63	6.69	7.16	7.69	6.58	6.02	5.61	5.14	(7)	
	HDD50	151	0	0	0	0	6	43	62	28	12	0	0	0	(8)	
	HDD65	1822	3	5	16	70	220	367	417	317	252	108	39	8	(9)	
	CDD50	4997	761	638	631	444	272	129	117	194	224	406	514	667	(10)	
	CDD65	1190	299	223	181	64	21	3	7	17	14	49	103	209	(11)	
	CDH74	9000	2634	1602	1140	332	84	9	37	151	113	350	833	1715	(12)	
	CDH80	2928	1018	534	282	77	7	0	4	39	29	100	242	596	(13)	
(14) Wind	WSAvg	4.8	5.3	5.0	4.1	4.5	3.6	4.0	4.2	4.5	5.3	5.4	5.8	5.6	(14)	
(15) Precipitation	PrecAvg	52.6	3.8	4.7	4.0	4.9	4.8	5.0	4.8	4.3	4.6	4.8	4.2	4.0	(15)	
	PrecMax	74.8	13.1	21.1	13.5	14.9	14.6	15.0	12.5	10.8	9.8	11.9	13.8	13.6	(16)	
	PrecMin	31.2	0.0	0.2	0.2	0.4	0.2	0.1	0.8	1.0	1.1	0.8	0.5	0.6	(17)	
	PrecStd	12.0	2.8	4.7	2.8	3.5	3.9	3.5	3.0	2.4	2.6	2.5	3.4	2.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.9	94.0	89.6	87.9	80.5	75.3	79.2	84.8	83.9	88.4	91.6	96.3	(19)	
		MCWB	74.6	73.5	72.5	75.4	69.6	64.2	66.1	68.4	70.0	72.4	72.6	75.9	(20)	
	2%	DB	92.1	89.7	85.8	81.1	76.2	70.1	71.0	77.7	76.4	82.4	86.2	89.8	(21)	
		MCWB	72.4	72.1	71.9	69.7	68.2	63.3	63.1	66.1	66.1	69.5	69.9	71.9	(22)	
	5%	DB	88.9	85.9	83.4	77.3	72.4	66.2	66.4	72.0	71.4	77.4	82.0	86.2	(23)	
		MCWB	72.3	72.5	70.9	68.1	65.5	61.2	60.4	63.2	62.6	67.1	68.0	71.6	(24)	
	10%	DB	85.6	82.8	80.6	74.2	68.7	63.0	62.2	66.9	67.7	73.6	78.7	82.5	(25)	
		MCWB	71.7	71.2	70.0	66.6	63.1	59.3	57.8	60.0	59.7	65.1	67.4	69.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.4	77.9	76.4	75.5	72.3	66.3	67.1	70.8	71.5	74.8	76.8	76.6	(27)	
		MCDB	89.4	87.4	83.3	86.3	77.4	70.8	75.7	81.8	81.5	84.4	87.6	88.6	(28)	
	2%	WB	76.2	76.3	74.9	72.5	68.8	64.5	64.2	67.2	67.1	71.5	72.4	75.0	(29)	
		MCDB	86.0	84.6	80.7	78.4	75.2	68.4	70.7	76.3	74.8	78.9	80.7	85.7	(30)	
	5%	WB	74.8	74.8	73.3	70.4	66.7	62.7	61.6	64.4	64.0	68.8	70.4	73.5	(31)	
		MCDB	83.7	81.6	78.7	74.9	71.0	66.2	65.3	70.6	68.8	75.2	77.6	81.4	(32)	
	10%	WB	73.4	73.3	71.9	68.6	64.8	60.1	59.1	61.4	61.8	66.8	68.6	72.1	(33)	
		MCDB	81.2	78.8	77.7	72.1	67.9	62.5	61.6	65.3	65.9	72.2	75.7	79.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	21.3	18.2	18.8	17.5	17.7	16.6	16.4	18.1	18.0	18.3	19.4	20.0	(35)	
		MCDBR	25.1	23.0	22.0	22.0	20.1	19.6	21.4	24.6	22.7	23.4	25.3	25.8	(36)	
	5% WB	MCWBR	8.7	8.5	9.1	11.6	11.6	11.9	12.8	12.7	12.3	11.7	11.4	10.8	(37)	
		MCWBR	20.0	17.3	16.5	17.2	17.3	15.3	17.2	21.6	19.1	19.5	20.5	20.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.411	0.409	0.391	0.373	0.361	0.369	0.371	0.457	0.474	0.428	0.403	0.403	(40)	
		taud	2.338	2.360	2.394	2.396	2.406	2.372	2.333	2.035	2.015	2.201	2.303	2.331	(41)	
	Ebn at Noon	Ebn at Noon	294	288	282	268	254	241	246	235	251	279	295	298	(42)	
		Edh at Noon	43	40	36	32	29	28	30	46	52	47	44	43	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2225	1910	1627	1227	870	738	782	994	1330	1716	2136	2266	(44)	
	RadStd	RadStd	176	163	142	141	69	71	69	103	120	176	209	156	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page