

FLORIDA, Uruguay

WMO: 865450

Lat: 34.083S

Lon: 56.233W

Elev: 223

StdP: 14.58

Time Zone: -3.00 (W03)

Period: 95-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.1	32.7	27.2	21.3	34.6	29.6	23.9	36.3	37.6	51.3	30.6	52.9	1.2	40	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	93.5	72.7	90.3	71.8	87.6	71.1	76.8	86.4	75.2	85.2	73.6	82.9	7.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.1	128.3	82.2	72.3	120.6	80.2	70.8	114.3	78.0	40.5	85.8	38.9	84.6	37.4	82.6	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.3	21.2	18.6	DB	25.3	100.9	2.5	4.5	23.5	104.2	22.1	106.8	20.7	109.3	18.8	112.6
			WB	25.2	80.4	3.1	3.6	22.9	82.9	21.1	85.0	19.3	87.0	17.0	89.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	74.1	72.7	69.4	62.3	56.3	50.8	49.7	52.8	55.2	60.8	65.8	70.3	(6)
	DBStd	10.43	5.02	5.05	5.37	6.68	6.70	6.55	7.29	7.75	6.27	5.69	6.39	5.41	(7)
	HDD50	246	0	0	0	1	15	63	95	52	19	1	0	0	(8)
	HDD65	2275	2	5	22	129	280	430	480	389	301	155	66	16	(9)
	CDD50	4489	748	635	601	370	211	88	85	139	175	335	472	630	(10)
	CDD65	1042	285	220	158	48	10	4	5	11	7	24	89	181	(11)
	CDH74	9851	3133	1886	1206	361	52	8	21	88	53	237	962	1844	(12)
	CDH80	3570	1383	701	344	83	3	0	1	19	9	45	294	688	(13)
(14) Wind	WSAvg	7.0	7.3	7.1	6.0	6.2	5.6	6.0	6.9	7.4	8.2	7.9	7.9	7.7	(14)
(15) Precipitation	PrecAvg	49.6	4.1	4.4	5.0	5.0	3.6	3.8	3.6	3.3	4.1	4.7	4.3	3.8	(15)
	PrecMax	70.2	11.6	13.0	18.6	15.9	11.3	10.3	7.6	8.5	13.3	10.7	10.6	12.4	(16)
	PrecMin	27.6	0.1	0.0	1.3	0.7	0.5	0.9	0.4	0.4	0.6	0.9	1.1	0.6	(17)
	PrecStd	10.8	3.2	2.8	4.4	3.4	2.3	2.4	2.0	2.0	2.8	2.9	2.2	3.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.1	96.6	90.0	87.2	79.0	74.0	77.3	83.1	80.6	84.9	91.8	95.0	(19)
		MCWB	74.8	73.4	74.2	73.2	68.8	67.1	66.7	69.6	68.5	70.3	71.1	70.1	(20)
	2%	DB	94.6	91.3	86.4	81.8	74.2	68.2	69.4	75.4	74.4	79.8	87.2	91.3	(21)
		MCWB	73.2	72.8	72.6	70.0	65.3	64.4	62.8	65.7	64.0	67.9	69.8	69.8	(22)
	5%	DB	90.8	87.8	84.0	78.0	70.5	64.7	64.7	70.1	70.8	76.0	83.5	87.3	(23)
		MCWB	72.1	72.4	71.8	67.7	63.7	60.2	59.3	62.4	61.8	64.6	67.9	69.2	(24)
	10%	DB	87.8	84.5	81.0	74.3	67.2	61.5	60.8	65.6	67.3	72.8	79.9	83.8	(25)
		MCWB	71.1	71.0	70.5	66.3	62.3	57.3	55.9	59.3	59.5	62.8	66.5	68.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	80.4	78.0	74.7	70.1	68.3	68.6	70.2	69.6	74.1	75.4	75.2	(27)
		MCDB	90.3	89.6	86.8	83.9	76.8	71.8	74.5	80.3	77.4	81.9	84.2	84.0	(28)
	2%	WB	76.5	76.8	75.5	71.9	67.3	64.9	63.9	66.8	66.5	69.8	72.6	72.9	(29)
		MCDB	87.6	86.2	83.6	79.9	72.2	67.4	68.9	74.6	72.3	76.5	83.0	83.4	(30)
	5%	WB	74.9	74.8	73.4	69.8	65.2	61.4	60.5	63.5	63.5	66.8	70.2	71.6	(31)
		MCDB	86.8	83.4	80.5	75.3	68.7	64.3	63.4	68.6	68.3	73.0	78.9	82.5	(32)
	10%	WB	73.1	72.8	71.6	67.6	63.2	58.3	57.1	60.2	61.1	64.6	68.2	70.2	(33)
		MCDB	83.7	80.5	78.1	72.3	66.4	60.6	59.7	64.2	65.7	70.1	76.2	80.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	25.2	21.4	20.6	21.1	19.8	18.2	18.4	19.7	19.9	21.6	23.1	23.3	(35)
		MCDBR	30.7	27.0	24.4	25.6	23.8	20.6	21.2	24.8	25.4	26.8	28.4	30.1	(36)
		MCWBR	12.1	11.5	12.1	13.7	15.0	14.3	13.0	14.5	15.2	14.9	12.8	11.3	(37)
	5% WB	MCDBR	24.7	22.9	21.3	20.9	19.4	16.5	17.0	22.6	20.2	21.6	22.9	22.9	(38)
		MCWBR	11.7	12.2	11.9	12.8	13.2	12.9	11.3	14.1	13.4	13.7	12.3	10.4	(39)
(40) Clear-Sky Solar Irradiance	taub		0.406	0.403	0.381	0.370	0.361	0.368	0.356	0.446	0.463	0.422	0.392	0.411	(40)
	taud		2.338	2.369	2.407	2.387	2.386	2.353	2.366	2.055	2.029	2.206	2.326	2.294	(41)
	Ebn at Noon		296	290	284	268	252	239	250	237	253	280	298	295	(42)
	Edh at Noon		43	40	36	32	29	28	29	44	51	46	43	45	(43)
(44) All-Sky Solar Radiation	RadAvg		2317	1980	1669	1224	856	725	761	1006	1375	1780	2181	2371	(44)
	RadStd		161	186	150	141	62	68	79	102	108	164	184	149	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+0.86	+1.26	N/A	+1.24	+1.13	N/A	N/A	N/A	N/A	+225	+121

Nomenclature: See separate page