

MONTEVIDEO PRADO, Uruguay

WMO: 865850

Lat: 34.8607S

Lon: 56.2077W

Elev: 56

StdP: 14.67

Time Zone: -3.00 (W03)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.4	39.8	30.6	24.8	44.7	32.7	27.3	45.4	26.2	49.3	20.7	52.0	2.1	40	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	89.1	72.8	86.4	71.8	84.1	71.2	76.1	85.3	74.5	82.6	73.2	80.5	8.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.4	124.3	80.3	72.0	118.6	79.2	70.7	113.5	77.8	39.6	85.3	38.2	82.7	36.9	80.7	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.9	18.6	16.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.5	74.0	72.5	70.1	63.1	57.9	52.7	52.1	53.9	55.8	61.1	66.5	70.7
	DBStd	9.48	4.96	4.49	4.69	4.80	5.56	5.59	6.14	6.65	5.95	5.67	5.50	5.17
	HDD50	122	0	0	0	0	5	33	44	28	11	1	0	0
	HDD65	1952	1	2	10	92	230	369	404	354	285	150	44	11
	CDD50	4680	746	631	624	392	248	115	110	150	185	344	494	641
	CDD65	1035	281	213	169	34	8	1	5	10	9	29	89	187
	CDH74	6554	2189	1323	784	101	23	2	22	59	55	165	559	1272
	CDH80	1763	722	331	145	5	2	0	2	14	10	27	143	362
(14) Wind	WSAvg	7.1	7.5	7.0	6.9	6.1	6.6	6.2	6.9	7.4	7.6	7.3	8.0	7.7
(15) Precipitation	PrecAvg	42.1	2.6	3.4	4.4	3.9	3.6	3.5	3.4	3.2	3.3	4.5	3.5	3.5
	PrecMax	64.0	8.2	7.1	21.2	12.0	11.3	8.7	7.1	12.6	8.2	10.4	8.5	11.7
	PrecMin	27.8	0.1	0.5	0.3	0.3	0.2	0.0	0.7	0.2	0.6	0.5	0.7	0.3
	PrecStd	8.9	2.2	2.0	4.3	2.5	2.6	2.1	1.7	2.7	1.8	2.6	2.2	2.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.0	91.7	87.8	80.1	77.0	71.1	76.6	80.8	80.8	83.0	88.7	90.5
		MCWB	75.5	73.6	75.3	69.1	67.2	64.6	66.3	69.8	68.7	67.3	70.5	71.3
	2%	DB	90.2	86.8	83.8	76.6	71.9	67.2	69.3	72.6	74.3	78.5	84.2	86.9
		MCWB	73.4	72.6	72.0	66.4	64.4	62.7	61.4	64.9	64.3	65.4	69.3	71.4
	5%	DB	87.0	84.0	80.9	73.7	68.8	64.8	64.4	67.9	69.7	74.2	80.0	84.1
		MCWB	72.5	71.9	70.8	65.6	62.9	60.1	58.7	60.6	60.2	63.6	67.1	70.4
	10%	DB	84.1	81.3	78.2	71.0	66.0	61.9	60.8	63.7	66.0	70.8	76.5	80.9
		MCWB	71.7	71.1	69.8	64.7	61.3	57.6	56.8	58.0	58.9	62.4	65.8	69.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.6	77.1	77.2	71.6	69.1	66.7	66.7	70.0	70.7	71.6	74.4	76.2
		MCDB	88.0	87.2	86.0	77.3	75.5	69.6	75.8	80.3	76.7	79.1	85.2	85.7
	2%	WB	76.4	75.0	74.6	69.5	66.5	64.5	63.0	65.6	65.5	68.0	71.1	74.0
		MCDB	86.2	83.1	80.6	73.7	70.7	66.3	67.7	71.7	72.1	74.6	78.9	82.6
	5%	WB	74.7	73.5	72.8	67.7	64.3	61.5	60.2	62.5	62.4	66.0	69.1	72.2
		MCDB	83.3	80.9	78.1	70.9	66.8	63.8	63.3	66.9	67.8	71.0	77.0	80.4
	10%	WB	73.2	72.3	71.1	66.0	62.4	58.4	57.1	58.9	59.6	63.7	67.4	70.7
		MCDB	80.7	79.2	76.2	69.7	65.3	60.8	60.1	62.4	64.3	69.3	74.2	78.3
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	13.8	12.2	12.3	12.3	12.6	11.9	12.4	13.0	13.5	14.8	14.8
		MCDBR	20.7	18.9	17.2	17.2	16.4	15.6	18.4	19.0	20.5	20.5	21.1	21.1
		MCWBR	9.3	8.8	8.2	9.0	9.8	10.4	11.4	11.6	11.1	11.2	10.4	9.8
	5% WB	MCDBR	16.6	14.8	13.0	12.6	11.7	11.5	14.8	17.3	16.6	15.2	16.3	16.2
		MCWBR	8.9	8.4	7.2	7.8	8.7	9.8	10.9	11.9	10.7	10.3	10.2	8.5
(40) Clear-Sky Solar Irradiance	taub		0.396	0.392	0.370	0.366	0.359	0.362	0.363	0.443	0.456	0.401	0.385	0.386
	taud		2.421	2.453	2.500	2.460	2.444	2.423	2.392	2.110	2.093	2.324	2.402	2.424
	Ebn at Noon		298	292	287	269	251	240	246	237	255	286	300	303
	Edh at Noon		39	36	32	30	27	26	28	42	48	41	40	39
(44) All-Sky Solar Radiation	RadAvg		2324	1998	1668	1210	838	704	734	980	1364	1779	2171	2393
	RadStd		153	184	147	129	61	66	75	98	99	157	170	137

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.86	+1.26	N/A	+1.24	+1.13	N/A	N/A	N/A	N/A	+225	+121

Nomenclature: See separate page