

MONTEVIDEO PRADO, Uruguay

WMO: 865850

Lat: 34.8607S

Lon: 56.2077W

Elev: 17

StdP: 101.12

Time Zone: -3.00 (W03)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.0	4.3	-0.8	3.5	7.1	0.4	3.9	7.4	11.7	9.6	9.3	11.1	1.0	40	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.3	31.7	22.7	30.2	22.1	28.9	21.8	24.5	29.6	23.6	28.1	22.9	26.9	3.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	17.8	26.9	22.2	16.9	26.2	21.5	16.2	25.4	74.3	29.6	70.9	28.2	68.0	27.0	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.3	7.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	23.4	22.5	21.2	17.3	14.4	11.5	11.2	12.2	13.2	16.2	19.1	21.5		
	DBStd	5.27	2.75	2.49	2.61	2.66	3.09	3.11	3.41	3.70	3.30	3.15	3.05	2.87		
	HDD10.0	68	0	0	0	0	3	18	24	16	6	1	0	0		
	HDD18.3	1084	1	1	6	51	128	205	224	197	158	83	24	6		
	CDD10.0	2600	414	351	347	218	138	64	61	83	103	191	274	356		
	CDD18.3	575	156	118	94	19	4	1	3	6	5	16	49	104		
	CDH23.3	3641	1216	735	436	56	13	1	12	33	31	92	311	707		
(14) Wind	WSAvg	3.2	3.3	3.1	3.1	2.7	2.9	2.8	3.1	3.3	3.4	3.3	3.6	3.4		
	PrecAvg	1069	67	86	111	98	92	88	87	81	84	114	89	90		
	PrecMax	1625	208	181	539	306	287	220	180	319	208	265	217	297		
	PrecMin	705	3	12	8	7	4	1	19	6	16	12	18	7		
	PrecStd	226	55	50	108	64	67	53	44	68	46	65	56	70		
	DB	35.6	33.2	31.0	26.7	25.0	21.7	24.8	27.1	27.1	28.3	31.5	32.5			
	MCWB	24.2	23.1	24.1	20.6	19.5	18.1	19.0	21.0	20.4	19.6	21.4	21.8			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	32.3	30.4	28.8	24.8	22.2	19.6	20.7	22.6	23.5	25.8	29.0	30.5			
	2% MCWB	23.0	22.6	22.2	19.1	18.0	17.1	16.3	18.3	18.0	18.5	20.7	21.9			
	5% DB	30.6	28.9	27.2	23.1	20.4	18.2	18.0	20.0	20.9	23.5	26.6	28.9			
	5% MCWB	22.5	22.2	21.6	18.6	17.1	15.6	14.8	15.9	15.7	17.5	19.5	21.3			
	10% DB	28.9	27.4	25.7	21.7	18.9	16.6	16.0	17.6	18.9	21.5	24.7	27.2			
	10% MCWB	22.1	21.7	21.0	18.2	16.3	14.2	13.8	14.5	15.0	16.9	18.8	20.7			
	WB	25.9	25.0	25.1	22.0	20.6	19.3	19.3	21.1	21.5	22.0	23.5	24.5			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	31.1	30.7	30.0	25.2	24.2	20.9	24.3	26.8	24.8	26.2	29.5	29.8			
	2% WB	24.7	23.9	23.7	20.9	19.2	18.1	17.2	18.7	18.6	20.0	21.7	23.3			
	2% MCDB	30.1	28.4	27.0	23.2	21.5	19.1	19.8	22.1	22.3	23.6	26.1	28.1			
	5% WB	23.7	23.1	22.7	19.8	17.9	16.4	15.7	16.9	16.9	18.9	20.6	22.4			
	5% MCDB	28.5	27.1	25.6	21.6	19.3	17.7	17.4	19.4	19.9	21.6	25.0	26.9			
	10% WB	22.9	22.4	21.7	18.9	16.9	14.7	13.9	14.9	15.3	17.6	19.7	21.5			
	10% MCDB	27.1	26.2	24.6	21.0	18.5	16.0	15.6	16.9	17.9	20.7	23.4	25.7			
(35) Mean Daily Temperature Range	MDBR	8.3	7.7	6.8	6.8	6.8	7.0	6.6	6.9	7.2	7.5	8.2	8.2			
	5% DB MCDBR	11.5	10.5	9.5	9.6	9.1	8.7	10.2	10.5	11.4	11.4	11.7	11.7			
	5% DB MCWBR	5.2	4.9	4.5	5.0	5.4	5.8	6.4	6.4	6.2	6.2	5.8	5.5			
	5% WB MCDBR	9.2	8.2	7.2	7.0	6.5	6.4	8.2	9.6	9.2	8.4	9.1	9.0			
	5% WB MCWBR	4.9	4.7	4.0	4.3	4.9	5.4	6.1	6.6	6.0	5.7	5.7	4.7			
(40) Clear-Sky Solar Irradiance	taub	0.396	0.392	0.370	0.366	0.359	0.362	0.363	0.443	0.456	0.401	0.385	0.386			
	taud	2.421	2.453	2.500	2.460	2.444	2.423	2.392	2.110	2.093	2.324	2.402	2.424			
	Ebn at Noon	941	922	906	848	792	757	777	747	803	903	945	954			
	Edh at Noon	123	115	102	94	85	81	88	132	151	129	125	124			
(44) All-Sky Solar Radiation	RadAvg	7.33	6.30	5.26	3.82	2.64	2.22	2.31	3.09	4.30	5.61	6.84	7.54			
	RadStd	0.48	0.58	0.46	0.41	0.19	0.21	0.23	0.31	0.31	0.49	0.54	0.43			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.48	+0.70	N/A	+0.69	+0.63	N/A	N/A	N/A	+125	+67

Nomenclature: See separate page