

TARTAGAL, Argentina

WMO: 870220

Lat: 22.6167S

Lon: 63.7967W

Elev: 1476

StdP: 13.93

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.4	43.7	24.0	19.2	58.0	28.4	23.6	59.5	22.8	70.9	20.2	68.0	1.4	270	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.3	100.6	72.4	97.8	72.6	95.2	72.7	78.9	89.7	77.9	88.7	77.0	87.8	11.0	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.2	144.4	84.2	75.1	139.2	83.1	74.1	134.6	82.0	43.8	89.2	42.8	89.3	41.8	87.9	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	17.8	15.1	DB	34.9	106.0	3.1	2.3	32.7	107.7	30.8	109.0	29.1	110.3	26.8	112.0	(4)
(5)			WB	32.8	81.5	2.9	1.6	30.7	82.6	29.1	83.6	27.5	84.4	25.4	85.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	71.5	79.7	78.4	75.1	70.4	64.8	61.0	60.3	65.3	70.6	76.5	77.9	79.0	(6)
(7)		DBStd	9.55	4.91	4.95	5.34	6.26	6.38	6.43	7.36	8.45	8.24	7.38	6.52	5.73	(7)
(8)		HDD50	13	0	0	0	0	1	3	8	1	0	0	0	0	(8)
(9)		HDD65	596	0	0	3	22	84	153	183	104	38	7	2	0	(9)
(10)		CDD50	7874	920	795	777	611	459	334	327	475	618	822	837	899	(10)
(11)		CDD65	2982	455	375	315	184	77	34	37	113	206	363	389	434	(11)
(12)		CDH74	28446	4588	3338	2258	1112	383	171	337	1198	2260	4018	4236	4547	(12)
(13)		CDH80	12967	2159	1437	819	343	72	25	81	500	1064	2069	2163	2235	(13)
(14)	Wind	WSAvg	4.5	4.3	4.0	3.9	3.5	3.3	3.6	4.1	5.0	5.6	5.8	5.6	4.9	(14)
(15)	Precipitation	PrecAvg	39.1	7.4	7.6	6.4	2.5	1.0	0.4	0.2	0.7	1.9	4.4	6.6		(15)
(16)		PrecMax	59.1	15.2	15.4	15.4	7.5	3.7	1.6	0.7	0.9	2.4	5.8	7.8	15.5	(16)
(17)		PrecMin	25.3	1.9	2.2	1.5	0.3	0.0	0.0	0.0	0.0	0.0	0.3	0.7	1.5	(17)
(18)		PrecStd	7.9	3.1	3.0	3.5	1.6	0.8	0.4	0.2	0.3	0.7	1.1	1.8	3.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.8	99.1	94.5	90.4	86.1	83.0	86.9	95.9	100.7	104.4	103.8	102.1	(19)
(20)			MCWB	73.5	75.4	75.5	73.0	72.2	68.6	67.0	68.0	69.1	70.9	72.9	73.4	(20)
(21)		2%	DB	96.9	94.8	91.1	87.6	81.7	78.7	82.0	90.9	95.8	99.5	99.3	98.3	(21)
(22)			MCWB	74.1	75.6	76.3	73.6	70.3	66.9	66.5	67.6	68.1	71.3	72.8	73.8	(22)
(23)		5%	DB	94.0	91.7	88.1	84.6	78.5	74.8	77.7	86.0	91.5	95.5	95.6	94.8	(23)
(24)			MCWB	74.9	76.0	75.8	73.2	68.4	64.8	63.3	65.3	67.0	71.0	72.1	74.4	(24)
(25)		10%	DB	91.0	88.7	84.7	81.0	74.9	71.4	73.4	81.3	86.8	91.3	91.6	91.4	(25)
(26)			MCWB	74.6	75.4	74.4	72.1	67.1	63.0	60.8	63.0	65.2	69.8	71.4	73.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	80.7	79.3	77.8	74.1	71.1	70.2	71.7	73.6	77.0	78.5	79.2	(27)
(28)			MCDWB	90.4	91.4	88.5	86.1	82.4	79.0	82.1	89.0	92.2	96.3	94.7	91.2	(28)
(29)		2%	WB	78.3	78.8	77.9	76.0	72.3	68.9	67.6	69.0	71.0	74.9	76.5	77.8	(29)
(30)			MCDWB	89.2	88.7	86.9	83.8	79.3	75.9	79.6	86.3	89.0	91.8	91.2	90.0	(30)
(31)		5%	WB	77.3	77.6	76.7	74.6	70.4	67.0	65.2	66.9	69.0	72.9	75.0	76.5	(31)
(32)			MCDWB	88.3	87.3	85.1	81.6	75.9	72.7	74.7	83.2	85.7	89.2	88.4	88.7	(32)
(33)		10%	WB	76.2	76.3	75.4	73.1	68.6	64.9	63.0	64.7	67.1	71.3	73.5	75.3	(33)
(34)			MCDWB	86.7	85.5	82.8	78.9	73.2	69.5	71.1	79.2	83.0	86.4	86.3	87.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.3	16.7	14.5	13.8	14.1	15.6	19.8	22.6	22.5	20.8	20.2	18.7	(35)
(36)			MCDBR	23.9	22.4	19.9	19.7	19.0	20.6	26.5	29.6	29.9	28.2	27.7	25.4	(36)
(37)			MCWBR	7.3	7.9	7.8	8.6	9.0	10.5	12.8	12.0	11.5	9.1	8.7	7.7	(37)
(38)		5% WB	MCDWB	19.5	18.7	17.3	16.4	15.2	17.5	23.6	26.7	24.1	23.6	22.7	20.8	(38)
(39)			MCWBR	8.0	8.4	8.2	8.1	7.9	9.4	12.2	11.5	10.2	9.3	8.7	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.413	0.406	0.401	0.385	0.368	0.335	0.343	0.414	0.494	0.485	0.425	0.419	(40)	
(41)		taud	2.390	2.420	2.437	2.453	2.431	2.509	2.457	2.235	2.024	2.118	2.315	2.356	(41)	
(42)		Ebn at Noon	296	294	287	278	269	274	275	264	255	268	291	294	(42)	
(43)		Edh at Noon	41	39	37	33	31	28	30	41	55	52	44	43	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1945	1787	1492	1214	1010	954	1157	1438	1627	1695	1846	1877	(44)	
(45)		RadStd	157	105	147	135	127	99	100	112	153	153	186	152	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page