

TARTAGAL, Argentina

WMO: 870220

Lat: 22.6167S

Lon: 63.7967W

Elev: 450

StdP: 96.03

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	6.5	-4.4	2.7	14.5	-2.0	3.4	15.3	10.2	21.6	9.0	20.0	0.6	270	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.2	38.1	22.4	36.5	22.6	35.1	22.6	26.1	32.1	25.5	31.5	25.0	31.0	4.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	20.6	29.0	23.9	19.9	28.4	23.4	19.2	27.8	84.0	31.8	81.6	31.8	79.3	31.1	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.0	6.8	1.6	41.1	1.7	1.3	0.4	42.0	-0.6	42.8	-1.6	43.5	-2.9	44.4		
			0.4	27.5	1.6	0.9	-0.7	28.1	-1.6	28.6	-2.5	29.1	-3.7	29.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.0	26.5	25.8	23.9	21.3	18.2	16.1	15.7	18.5	21.4	24.7	25.5	26.1
	DBStd	5.31	2.73	2.75	2.97	3.48	3.54	3.57	4.09	4.70	4.58	4.10	3.62	3.18
	HDD10.0	7	0	0	0	0	1	2	4	1	0	0	0	0
	HDD18.3	331	0	0	2	12	47	85	102	58	21	4	1	0
	CDD10.0	4374	511	442	432	339	255	186	182	264	343	457	465	499
	CDD18.3	1657	253	208	175	102	43	19	21	63	114	202	216	241
	CDH23.3	15803	2549	1854	1254	618	213	95	187	666	1256	2232	2353	2526
(13)	CDH26.7	7204	1199	798	455	191	40	14	45	278	591	1149	1202	1242
(14)	Wind	WSAvg	2.0	1.9	1.8	1.7	1.5	1.5	1.8	2.2	2.5	2.6	2.5	2.2
(15) Precipitation	PrecAvg	993	188	192	162	64	25	9	4	4	18	48	111	168
	PrecMax	1500	385	390	391	190	94	40	17	23	61	148	199	394
	PrecMin	642	47	55	37	8	1	0	0	0	8	17	37	37
	PrecStd	200	78	75	88	41	20	9	5	7	18	28	45	91
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	37.3	34.7	32.4	30.1	28.4	30.5	35.5	38.1	40.2	39.9	38.9
		MCWB	23.1	24.1	24.2	22.8	22.4	20.3	19.5	20.0	20.6	21.6	22.7	23.0
	2%	DB	36.1	34.9	32.9	30.9	27.6	26.0	27.8	32.7	35.5	37.5	37.4	36.8
		MCWB	23.4	24.2	24.6	23.1	21.3	19.4	19.2	19.8	20.0	21.8	22.6	23.2
	5%	DB	34.4	33.2	31.2	29.2	25.8	23.8	25.4	30.0	33.1	35.3	35.3	34.9
		MCWB	23.8	24.4	24.3	22.9	20.2	18.2	17.4	18.5	19.4	21.7	22.3	23.5
	10%	DB	32.8	31.5	29.3	27.2	23.8	21.9	23.0	27.4	30.4	33.0	33.1	33.0
		MCWB	23.7	24.1	23.6	22.3	19.5	17.2	16.0	17.2	18.5	21.0	21.9	23.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	27.1	26.3	25.4	23.4	21.7	21.2	22.0	23.1	25.0	25.9	26.2
		MCDB	32.5	33.0	31.4	30.1	28.0	26.1	27.8	31.7	33.4	35.7	34.8	32.9
	2%	WB	25.7	26.0	25.5	24.4	22.4	20.5	19.8	20.6	21.7	23.8	24.7	25.4
		MCDB	31.8	31.5	30.5	28.8	26.3	24.4	26.4	30.1	31.7	33.2	32.9	32.2
	5%	WB	25.1	25.3	24.9	23.6	21.3	19.4	18.5	19.4	20.6	22.7	23.9	24.7
		MCDB	31.3	30.7	29.5	27.6	24.4	22.6	23.7	28.5	29.8	31.8	31.3	31.5
	10%	WB	24.5	24.6	24.1	22.8	20.3	18.3	17.2	18.2	19.5	21.8	23.0	24.1
		MCDB	30.4	29.7	28.2	26.1	22.9	20.8	21.7	26.2	28.4	30.2	30.2	30.6
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	9.3	8.1	7.6	7.8	8.7	11.0	12.6	12.5	11.5	11.2	10.4
		MCDBR	13.3	12.4	11.1	11.0	10.6	11.5	14.7	16.5	16.6	15.7	15.4	14.1
		MCWBR	4.0	4.4	4.4	4.8	5.0	5.8	7.1	6.7	6.4	5.1	4.8	4.3
	5% WB	MCDBR	10.9	10.4	9.6	9.1	8.4	9.7	13.1	14.8	13.4	13.1	12.6	11.5
		MCWBR	4.4	4.7	4.5	4.5	4.4	5.2	6.8	6.4	5.6	5.1	4.8	4.5
(40) Clear-Sky Solar Irradiance	taub		0.413	0.406	0.401	0.385	0.368	0.335	0.343	0.414	0.494	0.485	0.425	0.419
	taud		2.390	2.420	2.437	2.453	2.431	2.509	2.457	2.235	2.024	2.118	2.315	2.356
	Ebn at Noon		933	926	904	876	849	863	867	832	805	844	916	928
	Edh at Noon		129	123	116	105	99	88	95	129	172	164	138	134
(44) All-Sky Solar Radiation	RadAvg		6.13	5.63	4.70	3.83	3.18	3.01	3.65	4.53	5.13	5.34	5.82	5.92
	RadStd		0.49	0.33	0.46	0.43	0.40	0.31	0.31	0.35	0.48	0.48	0.59	0.48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page