

JUJUY, Argentina

WMO: 870460

Lat: 24.3839S

Lon: 65.0956W

Elev: 2969

StdP: 13.19

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.5	38.6	23.0	19.3	48.2	26.4	22.6	49.8	21.2	65.3	18.5	60.8	5.6	320	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.7	95.7	69.5	93.1	69.3	90.6	69.2	75.2	86.8	74.0	85.1	72.9	83.5	9.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.9	132.0	79.9	71.1	128.1	79.0	70.0	123.2	77.6	41.0	86.9	39.8	84.8	38.8	83.7	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.3	17.0	14.0	DB	29.8	102.4	3.8	2.3	27.1	104.1	24.9	105.5	22.8	106.8	20.0	108.4
			WB	28.1	78.3	3.3	2.4	25.7	80.0	23.8	81.4	21.9	82.7	19.5	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	75.9	74.1	71.3	66.4	60.5	56.4	55.8	60.6	65.6	71.6	73.9	75.6	(6)
	DBStd	9.52	4.37	4.63	4.66	5.93	6.28	6.24	7.19	8.12	8.24	6.87	6.06	5.17	(7)
	HDD50	54	0	0	0	0	3	15	26	8	2	0	0	0	(8)
	HDD65	1097	1	2	8	54	166	264	296	187	91	20	6	2	(9)
	CDD50	6358	801	674	661	491	330	207	205	337	472	669	716	795	(10)
	CDD65	1923	337	256	204	95	28	5	10	51	110	224	272	331	(11)
	CDH74	17072	2794	1829	1171	532	186	96	189	736	1371	2377	2739	3052	(12)
	CDH80	6825	1140	646	320	111	25	18	43	275	579	1074	1245	1349	(13)
(14) Wind	WSAvg	5.7	5.5	5.3	4.7	4.6	4.4	4.7	5.7	6.7	7.2	7.0	6.6	6.0	(14)
(15) Precipitation	PrecAvg	31.0	6.4	6.5	5.6	1.8	0.6	0.2	0.2	0.2	0.3	1.1	2.4	5.7	(15)
	PrecMax	40.1	11.3	9.9	12.9	4.1	2.3	0.6	0.5	0.7	1.5	4.9	4.7	9.1	(16)
	PrecMin	22.0	1.5	1.8	2.0	0.2	0.1	0.0	0.0	0.0	0.1	0.1	0.6	2.4	(17)
	PrecStd	4.5	2.5	2.0	2.2	0.9	0.6	0.2	0.1	0.2	0.3	1.1	1.1	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.4	93.3	90.0	86.3	83.1	82.2	85.5	91.8	96.6	99.5	99.4	98.2	(19)
		MCWB	72.2	72.6	73.2	71.0	68.2	61.7	62.3	64.4	65.8	67.9	69.6	71.4	(20)
	2%	DB	91.9	89.8	86.2	82.9	78.8	76.6	79.0	87.5	91.4	94.8	94.4	93.9	(21)
		MCWB	72.0	72.7	72.2	69.6	66.2	62.7	61.4	63.5	65.0	68.1	69.3	70.9	(22)
	5%	DB	89.6	87.1	83.8	80.2	75.4	72.0	74.8	82.4	87.2	90.2	90.8	91.0	(23)
		MCWB	71.5	72.3	71.6	69.0	64.1	60.4	59.8	62.2	63.8	67.1	68.1	70.1	(24)
	10%	DB	86.3	84.2	80.7	76.8	71.6	68.3	69.9	77.1	82.3	86.1	87.5	87.7	(25)
		MCWB	71.2	71.5	70.2	67.6	62.5	57.7	56.8	59.6	61.6	65.5	67.0	70.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.6	76.6	75.6	74.0	70.7	66.1	65.9	68.0	69.7	72.3	74.5	75.5	(27)
		MCDB	88.4	87.6	85.3	82.8	79.5	76.6	80.0	86.1	89.7	90.0	90.7	89.0	(28)
	2%	WB	74.7	74.9	73.9	72.1	67.9	63.7	62.9	64.9	67.1	70.3	72.0	74.0	(29)
		MCDB	86.4	85.3	83.2	79.6	76.0	73.7	76.0	83.2	85.9	87.6	86.6	86.9	(30)
	5%	WB	73.5	73.5	72.5	70.5	65.5	61.6	60.5	62.7	65.1	68.8	70.6	72.6	(31)
		MCDB	84.6	83.2	80.9	77.1	72.7	70.2	72.5	80.6	82.9	85.0	84.8	85.1	(32)
	10%	WB	72.3	72.3	71.1	68.7	63.6	59.4	57.9	60.2	62.8	67.1	69.2	71.4	(33)
		MCDB	82.7	81.3	78.3	74.8	70.4	66.6	68.0	75.8	79.4	82.2	82.7	83.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.4	17.9	16.2	16.6	17.3	20.6	23.5	25.4	25.3	22.9	22.0	20.7	(35)
		MCDBR	24.4	22.7	21.2	21.6	23.2	27.5	30.8	33.6	32.3	30.6	28.1	26.8	(36)
	5% WB	MCWBR	8.7	8.8	9.5	10.5	12.5	15.5	16.6	16.1	13.6	11.7	9.8	9.0	(37)
		MCWBR	20.7	20.0	18.4	18.2	20.6	24.2	27.8	31.0	28.5	25.9	24.1	22.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.437	0.423	0.421	0.390	0.326	0.302	0.307	0.359	0.424	0.475	0.423	0.431	(40)
		taud	2.291	2.337	2.333	2.377	2.497	2.546	2.503	2.333	2.157	2.069	2.267	2.293	(41)
	Ebn at Noon		289	288	279	274	281	283	285	279	274	270	291	291	(42)
		Edh at Noon	45	42	41	36	29	26	28	36	47	55	46	45	(43)
(44) All-Sky Solar Radiation	RadAvg		1970	1828	1604	1401	1204	1155	1291	1575	1843	1962	2089	2004	(44)
	RadStd		147	130	106	92	90	71	61	93	108	116	149	129	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page