

CATARATAS DEL IGUAZU, Argentina

WMO: 870970

Lat: 25.731S

Lon: 54.479W

Elev: 886

StdP: 14.23

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.4	43.0	35.9	32.0	44.7	39.3	36.6	47.6	20.2	60.2	18.0	61.4	4.2	230	0.310

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.5	95.1	75.4	93.2	75.5	91.4	75.2	79.9	88.3	79.0	87.5	78.1	86.5	7.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	147.4	84.0	76.8	144.5	83.6	75.5	138.2	82.1	44.4	88.5	43.2	87.9	42.2	87.1	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	14.4	12.0	DB	32.8	99.2	2.8	1.8	30.7	100.5	29.1	101.5	27.5	102.5	25.5	103.8	(4)
(5)			WB	32.6	82.6	2.7	1.4	30.6	83.7	29.1	84.5	27.5	85.3	25.6	86.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.3	79.2	78.6	76.6	72.0	65.0	62.7	62.1	65.7	68.6	72.8	75.0	77.9	(6)	
	DBStd	8.41	3.07	3.34	3.83	5.93	6.19	7.29	7.86	8.00	7.47	5.28	4.34	3.77	(7)	
	HDD50	18	0	0	0	0	1	4	9	3	1	0	0	0	(8)	
	HDD65	514	0	0	0	16	78	127	147	94	47	4	1	0	(9)	
	CDD50	7800	907	802	826	661	465	384	384	491	559	708	749	864	(10)	
	CDD65	2823	442	382	362	226	78	57	57	117	156	247	300	399	(11)	
	CDH74	23665	4087	3267	2928	1580	404	273	372	999	1391	2029	2677	3658	(12)	
	CDH80	9561	1815	1413	1186	530	74	31	60	345	576	823	1104	1604	(13)	
(14) Wind	WSAvg	4.9	4.7	4.5	4.1	4.3	4.4	4.6	5.2	5.5	5.9	5.6	5.2	4.8	(14)	
(15) Precipitation	PrecAvg	71.9	6.6	5.6	4.5	5.9	6.8	6.4	4.4	4.9	5.1	7.1	7.1	5.2	(15)	
	PrecMax	122.2	18.0	14.2	10.2	14.3	16.9	13.1	17.6	14.8	15.7	10.0	23.1	11.2	(16)	
	PrecMin	47.4	0.8	0.2	0.9	0.2	0.7	1.3	0.1	0.4	0.7	3.6	0.8	0.9	(17)	
	PrecStd	21.3	4.0	3.6	2.5	4.1	5.0	3.3	4.1	4.1	3.8	1.9	5.0	3.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.4	97.1	95.2	91.6	86.0	82.7	84.5	91.0	95.4	95.8	95.3	96.9	(19)	
		MCWB	76.4	75.2	75.5	75.5	73.5	70.4	68.3	68.8	72.2	76.1	75.0	74.3	(20)	
	2%	DB	93.3	93.4	91.7	89.0	82.1	80.5	81.9	87.7	91.5	91.7	91.9	93.5	(21)	
		MCWB	76.4	76.3	75.4	75.4	71.9	69.8	68.4	68.9	71.4	74.9	74.5	75.6	(22)	
	5%	DB	91.4	91.0	89.4	86.1	78.7	77.3	78.7	84.2	86.8	88.2	89.5	91.1	(23)	
		MCWB	76.4	76.4	75.3	74.6	70.1	69.2	68.3	68.9	70.6	73.3	73.1	75.6	(24)	
	10%	DB	89.4	88.1	86.6	82.7	75.2	73.6	74.8	80.2	82.3	84.5	86.4	88.2	(25)	
		MCWB	76.1	75.9	74.6	73.2	68.6	67.9	66.9	68.1	68.9	71.9	73.0	75.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	80.9	79.8	79.0	75.3	73.1	72.6	73.5	76.6	79.1	79.8	80.8	(27)	
		MCDB	89.0	88.6	88.0	86.9	81.8	78.3	79.5	84.1	88.9	90.3	88.7	89.4	(28)	
	2%	WB	79.5	79.3	78.3	77.3	73.1	71.3	70.4	71.4	74.0	77.1	77.9	79.2	(29)	
		MCDB	88.0	87.5	86.6	84.7	78.8	77.1	77.7	81.0	85.0	88.0	86.7	87.6	(30)	
	5%	WB	78.6	78.2	77.2	75.9	71.5	69.8	68.7	69.9	72.1	75.2	76.3	78.0	(31)	
		MCDB	87.1	86.4	85.5	83.1	76.9	75.8	75.5	80.5	82.2	84.8	84.9	86.1	(32)	
	10%	WB	77.5	77.2	76.1	74.4	69.7	68.2	67.2	68.3	70.3	73.6	74.7	76.8	(33)	
		MCDB	85.6	85.1	83.8	81.1	74.3	72.7	73.5	77.6	79.6	81.9	82.8	84.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	19.5	19.0	19.4	18.7	17.4	17.4	20.0	22.6	21.8	20.0	20.8	20.0	(35)	
		MCDBR	23.0	23.3	23.4	22.0	20.9	21.1	23.8	27.7	28.7	26.2	25.8	24.1	(36)	
		MCWBR	9.1	9.2	9.9	10.4	11.5	11.5	12.3	12.3	12.5	11.9	11.3	9.9	(37)	
	5% WB	MCDBR	19.3	19.6	19.6	19.4	18.4	18.8	21.1	25.2	24.6	22.8	21.4	19.8	(38)	
		MCWBR	9.1	9.3	9.8	10.2	10.8	11.1	12.1	12.7	12.3	11.6	11.1	10.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.403	0.397	0.386	0.381	0.353	0.386	0.382	0.466	0.561	0.467	0.416	0.412	(40)	
	taud		2.432	2.447	2.467	2.452	2.500	2.401	2.392	2.114	1.867	2.198	2.345	2.383	(41)	
	Ebn at Noon		298	295	289	276	271	251	257	245	235	272	293	296	(42)	
	Edh at Noon		39	38	35	33	29	30	31	45	63	48	43	41	(43)	
(44) All-Sky Solar Radiation	RadAvg		2042	1869	1700	1402	1041	900	1017	1253	1430	1643	1999	2048	(44)	
	RadStd		159	155	117	132	145	95	121	92	153	189	201	199	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page