

CATARATAS DEL IGUAZU, Argentina

WMO: 870970

Lat: 25.731S

Lon: 54.479W

Elev: 270

StdP: 98.12

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.1	6.1	2.2	4.6	7.1	4.1	5.2	8.7	9.0	15.7	8.0	16.3	1.9	230	0.310

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	35.1	24.1	34.0	24.1	33.0	24.0	26.6	31.3	26.1	30.8	25.6	30.3	3.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	21.1	28.9	24.9	20.6	28.7	24.2	19.7	27.8	85.3	31.4	82.7	31.0	80.3	30.6	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.9	6.4	5.4	DB	0.4	37.3	1.6	1.0	-0.7	38.0	-1.6	38.6	-2.5	39.2	-3.6	39.9
			WB	0.3	28.1	1.5	0.8	-0.8	28.7	-1.6	29.2	-2.5	29.6	-3.6	30.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.8	26.2	25.9	24.8	22.2	18.3	17.0	16.7	18.7	20.3	22.7	23.9	25.5	(6)	
(7)		DBStd	4.67	1.71	1.85	2.13	3.29	3.44	4.05	4.36	4.44	4.15	2.94	2.41	2.10	(7)	
(8)		HDD10.0	10	0	0	0	0	1	2	5	2	1	0	0	0	(8)	
(9)		HDD18.3	286	0	0	0	9	43	71	82	52	26	2	1	0	(9)	
(10)		CDD10.0	4333	504	446	459	367	258	213	213	273	311	393	416	480	(10)	
(11)		CDD18.3	1568	246	212	201	126	43	32	32	65	87	137	167	222	(11)	
(12)		CDH23.3	13147	2271	1815	1627	878	224	152	207	555	773	1127	1487	2032	(12)	
(13)	CDH26.7	5312	1008	785	659	294	41	17	33	192	320	457	613	891	(13)		
(14)	Wind	WSAvg	2.2	2.1	2.0	1.8	1.9	2.0	2.1	2.3	2.5	2.7	2.5	2.3	2.1	(14)	
(15)	Precipitation	PrecAvg	1826	167	142	115	149	172	163	113	124	130	180	180	132	(15)	
(16)		PrecMax	3105	458	360	258	363	428	333	447	376	400	253	588	284	(16)	
(17)		PrecMin	1205	21	4	24	4	18	32	2	11	19	92	20	24	(17)	
(18)		PrecStd	541	102	91	63	103	126	83	104	105	96	49	127	80	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	36.2	35.1	33.1	30.0	28.2	29.2	32.8	35.2	35.4	35.2	36.0	(19)	
(20)			MCWB	24.7	24.0	24.2	24.2	23.1	21.3	20.2	20.4	22.4	24.5	23.9	23.5	(20)	
(21)		2%	DB	34.1	34.1	33.2	31.7	27.8	27.0	27.7	30.9	33.0	33.2	33.3	34.2	(21)	
(22)			MCWB	24.7	24.6	24.1	24.1	22.1	21.0	20.2	20.5	21.9	23.8	23.6	24.2	(22)	
(23)		5%	DB	33.0	32.8	31.9	30.0	25.9	25.1	25.9	29.0	30.4	31.2	32.0	32.9	(23)	
(24)			MCWB	24.7	24.7	24.0	23.7	21.2	20.7	20.2	20.5	21.4	22.9	22.9	24.2	(24)	
(25)		10%	DB	31.9	31.2	30.4	28.2	24.0	23.1	23.8	26.8	27.9	29.2	30.2	31.2	(25)	
(26)			MCWB	24.5	24.4	23.6	22.9	20.3	19.9	19.4	20.0	20.5	22.2	22.8	23.9	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.2	26.6	26.1	24.1	22.8	22.5	23.1	24.8	26.2	26.6	27.1	(27)
(28)				MCDWB	31.7	31.4	31.1	30.5	27.7	25.7	26.4	29.0	31.6	32.4	31.5	31.9	(28)
(29)	2%		WB	26.4	26.3	25.7	25.1	22.8	21.8	21.4	21.9	23.3	25.1	25.5	26.2	(29)	
(30)			MCDWB	31.1	30.8	30.4	29.3	26.0	25.0	25.4	27.2	29.5	31.1	30.4	30.9	(30)	
(31)	5%		WB	25.9	25.7	25.1	24.4	21.9	21.0	20.4	21.0	22.3	24.0	24.6	25.6	(31)	
(32)			MCDWB	30.6	30.2	29.7	28.4	24.9	24.4	24.2	26.9	27.9	29.4	29.4	30.1	(32)	
(33)	10%		WB	25.3	25.1	24.5	23.6	20.9	20.1	19.6	20.2	21.3	23.1	23.7	24.9	(33)	
(34)			MCDWB	29.8	29.5	28.8	27.3	23.5	22.6	23.1	25.4	26.4	27.7	28.2	29.2	(34)	
(35)	Mean Daily Temperature Range		5% DB	MDBR	10.9	10.6	10.8	10.4	9.7	9.7	11.1	12.6	12.1	11.1	11.6	11.1	(35)
(36)				MCDBR	12.8	12.9	13.0	12.2	11.6	11.7	13.2	15.4	15.9	14.6	14.3	13.4	(36)
(37)		MCWBR		5.1	5.1	5.5	5.8	6.4	6.4	6.9	6.8	7.0	6.6	6.3	5.5	(37)	
(38)		5% WB	MCDWB	10.7	10.9	10.9	10.8	10.2	10.4	11.7	14.0	13.7	12.7	11.9	11.0	(38)	
(39)			MCWBR	5.1	5.1	5.4	5.6	6.0	6.2	6.7	7.0	6.8	6.4	6.2	5.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.403	0.397	0.386	0.381	0.353	0.386	0.382	0.466	0.561	0.467	0.416	0.412	(40)	
(41)		taud		2.432	2.447	2.467	2.452	2.500	2.401	2.392	2.114	1.867	2.198	2.345	2.383	(41)	
(42)		Ebn at Noon		941	931	912	870	853	791	811	771	741	857	923	934	(42)	
(43)		Edh at Noon		124	119	111	103	90	95	99	143	199	151	134	130	(43)	
(44)	All-Sky Solar Radiation	RadAvg		6.44	5.89	5.36	4.42	3.28	2.84	3.21	3.95	4.51	5.18	6.30	6.46	(44)	
(45)		RadStd		0.50	0.49	0.37	0.41	0.46	0.30	0.38	0.29	0.48	0.60	0.63	0.63	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page