

RESISTENCIA, Argentina

WMO: 871550

Lat: 27.4389S

Lon: 59.0461W

Elev: 171

StdP: 14.61

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.5	39.1	29.8	24.1	47.6	32.4	27.0	49.1	21.6	68.8	19.5	67.4	2.8	230	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.6	99.0	75.6	96.8	76.0	94.7	75.9	81.0	90.8	79.9	89.7	79.0	88.6	10.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	149.9	86.4	77.3	142.7	85.2	76.4	138.8	84.5	45.0	90.9	43.7	90.1	42.6	88.9	95.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.8	16.9	15.0	DB	29.4	103.9	2.7	2.8	27.5	105.9	25.9	107.6	24.4	109.2	22.4	111.3
			WB	28.9	84.1	2.8	2.7	26.9	86.0	25.2	87.6	23.6	89.2	21.6	91.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.8	81.0	79.6	76.6	71.2	64.5	61.0	60.0	63.3	66.9	72.2	74.8	78.9	(6)
	DBStd	10.34	4.53	5.19	5.51	6.96	7.94	9.01	9.80	10.04	9.02	7.15	5.79	5.21	(7)
	HDD50	34	0	0	0	0	1	9	16	7	1	0	0	0	(8)
	HDD65	802	0	0	1	22	110	185	223	160	82	15	4	0	(9)
	CDD50	7626	961	830	826	636	452	340	327	420	507	689	744	894	(10)
	CDD65	2919	496	410	362	208	95	67	69	107	139	239	297	430	(11)
	CDH74	29243	5690	4352	3394	1634	624	368	512	1113	1436	2289	3061	4770	(12)
	CDH80	13177	2889	2072	1480	603	169	82	154	475	629	996	1317	2311	(13)
(14) Wind	WSAvg	6.8	6.3	6.3	5.8	6.0	5.7	6.2	6.7	7.7	8.2	8.2	7.3	6.6	(14)
(15) Precipitation	PrecAvg	53.2	6.5	5.9	6.5	6.6	3.3	2.3	1.5	1.8	2.3	4.8	6.1	5.6	(15)
	PrecMax	87.3	17.4	18.7	19.1	20.8	9.8	10.5	5.2	6.0	8.5	13.3	24.1	12.6	(16)
	PrecMin	28.9	1.4	0.5	0.5	1.2	0.1	0.1	0.0	0.0	0.0	0.9	0.8	0.4	(17)
	PrecStd	11.7	3.5	3.3	4.3	5.0	2.5	2.0	1.1	1.3	1.7	2.4	3.9	3.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.8	100.8	98.8	93.5	89.7	86.1	87.9	94.9	99.0	101.1	99.4	100.6	(19)
		MCWB	76.3	76.4	74.9	76.4	74.3	71.7	69.0	69.8	71.3	75.5	76.2	74.8	(20)
	2%	DB	98.2	97.1	94.9	90.4	84.6	82.5	84.4	90.0	93.2	94.8	93.6	97.0	(21)
		MCWB	76.3	76.8	76.6	75.7	72.7	71.1	69.0	69.7	70.9	75.4	75.0	76.8	(22)
	5%	DB	95.3	94.1	91.4	87.3	80.7	78.6	80.6	85.9	87.5	89.7	90.9	94.3	(23)
		MCWB	76.5	76.9	75.9	74.3	70.9	69.5	68.0	68.7	69.6	73.6	73.9	76.1	(24)
	10%	DB	92.9	91.1	88.0	82.8	77.0	74.0	75.1	80.3	82.3	85.2	87.6	91.3	(25)
		MCWB	76.0	76.1	74.6	72.4	69.2	67.7	65.9	66.7	67.8	71.3	72.5	75.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.5	82.4	80.9	79.9	76.8	74.3	72.9	74.1	76.1	79.8	81.2	81.9	(27)
		MCDB	92.8	91.9	90.7	88.6	84.7	82.1	82.9	87.9	90.1	91.6	90.7	92.8	(28)
	2%	WB	80.7	80.4	79.3	77.9	74.6	72.3	70.9	71.8	73.7	77.3	78.5	80.1	(29)
		MCDB	90.7	89.4	89.0	86.4	81.6	79.5	80.5	85.4	86.8	90.0	88.7	90.3	(30)
	5%	WB	79.5	79.1	78.1	76.2	72.5	70.6	68.8	69.7	71.7	75.4	76.7	79.0	(31)
		MCDB	89.3	88.4	87.2	84.1	78.7	76.9	77.6	82.1	83.5	87.7	86.5	89.0	(32)
	10%	WB	78.4	78.0	76.6	74.3	70.7	68.7	66.8	67.5	69.6	73.3	74.9	77.7	(33)
		MCDB	87.8	87.1	84.6	80.6	75.7	73.8	74.4	78.9	79.6	82.5	83.7	86.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.6	19.2	19.1	18.2	18.4	18.1	21.0	23.1	22.7	20.1	21.0	20.5	(35)
		MCDBR	24.8	23.8	23.8	22.3	20.5	19.3	22.9	27.2	28.3	26.3	26.0	25.2	(36)
	5% WB	MCWBR	7.9	7.8	8.7	9.3	9.9	9.6	10.3	11.0	11.3	10.9	10.0	8.6	(37)
		MCWBR	19.2	18.4	19.1	18.3	16.9	17.5	21.1	24.6	23.5	22.2	19.6	19.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.411	0.409	0.397	0.393	0.375	0.390	0.384	0.476	0.545	0.478	0.403	0.413	(40)
		taud	2.394	2.406	2.427	2.412	2.421	2.366	2.363	2.052	1.885	2.143	2.372	2.373	(41)
	Ebn at Noon		296	291	285	270	260	246	253	239	238	268	296	296	(42)
		Edh at Noon	41	39	36	34	30	30	32	48	62	50	41	42	(43)
(44) All-Sky Solar Radiation	RadAvg		2154	1967	1690	1307	1026	844	1006	1234	1491	1736	2080	2148	(44)
	RadStd		178	134	117	139	127	74	89	110	180	185	153	151	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page