

FORMOSA, Argentina

WMO: 871620

Lat: 26.2125S

Lon: 58.2292W

Elev: 60

StdP: 100.61

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	6.2	0.7	4.0	10.4	2.2	4.4	10.1	12.9	22.6	11.0	23.4	1.9	230	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	37.8	24.8	36.5	24.9	35.2	24.8	27.5	33.1	27.0	32.6	26.5	32.1	6.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.7	30.3	25.6	21.0	29.9	25.1	20.3	29.4	88.1	33.3	85.6	32.7	83.4	32.3	32.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.2	8.1	DB	1.1	40.1	1.6	1.1	-0.1	40.8	-1.0	41.5	-1.9	42.1	-3.1	42.9	(4)
(5)			WB	0.6	29.1	1.6	1.3	-0.5	30.0	-1.4	30.7	-2.3	31.4	-3.5	32.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	28.1	27.5	26.0	23.2	19.4	17.7	17.2	19.0	20.7	23.7	24.9	27.0	(6)	
	DBStd	5.52	2.36	2.67	2.91	3.83	4.22	4.90	5.38	5.48	4.93	3.84	3.14	2.75	(7)	
	HDD10.0	8	0	0	0	0	0	2	4	2	0	0	0	0	(8)	
	HDD18.3	307	0	0	0	7	39	73	92	62	30	3	1	0	(9)	
	CDD10.0	4696	562	489	495	396	291	233	227	279	322	424	448	528	(10)	
	CDD18.3	1954	304	256	237	153	71	54	56	82	102	169	199	270	(11)	
	CDH23.3	19916	3579	2803	2334	1284	471	319	418	836	1068	1638	2056	3108	(12)	
(13)	CDH26.7	9282	1840	1368	1073	521	142	78	132	364	492	754	949	1569	(13)	
(14)	Wind	WSAvg	3.6	3.5	3.3	3.1	3.2	3.2	3.5	3.7	4.1	4.2	4.2	3.9	3.7	(14)
(15) Precipitation	PrecAvg	1412	167	140	142	158	106	65	43	49	82	136	162	165	(15)	
	PrecMax	2039	338	654	357	395	271	188	165	195	224	292	468	425	(16)	
	PrecMin	826	8	4	8	17	13	6	0	0	1	16	22	35	(17)	
	PrecStd	266	84	99	77	100	66	43	37	46	53	71	89	88	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	38.3	37.3	35.2	32.4	30.5	31.9	35.2	37.4	38.5	38.0	38.3	(19)	
		MCWB	25.3	25.3	24.7	25.1	23.9	22.7	21.4	21.5	23.3	25.1	24.7	24.2	(20)	
	2%	DB	36.9	36.8	35.8	33.7	30.2	29.0	30.0	33.1	35.0	36.1	35.7	36.8	(21)	
		MCWB	25.1	25.5	25.2	24.5	22.7	21.9	21.1	21.6	22.7	24.6	24.7	24.8	(22)	
	5%	DB	35.8	35.0	34.0	31.9	28.0	27.1	28.1	31.0	32.1	33.2	33.9	35.1	(23)	
		MCWB	25.2	25.9	24.9	24.2	22.0	21.5	20.7	20.9	22.0	24.0	24.0	24.8	(24)	
	10%	DB	34.1	33.2	32.1	29.9	25.9	24.9	25.6	28.2	29.3	30.8	31.8	33.8	(25)	
		MCWB	25.0	25.0	24.4	23.7	21.3	20.9	19.9	20.3	21.1	23.2	23.3	24.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	28.4	27.5	27.0	25.3	23.7	23.5	24.0	25.4	27.0	27.6	27.8	(27)	
		MCDB	34.0	33.8	32.9	32.2	29.6	28.1	28.8	31.1	33.1	33.8	33.9	33.2	(28)	
	2%	WB	27.3	27.2	26.7	26.1	24.1	22.9	22.3	22.7	24.2	25.9	26.4	27.1	(29)	
		MCDB	33.0	32.6	32.0	31.3	28.4	27.1	27.3	30.7	31.7	33.2	32.4	32.8	(30)	
	5%	WB	26.7	26.6	26.1	25.3	23.0	22.0	21.2	21.6	23.0	24.9	25.5	26.5	(31)	
		MCDB	32.3	32.0	31.4	29.9	26.5	25.9	26.4	28.6	30.1	31.5	31.1	32.1	(32)	
	10%	WB	26.2	26.1	25.4	24.5	22.0	21.0	20.2	20.5	21.8	23.9	24.6	25.9	(33)	
		MCDB	31.6	31.3	30.3	28.4	24.9	24.6	24.9	27.0	27.9	29.8	29.7	31.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.3	10.4	9.9	9.3	9.2	10.7	12.1	12.1	10.7	11.0	11.0	(35)	
		MCDBR	13.0	12.4	12.9	12.2	11.3	10.5	12.4	14.6	15.5	14.1	14.2	13.3	(36)	
	5% WB	MCWBR	3.9	4.0	4.4	4.7	5.2	5.1	5.5	5.9	6.3	5.6	5.3	4.2	(37)	
		MCWBR	10.3	10.3	10.6	10.3	9.3	9.4	11.2	13.3	13.5	12.2	11.0	10.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.409	0.409	0.401	0.401	0.380	0.401	0.390	0.497	0.565	0.492	0.412	0.414	(40)	
		taud	2.405	2.411	2.416	2.394	2.415	2.342	2.362	2.011	1.845	2.113	2.354	2.374	(41)	
	Ebn at Noon		935	920	897	847	820	771	800	740	736	834	926	932	(42)	
		Edh at Noon	127	123	117	109	97	100	102	157	203	164	133	131	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.73	6.17	5.31	4.21	3.25	2.68	3.17	3.80	4.56	5.40	6.38	6.71	(44)	
	RadStd		0.48	0.41	0.38	0.46	0.42	0.26	0.29	0.29	0.52	0.61	0.38	0.46	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page