

POSADAS, Argentina

WMO: 871780

Lat: 27.3911S

Lon: 55.9669W

Elev: 125

StdP: 99.83

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	7.0	-0.8	3.6	9.0	1.0	4.1	10.3	8.6	18.9	7.6	18.4	2.2	140	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.2	36.1	24.0	35.1	24.0	34.1	23.9	26.6	32.6	26.1	32.0	25.6	31.3	3.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.4	30.0	24.2	19.4	29.2	24.0	19.1	28.9	84.2	32.7	81.8	32.3	79.4	31.6	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	6.8	5.9	2.2	38.2	1.4	0.9	1.2	38.8	0.4	39.3	-0.3	39.8	-1.3	40.4		
			0.8	28.0	1.5	0.9	-0.2	28.6	-1.1	29.1	-1.9	29.6	-3.0	30.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	27.6	27.1	25.6	22.8	19.1	17.5	17.1	18.9	20.3	22.9	24.6	26.6
	DBStd	5.20	2.18	2.44	2.72	3.65	3.86	4.52	4.97	5.06	4.42	3.27	2.82	2.60
	HDD10.0	8	0	0	0	0	1	2	4	2	0	0	0	0
	HDD18.3	293	0	0	0	8	39	69	87	58	28	3	1	0
	CDD10.0	4564	546	478	483	384	281	227	223	277	310	402	438	516
	CDD18.3	1808	287	244	226	142	61	45	47	75	88	146	189	257
	CDH23.3	16821	3169	2505	2089	1103	333	219	258	593	754	1228	1801	2768
CDH26.7	7218	1515	1136	901	412	82	42	54	203	296	492	773	1313	
Wind	WSAvg	2.7	2.6	2.6	2.4	2.5	2.5	2.6	2.8	3.0	3.1	3.1	2.9	2.8
Precipitation	PrecAvg	1755	166	142	156	166	132	132	96	98	138	210	163	165
	PrecMax	3025	358	465	462	428	576	388	404	248	393	548	539	465
	PrecMin	532	4	20	23	0	1	6	5	18	21	15	19	12
	PrecStd	457	93	88	91	109	103	82	73	59	73	114	111	103
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	37.2	36.1	34.1	31.3	29.8	30.1	33.1	35.2	36.0	36.0	37.2
		MCWB	24.0	24.4	23.9	24.3	22.9	21.5	20.9	21.4	22.3	24.5	24.0	23.5
	2%	DB	35.8	35.2	34.2	32.8	29.0	28.0	28.2	31.1	32.9	33.5	34.2	35.7
		MCWB	24.2	24.3	24.3	23.8	21.8	21.1	20.3	20.7	22.1	23.7	23.2	23.7
	5%	DB	34.8	33.9	33.0	31.0	26.9	26.0	26.2	29.1	30.1	31.4	32.9	34.2
		MCWB	24.2	24.4	23.9	23.3	20.9	20.5	19.8	20.2	21.2	22.5	22.6	23.7
	10%	DB	33.2	32.7	31.4	29.1	24.9	24.0	24.2	26.8	27.7	29.5	31.1	32.9
		MCWB	24.2	24.2	23.4	22.4	20.1	19.6	19.0	19.4	20.0	21.6	22.1	23.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.3	26.7	26.2	24.0	22.8	22.5	22.9	24.4	26.0	26.3	27.0
		MCDB	33.1	32.6	32.8	31.9	29.2	27.3	27.3	30.3	32.0	33.1	32.4	33.3
	2%	WB	26.5	26.4	25.9	25.1	22.8	21.6	21.2	21.6	23.0	24.7	25.2	26.2
		MCDB	32.4	32.0	31.9	30.3	27.1	26.3	26.2	29.0	30.3	31.7	31.2	32.4
	5%	WB	25.9	25.7	25.2	24.3	21.7	20.8	20.3	20.7	21.8	23.6	24.4	25.5
		MCDB	31.7	31.2	30.6	29.3	25.4	25.1	25.0	27.5	28.0	29.9	30.1	31.3
	10%	WB	25.2	25.1	24.4	23.4	20.8	19.9	19.4	19.7	20.8	22.6	23.4	24.8
		MCDB	30.8	30.3	29.5	27.8	24.0	23.4	23.8	25.8	26.2	27.9	28.7	30.2
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.0	10.0	9.7	8.9	8.7	9.6	10.6	10.4	10.1	10.9	10.6
		MCDBR	12.0	11.5	11.9	11.5	10.9	10.0	10.8	12.6	13.4	12.9	13.3	12.6
		MCWBR	4.4	4.2	4.6	4.9	5.2	5.0	5.4	5.7	6.0	6.0	5.7	5.0
	5% WB	MCDBR	10.0	9.8	10.1	10.2	9.0	9.2	10.1	11.5	11.4	11.2	10.8	10.4
MCWBR		4.4	4.4	4.6	4.8	4.8	5.1	5.7	5.8	5.9	5.8	5.5	5.0	
Clear-Sky Solar Irradiance	taub	0.409	0.407	0.398	0.394	0.371	0.393	0.392	0.490	0.553	0.467	0.406	0.411	
	taud	2.407	2.414	2.422	2.404	2.434	2.372	2.352	2.025	1.876	2.183	2.366	2.380	
	Ebn at Noon	935	920	897	850	823	774	791	741	742	855	932	935	
	Edh at Noon	127	122	115	107	94	96	101	154	196	153	131	130	
All-Sky Solar Radiation	RadAvg	6.61	6.12	5.31	4.22	3.14	2.64	3.04	3.67	4.37	5.24	6.39	6.71	
	RadStd	0.50	0.45	0.36	0.41	0.41	0.22	0.33	0.29	0.47	0.70	0.64	0.61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74

Nomenclature: See separate page