

RECONQUISTA, Argentina

WMO: 872700

Lat: 29.2050S

Lon: 59.6933W

Elev: 174

StdP: 14.60

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.2	40.3	28.0	22.1	49.7	31.1	25.5	49.0	26.2	63.6	22.4	61.3	3.4	230	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.1	97.1	76.8	94.6	76.1	92.1	75.1	80.7	91.2	79.4	89.2	78.2	87.3	11.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	146.2	86.5	76.7	140.2	85.0	75.5	134.5	83.8	44.6	91.2	43.2	89.6	41.9	87.4	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	20.5	18.3	31.7	102.1	3.2	1.9	29.3	103.5	27.4	104.7	25.6	105.8	23.3	107.2
			30.3	83.2	3.2	1.7	28.0	84.4	26.1	85.4	24.3	86.3	21.9	87.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	80.0	78.1	74.8	69.1	63.1	59.1	57.8	61.2	64.8	69.7	73.3	77.5
	DBStd	10.23	4.83	5.32	5.66	6.82	7.07	8.14	8.98	9.43	8.35	6.58	5.54	5.41
	HDD50	44	0	0	0	0	1	11	22	9	1	0	0	0
	HDD65	969	0	0	3	34	124	215	265	193	101	27	6	1
	CDD50	6978	929	788	770	574	407	285	264	356	444	609	700	852
	CDD65	2429	464	369	308	158	65	39	42	75	94	171	256	388
	CDH74	22473	5108	3604	2585	1061	294	160	242	677	919	1445	2364	4014
	CDH80	9206	2392	1531	976	320	52	24	51	250	370	521	919	1800
Wind	WSAvg	7.9	7.3	7.2	7.0	6.7	6.6	6.9	7.9	9.1	9.6	9.7	8.7	7.8
Precipitation	PrecAvg	48.2	5.7	6.0	6.4	5.7	3.0	1.7	1.3	1.4	2.2	4.8	5.5	5.7
	PrecMax	76.1	15.4	14.4	16.9	19.0	11.6	8.0	5.1	13.0	6.5	13.9	16.9	17.6
	PrecMin	23.3	0.6	0.7	0.3	1.0	0.2	0.0	0.0	0.0	0.1	0.5	0.9	0.6
	PrecStd	11.3	3.6	3.7	3.4	4.5	2.4	1.9	1.1	1.8	1.4	3.2	3.0	3.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.4	98.9	96.5	91.4	85.1	83.2	85.0	91.8	97.9	96.2	96.1	99.5
		MCWB	77.0	78.5	77.5	76.7	73.4	71.5	69.1	71.4	73.0	75.8	75.3	77.4
	2%	DB	96.6	94.9	92.2	87.5	80.7	78.7	80.7	86.8	89.4	89.5	91.8	95.4
		MCWB	77.1	77.1	76.2	74.8	70.9	69.8	67.9	69.8	70.8	72.6	72.7	76.5
	5%	DB	93.7	91.6	88.6	83.8	77.1	74.7	75.8	81.8	83.8	85.8	88.6	92.5
		MCWB	76.3	76.1	74.9	72.4	69.3	68.6	66.4	67.6	67.6	71.8	71.3	75.1
	10%	DB	90.8	88.6	85.4	80.3	74.0	71.0	71.2	76.5	78.7	81.8	85.6	89.3
		MCWB	75.1	75.4	73.6	71.2	67.9	66.0	63.9	65.4	65.5	69.2	70.1	74.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.3	81.9	80.2	78.8	75.5	73.5	71.8	73.9	76.1	78.7	79.0	81.9
		MCDB	92.9	92.1	90.8	87.3	82.6	80.4	80.4	87.7	90.3	89.2	91.3	93.4
	2%	WB	80.2	80.4	78.6	76.8	73.1	71.1	69.2	71.1	72.7	76.1	76.2	80.1
		MCDB	90.4	90.0	88.1	84.8	77.9	76.1	77.6	83.6	84.9	86.9	86.4	90.6
	5%	WB	78.9	78.9	77.1	74.9	70.8	68.9	67.1	68.7	70.1	73.7	74.3	78.3
		MCDB	88.4	87.4	85.6	81.4	75.4	73.9	74.6	79.4	80.5	82.3	83.6	87.6
	10%	WB	77.5	77.3	75.4	72.9	68.7	66.6	64.9	66.2	67.6	71.3	72.6	76.4
		MCDB	86.5	84.9	82.6	77.9	73.1	70.8	70.8	75.8	76.1	79.1	81.0	85.3
Mean Daily Temperature Range	5% DB	MDBR	18.1	17.0	16.7	15.9	15.0	15.3	17.7	20.2	20.0	18.4	19.4	18.5
		MCDBR	21.9	21.0	20.9	19.9	17.9	16.8	21.2	25.3	26.9	24.0	24.2	23.4
		MCWBR	7.1	7.4	8.0	9.0	9.1	9.1	10.5	11.3	11.4	10.5	9.1	8.6
	5% WB	MCDBR	18.1	17.0	17.7	16.5	14.4	15.4	18.7	23.1	22.6	20.0	19.0	18.7
MCWBR		7.6	7.6	8.4	8.5	8.5	8.8	10.3	11.2	11.1	10.5	9.3	9.0	
Clear-Sky Solar Irradiance	taub	0.402	0.397	0.387	0.388	0.367	0.379	0.376	0.459	0.524	0.455	0.401	0.400	
	taud	2.405	2.427	2.437	2.412	2.434	2.385	2.364	2.079	1.912	2.187	2.357	2.391	
	Ebn at Noon	298	294	286	269	260	247	253	241	241	273	297	299	
	Edh at Noon	40	38	36	33	29	29	31	45	59	48	42	41	
All-Sky Solar Radiation	RadAvg	2181	1964	1689	1271	971	829	970	1229	1507	1780	2137	2200	
	RadStd	181	145	114	154	111	76	87	104	163	180	167	150	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+0.85	+0.77	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page