

RECONQUISTA, Argentina

WMO: 872700

Lat: 29.2050S

Lon: 59.6933W

Elev: 53

StdP: 100.69

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.9	4.6	-2.2	3.2	9.9	-0.5	3.6	9.4	11.7	17.5	10.0	16.3	1.5	230	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.1	36.2	24.9	34.8	24.5	33.4	24.0	27.0	32.9	26.3	31.8	25.7	30.7	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	20.9	30.3	24.9	20.0	29.5	24.2	19.2	28.8	85.8	32.9	82.6	32.0	79.5	30.8	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.1	8.2	-0.2	39.0	1.8	1.1	-1.5	39.7	-2.5	40.4	-3.5	41.0	-4.8	41.8		
			-0.9	28.4	1.8	0.9	-2.2	29.1	-3.3	29.6	-4.3	30.2	-5.6	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	26.7	25.6	23.8	20.6	17.3	15.1	14.3	16.2	18.2	20.9	23.0	25.3
	DBStd	5.68	2.68	2.96	3.15	3.79	3.93	4.52	4.99	5.24	4.64	3.66	3.08	3.01
	HDD10.0	24	0	0	0	0	1	6	12	5	1	0	0	0
	HDD18.3	538	0	0	2	19	69	119	147	107	56	15	3	1
	CDD10.0	3877	516	438	428	319	226	158	147	198	247	338	389	473
	CDD18.3	1349	258	205	171	88	36	22	23	42	52	95	142	216
	CDH23.3	12485	2838	2002	1436	589	163	89	134	376	511	803	1313	2230
CDH26.7	5114	1329	851	542	178	29	13	28	139	206	289	511	1000	
Wind	WSAvg	3.5	3.2	3.2	3.1	3.0	3.0	3.1	3.5	4.0	4.3	4.3	3.9	3.5
Precipitation	PrecAvg	1225	146	152	162	145	75	43	34	36	57	123	140	144
	PrecMax	1934	392	365	429	483	294	204	129	329	164	353	428	447
	PrecMin	593	16	17	8	26	4	0	0	0	2	13	24	16
	PrecStd	288	92	93	86	115	60	49	28	46	36	81	77	95
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.0	37.2	35.8	33.0	29.5	28.4	29.4	33.2	36.6	35.7	35.6	37.5
		MCWB	25.0	25.8	25.3	24.8	23.0	21.9	20.6	21.9	22.8	24.3	24.1	25.2
	2%	DB	35.9	34.9	33.4	30.9	27.1	25.9	27.1	30.5	31.9	31.9	33.2	35.2
		MCWB	25.1	25.0	24.5	23.8	21.6	21.0	19.9	21.0	21.6	22.6	22.6	24.7
	5%	DB	34.3	33.1	31.5	28.8	25.0	23.7	24.3	27.7	28.8	29.9	31.5	33.6
		MCWB	24.6	24.5	23.8	22.4	20.7	20.3	19.1	19.8	19.8	22.1	21.8	24.0
	10%	DB	32.6	31.4	29.7	26.9	23.3	21.7	21.8	24.7	26.0	27.7	29.8	31.8
		MCWB	24.0	24.1	23.1	21.8	20.0	18.9	17.7	18.6	18.6	20.6	21.2	23.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	27.7	26.8	26.0	24.2	23.1	22.1	23.3	24.5	26.0	26.1	27.7
		MCDB	33.9	33.4	32.7	30.7	28.1	26.9	26.9	31.0	32.4	31.8	32.9	34.1
	2%	WB	26.8	26.9	25.9	24.9	22.8	21.7	20.7	21.7	22.6	24.5	24.5	26.7
		MCDB	32.5	32.2	31.2	29.3	25.5	24.5	25.3	28.7	29.4	30.5	30.2	32.6
	5%	WB	26.1	26.0	25.1	23.8	21.6	20.5	19.5	20.4	21.2	23.1	23.5	25.7
		MCDB	31.3	30.8	29.8	27.4	24.1	23.3	23.7	26.4	26.9	27.9	28.6	30.9
	10%	WB	25.3	25.2	24.1	22.7	20.4	19.2	18.3	19.0	19.8	21.8	22.6	24.7
		MCDB	30.3	29.4	28.1	25.5	22.8	21.6	21.5	24.4	24.5	26.2	27.2	29.6
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.4	9.3	8.8	8.3	8.5	9.8	11.2	11.1	10.2	10.8	10.3
		MCDBR	12.2	11.6	11.6	11.0	9.9	9.4	11.8	14.0	14.9	13.4	13.4	13.0
		MCWBR	4.0	4.1	4.5	5.0	5.1	5.0	5.8	6.3	6.3	5.9	5.1	4.8
	5% WB	MCDDBR	10.0	9.4	9.8	9.2	8.0	8.5	10.4	12.8	12.5	11.1	10.5	10.4
		MCWBR	4.2	4.2	4.7	4.7	4.7	4.9	5.7	6.2	6.2	5.8	5.2	5.0
Clear-Sky Solar Irradiance	taub	0.402	0.397	0.387	0.388	0.367	0.379	0.376	0.459	0.524	0.455	0.401	0.400	
	taud	2.405	2.427	2.437	2.412	2.434	2.385	2.364	2.079	1.912	2.187	2.357	2.391	
	Ebn at Noon	941	927	903	849	819	778	798	761	760	862	935	944	
	Edh at Noon	126	120	112	105	92	92	98	143	187	151	132	129	
All-Sky Solar Radiation	RadAvg	6.88	6.19	5.32	4.01	3.06	2.61	3.06	3.87	4.75	5.61	6.74	6.93	
	RadStd	0.57	0.46	0.36	0.49	0.35	0.24	0.28	0.33	0.51	0.57	0.53	0.47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	+0.47	+0.43	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page