

SAN JUAN, Argentina

WMO: 873110

Lat: 31.5747S

Lon: 68.4225W

Elev: 1962

StdP: 13.68

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.3	31.1	6.4	8.2	62.7	11.7	10.7	55.5	30.4	63.2	25.5	60.3	2.4	0	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	100.6	67.7	98.1	67.4	95.4	66.8	72.3	92.7	71.0	90.9	69.8	89.4	11.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	103.5	80.4	64.5	97.8	80.3	63.0	92.5	79.6	37.4	92.6	36.2	90.9	35.0	89.5	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
29.4	24.8	21.7	DB	22.8	108.0	3.0	3.0	20.6	110.1	18.9	111.9	17.2	113.6	15.0	115.7
			WB	20.9	74.8	2.7	1.7	18.9	76.0	17.4	77.0	15.9	77.9	13.9	79.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	81.2	78.4	73.4	64.3	55.6	48.5	47.3	52.8	59.5	67.5	73.9	79.0	(6)
	DBStd	13.21	5.15	5.97	5.84	6.30	5.84	5.22	5.75	6.54	7.07	6.66	6.26	5.79	(7)
	HDD50	276	0	0	0	2	15	86	120	42	10	1	0	0	(8)
	HDD65	2074	1	2	8	88	294	495	551	385	190	49	9	2	(9)
	CDD50	5772	969	796	727	430	189	41	35	128	295	544	718	900	(10)
	CDD65	2093	504	378	269	66	4	0	1	5	25	127	277	437	(11)
	CDH74	25855	6352	4382	2717	722	93	25	35	176	560	1705	3454	5634	(12)
	CDH80	12905	3517	2282	1185	205	18	8	7	59	179	695	1675	3075	(13)
(14) Wind	WSAvg	8.4	10.4	9.5	8.5	7.1	5.7	6.0	6.3	7.3	8.5	9.8	10.7	10.7	(14)
(15) Precipitation	PrecAvg	4.0	0.7	1.0	0.5	0.2	0.1	0.1	0.1	0.1	0.2	0.1	0.3	0.6	(15)
	PrecMax	8.9	1.7	6.1	1.1	0.8	0.9	0.7	0.6	1.3	1.8	0.7	0.9	2.0	(16)
	PrecMin	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	1.8	0.6	1.2	0.3	0.2	0.2	0.2	0.1	0.2	0.4	0.2	0.3	0.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.1	102.2	97.3	90.0	81.6	77.3	79.2	87.5	91.7	97.3	100.3	104.3	(19)
		MCWB	70.0	67.7	69.0	65.7	59.4	50.5	52.3	54.7	58.6	61.1	64.7	67.4	(20)
	2%	DB	100.4	98.2	93.3	85.5	76.0	68.1	69.7	78.9	85.1	91.5	96.4	99.8	(21)
		MCWB	68.7	68.9	67.6	63.4	57.9	51.4	49.7	53.9	56.5	61.8	64.5	67.3	(22)
	5%	DB	97.5	95.2	90.2	81.9	72.0	64.5	65.2	73.1	80.3	87.3	92.9	96.9	(23)
		MCWB	68.6	67.8	66.7	61.9	56.3	50.0	48.2	51.7	54.7	60.1	63.8	66.5	(24)
	10%	DB	94.7	92.2	87.0	77.9	68.5	61.4	61.4	68.5	76.1	83.3	89.5	93.7	(25)
		MCWB	67.8	67.3	65.8	60.4	54.6	48.4	46.5	49.5	53.5	58.4	62.8	65.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	73.8	72.7	67.5	62.4	55.3	54.3	58.2	60.8	66.9	70.3	72.8	(27)
		MCDB	96.9	93.4	91.1	83.2	76.9	68.5	70.9	80.9	83.8	89.2	92.2	94.5	(28)
	2%	WB	72.1	72.2	70.2	65.5	60.1	53.1	51.5	54.7	58.3	64.0	67.6	70.8	(29)
		MCDB	93.9	90.9	88.0	80.5	72.5	65.5	67.2	75.0	80.2	85.5	89.3	92.3	(30)
	5%	WB	70.8	70.8	68.5	63.6	57.9	51.3	49.3	52.4	56.2	61.8	65.7	69.2	(31)
		MCDB	91.7	89.0	85.1	78.2	69.5	62.8	63.1	71.0	76.6	82.1	87.5	90.4	(32)
	10%	WB	69.5	69.3	66.9	61.8	55.8	49.3	47.2	50.2	54.2	59.8	63.9	67.7	(33)
		MCDB	89.5	87.3	83.2	75.9	66.5	59.9	60.1	67.5	73.3	79.7	85.5	87.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	24.8	24.0	23.1	23.2	23.1	25.2	26.8	27.9	27.5	26.7	27.1	26.3	(35)
		MCDBR	28.8	28.8	28.2	29.5	28.9	30.7	33.5	36.3	35.5	33.5	32.7	31.3	(36)
		MCWBR	8.2	8.6	9.4	12.2	14.6	17.1	17.9	17.2	14.9	12.4	11.3	9.8	(37)
	5% WB	MCDBR	25.5	24.6	24.6	25.2	25.7	27.7	30.4	33.1	31.4	29.1	28.5	26.5	(38)
		MCWBR	8.7	8.6	9.1	11.1	13.6	16.1	16.9	16.4	13.7	11.7	11.2	9.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.393	0.386	0.364	0.350	0.315	0.291	0.290	0.312	0.356	0.356	0.371	0.386	(40)
	taud		2.383	2.402	2.457	2.461	2.505	2.567	2.533	2.461	2.335	2.371	2.361	2.369	(41)
	Ebn at Noon		300	296	292	279	274	276	281	288	289	302	305	304	(42)
	Edh at Noon		41	39	35	31	26	23	25	30	38	40	42	42	(43)
(44) All-Sky Solar Radiation	RadAvg		2515	2253	1883	1469	1092	1005	1094	1412	1807	2231	2566	2671	(44)
	RadStd		137	121	95	105	110	67	58	76	114	124	125	129	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	+0.81	+0.77	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	+113	

Nomenclature: See separate page