

CHAMICAL, Argentina

WMO: 873200

Lat: 30.3478S

Lon: 66.2961W

Elev: 461

StdP: 95.91

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.0	3.8	-7.8	2.1	10.3	-5.7	2.5	10.2	10.9	13.0	9.2	15.2	1.0	140	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	38.2	23.6	36.6	23.0	35.1	22.4	25.6	34.3	24.7	33.2	24.0	32.0	5.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.1	29.6	22.3	18.0	28.9	21.6	17.2	28.3	81.7	34.7	78.0	33.2	74.9	32.0	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	10.0	8.4	-0.9	40.7	2.6	2.0	-2.7	42.1	-4.2	43.3	-5.7	44.5	-7.5	45.9		
			-3.0	26.8	2.2	1.6	-4.6	27.9	-5.8	28.9	-7.0	29.7	-8.6	30.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	27.9	26.1	23.5	19.6	15.6	12.6	12.3	15.2	18.5	22.4	24.6	26.7	(6)
(7)		DBStd	6.43	3.33	3.34	3.42	3.54	3.40	2.77	3.60	4.20	4.36	3.94	3.74	3.43	(7)
(8)		HDD10.0	33	0	0	0	1	2	8	16	5	1	0	0	0	(8)
(9)		HDD18.3	667	0	0	4	26	99	171	188	115	51	10	2	1	(9)
(10)		CDD10.0	3824	555	451	418	289	175	87	89	167	255	384	437	517	(10)
(11)		CDD18.3	1418	297	218	164	64	14	1	3	19	56	136	189	259	(11)
(12)		CDH23.3	14720	3558	2277	1280	394	61	3	23	193	507	1364	2056	3004	(12)
(13)	CDH26.7	6935	1923	1062	474	102	11	0	4	59	164	582	1003	1551	(13)	
(14)	Wind	WSAvg	2.6	3.0	2.6	2.1	2.1	1.6	1.5	1.8	2.4	3.0	3.6	3.6	3.4	(14)
(15)	Precipitation	PrecAvg	441	96	77	70	21	8	3	5	4	13	24	55	83	(15)
(16)		PrecMax	631	188	230	215	84	43	20	26	31	46	172	178	240	(16)
(17)		PrecMin	296	34	0	3	1	0	0	0	0	0	0	0	6	(17)
(18)		PrecStd	103	41	49	43	19	10	5	8	7	14	33	40	50	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.3	38.0	35.8	32.1	28.0	23.5	26.5	31.5	33.9	37.7	38.1	39.7	(19)
(20)		MCWB	24.6	25.1	24.5	22.2	19.8	16.7	17.3	19.1	20.3	21.7	22.1	23.5	(20)	
(21)		2%	DB	38.6	36.0	33.3	29.3	24.9	20.9	23.3	28.0	30.7	34.8	36.0	37.4	(21)
(22)		MCWB	24.0	24.4	23.3	21.1	18.1	14.7	15.5	16.7	18.1	20.6	21.3	22.9	(22)	
(23)		5%	DB	36.6	34.1	31.4	27.3	22.8	19.5	20.9	25.2	28.4	32.3	34.1	35.5	(23)
(24)		MCWB	23.6	23.4	22.6	19.8	16.9	13.7	13.6	15.5	17.1	19.5	20.5	22.2	(24)	
(25)		10%	DB	34.6	32.5	29.4	25.5	21.1	18.1	18.9	22.8	26.2	30.1	32.2	33.6	(25)
(26)		MCWB	23.1	22.9	21.8	19.2	16.0	13.1	12.2	13.8	16.0	18.5	19.9	21.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	28.0	25.5	23.4	20.4	17.2	18.4	19.7	21.8	23.7	24.2	25.6	(27)
(28)		MCDWB	36.5	35.2	33.4	28.8	25.7	21.1	25.1	29.5	30.6	34.5	34.0	35.9	(28)	
(29)		2%	WB	25.6	25.6	24.5	22.3	19.2	15.8	16.5	18.0	19.5	22.0	23.0	24.5	(29)
(30)		MCDWB	35.4	32.7	31.1	26.8	23.8	19.4	21.7	26.3	28.2	31.4	32.2	34.1	(30)	
(31)		5%	WB	24.6	24.5	23.5	21.3	18.1	14.8	15.0	16.3	18.1	20.7	21.9	23.6	(31)
(32)		MCDWB	34.1	31.7	29.5	25.5	21.6	18.4	19.2	23.5	26.4	29.8	31.1	32.9	(32)	
(33)		10%	WB	23.7	23.7	22.6	20.3	17.0	13.7	13.5	14.7	16.8	19.5	20.9	22.7	(33)
(34)		MCDWB	32.5	30.5	28.1	24.3	20.2	17.0	17.8	21.6	24.9	28.2	30.2	31.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.4	10.4	9.4	9.6	8.9	9.7	11.3	12.6	12.3	12.1	12.2	11.8	(35)	
(36)		5% DB	MCDBR	13.7	12.1	11.6	11.9	10.7	11.8	13.4	15.2	14.6	14.7	14.7	14.3	(36)
(37)		MCWBR	4.8	4.5	4.8	5.7	5.5	6.7	7.3	7.4	7.0	6.4	5.8	5.1	(37)	
(38)		5% WB	MCDBR	12.4	10.6	10.2	9.1	9.0	9.8	11.4	14.2	13.3	12.8	12.5	12.6	(38)
(39)		MCWBR	5.2	4.7	4.5	4.7	4.8	6.1	6.5	7.5	7.1	6.2	5.4	5.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.391	0.380	0.368	0.360	0.331	0.316	0.312	0.348	0.389	0.382	0.382	0.386	(40)	
(41)		taud	2.424	2.459	2.492	2.472	2.504	2.526	2.502	2.387	2.274	2.356	2.396	2.421	(41)	
(42)		Ebn at Noon	950	942	920	874	854	846	865	872	882	929	952	958	(42)	
(43)		Edh at Noon	124	116	106	97	84	78	83	104	129	127	127	125	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.38	6.48	5.36	4.16	3.25	3.00	3.42	4.45	5.60	6.62	7.46	7.67	(44)	
(45)		RadStd	0.42	0.46	0.43	0.43	0.32	0.28	0.20	0.25	0.34	0.49	0.39	0.42	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page