

VILLA DOLORES, Argentina

WMO: 873280

Lat: 31.9514S

Lon: 65.1492W

Elev: 569

StdP: 94.67

Time Zone: -3.00 (W03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.2	2.0	-10.0	1.7	9.8	-7.7	2.1	10.4	11.9	19.8	10.5	17.8	1.6	90	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	36.4	21.0	34.9	20.7	33.6	20.5	24.1	31.9	23.3	30.9	22.5	30.0	5.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	17.7	28.0	21.0	16.8	27.2	20.2	16.0	26.6	76.2	31.9	72.7	31.3	69.5	29.9	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.0	9.4	7.9	DB	-2.9	39.9	1.7	1.7	-4.2	41.2	-5.2	42.2	-6.1	43.2	-7.4	44.4	(4)
			WB	-4.1	26.3	1.5	1.6	-5.2	27.5	-6.1	28.4	-6.9	29.4	-8.0	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	26.1	24.6	22.1	18.8	15.0	11.9	11.4	14.2	16.9	20.4	23.0	24.9
	DBStd	6.25	3.18	3.33	3.33	3.82	3.79	3.39	4.04	4.51	4.54	3.98	3.86	3.41
	HDD10.0	70	0	0	0	1	4	19	31	11	4	0	0	0
	HDD18.3	833	1	2	7	39	117	194	218	143	78	24	7	1
	CDD10.0	3380	498	409	376	264	159	75	73	142	211	322	391	461
	CDD18.3	1101	240	177	124	52	13	1	3	16	36	88	147	204
	CDH23.3	11466	2743	1773	1026	375	76	8	29	179	389	923	1653	2292
	CDH26.7	5011	1380	787	367	96	8	0	5	55	123	350	743	1097
Wind	WSAvg	2.4	2.6	2.2	2.1	2.0	1.9	1.9	2.0	2.6	2.6	2.8	3.2	2.8
Precipitation	PrecAvg	613	120	91	76	37	12	9	7	8	26	38	72	122
	PrecMax	880	331	180	224	107	53	55	49	54	98	114	210	249
	PrecMin	406	56	24	6	0	0	0	0	0	0	0	11	46
	PrecStd	125	57	39	45	30	13	14	10	12	23	31	40	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.6	36.4	34.7	31.7	27.7	24.4	26.2	31.7	33.0	35.1	36.5	38.4
		MCWB	21.3	22.7	21.4	20.8	18.8	16.4	16.6	18.4	17.2	19.3	19.5	20.9
	2%	DB	36.5	34.5	32.1	29.4	25.4	21.9	23.3	27.8	30.1	32.6	34.7	35.8
		MCWB	21.6	22.4	21.4	19.6	17.8	14.3	15.0	15.7	16.5	18.4	19.0	20.5
	5%	DB	34.7	32.9	30.3	27.4	23.4	20.1	20.9	24.9	27.8	30.5	32.9	34.0
		MCWB	21.2	22.1	20.6	18.9	16.5	13.2	13.1	14.0	15.6	17.5	18.7	20.5
	10%	DB	33.0	31.2	28.6	25.4	21.3	18.3	18.6	22.2	25.4	28.6	31.0	32.2
		MCWB	21.0	21.6	20.0	18.3	15.1	12.0	11.3	12.5	14.3	16.5	18.2	20.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.4	25.1	23.6	22.9	20.1	17.5	18.0	19.2	19.7	21.6	21.9	24.1
		MCDB	33.5	32.0	30.5	28.3	26.2	23.4	24.8	30.3	28.1	31.7	31.9	33.8
	2%	WB	24.2	24.2	22.6	21.4	18.6	15.5	16.0	17.0	17.8	20.1	20.9	23.0
		MCDB	32.0	31.5	29.2	26.3	23.7	20.4	22.1	26.4	27.8	29.7	30.9	31.7
	5%	WB	23.2	23.4	21.8	20.2	17.4	14.2	14.2	15.0	16.5	18.8	20.0	22.0
		MCDB	30.9	30.7	27.8	25.0	21.8	18.8	19.4	22.7	25.6	27.9	29.6	30.7
	10%	WB	22.3	22.4	20.9	19.1	16.2	12.8	12.4	13.2	15.2	17.7	19.2	21.1
		MCDB	30.0	29.4	26.8	24.4	20.4	17.1	17.2	20.9	23.8	26.1	28.2	29.7
Mean Daily Temperature Range	5% DB	MDBR	12.5	11.7	11.1	10.5	10.3	11.4	12.2	13.2	13.3	13.2	13.4	13.0
		MCDBR	13.8	13.1	12.7	12.4	11.8	12.8	14.0	15.2	15.4	14.8	14.8	14.8
		MCWBR	4.7	4.8	5.1	5.7	5.9	7.1	7.4	7.4	7.0	6.2	5.4	5.4
	5% WB	MCDBR	12.2	11.8	11.0	10.5	10.5	11.4	13.0	14.3	13.7	13.3	13.1	12.7
	MCWBR	5.5	5.1	5.2	5.6	5.6	6.7	7.3	7.6	7.0	6.3	5.5	5.6	
Clear-Sky Solar Irradiance	taub	0.379	0.368	0.362	0.343	0.329	0.309	0.314	0.347	0.394	0.384	0.372	0.384	
	taud	2.433	2.468	2.481	2.497	2.476	2.535	2.475	2.372	2.236	2.328	2.395	2.393	
	Ebn at Noon	960	951	922	886	845	844	853	865	872	924	960	958	
	Edh at Noon	122	114	106	93	85	75	83	104	133	130	126	128	
All-Sky Solar Radiation	RadAvg	7.35	6.36	5.32	3.96	3.03	2.85	3.16	4.16	5.32	6.31	7.24	7.52	
	RadStd	0.45	0.45	0.45	0.46	0.34	0.29	0.21	0.29	0.39	0.50	0.40	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.59	+0.40	+0.58	N/A	N/A	N/A	N/A

Nomenclature: See separate page