

CORDOBA, Argentina

WMO: 873440

Lat: 31.2967S

Lon: 64.2119W

Elev: 1555

StdP: 13.89

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.7	34.0	12.9	11.2	52.0	17.3	14.0	50.5	27.2	65.4	24.8	66.2	5.0	290	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	95.0	70.7	91.8	70.1	89.4	69.6	76.7	87.4	74.8	84.9	73.3	83.0	15.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.7	133.1	81.6	71.8	124.7	80.0	70.2	117.6	78.4	41.6	88.0	39.6	85.4	38.1	83.1	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.0	22.2	19.7	DB	25.2	101.3	3.3	3.5	22.9	103.8	21.0	105.9	19.1	107.8	16.8	110.3
			WB	23.1	80.2	3.2	1.9	20.8	81.5	18.9	82.6	17.1	83.6	14.8	85.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	74.4	72.0	69.3	64.1	58.0	52.8	51.8	55.7	60.0	65.3	69.8	73.5	(6)
	DBStd	10.13	4.97	5.30	5.64	6.78	6.80	6.19	7.18	7.98	7.62	6.86	6.26	5.47	(7)
	HDD50	154	0	0	0	2	10	40	63	30	9	0	0	0	(8)
	HDD65	1752	2	7	23	96	236	368	415	309	186	80	25	5	(9)
	CDD50	5210	757	617	600	426	259	124	118	205	308	473	594	729	(10)
	CDD65	1333	294	204	157	70	20	2	5	20	35	88	169	269	(11)
	CDH74	13112	2773	1706	1295	608	176	44	81	339	538	1033	1809	2710	(12)
	CDH80	5122	1166	638	421	175	33	6	20	127	191	401	756	1188	(13)
(14) Wind	WSAvg	8.2	8.0	7.5	7.5	7.4	7.1	7.1	7.7	9.0	9.7	9.5	9.5	8.7	(14)
(15) Precipitation	PrecAvg	31.9	4.8	4.8	4.6	2.2	0.9	0.4	0.4	0.4	1.4	2.9	4.2	5.5	(15)
	PrecMax	51.9	9.3	16.4	11.6	7.9	5.2	2.0	4.9	2.0	6.0	9.3	11.1	14.0	(16)
	PrecMin	19.1	1.8	0.8	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.2	1.3	0.9	(17)
	PrecStd	6.9	2.0	2.8	3.0	1.9	1.0	0.5	0.7	0.5	1.5	1.8	1.9	2.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.3	94.6	92.9	90.0	84.2	79.1	82.6	91.0	94.1	95.9	97.4	98.3	(19)
		MCWB	71.8	73.1	73.1	69.6	66.1	61.6	62.4	64.1	66.0	67.6	68.9	72.4	(20)
	2%	DB	93.2	90.3	87.9	84.6	78.9	73.6	75.0	82.7	85.4	89.4	91.8	93.8	(21)
		MCWB	72.3	73.3	71.2	67.3	64.6	58.1	57.0	60.8	62.1	66.3	67.6	70.9	(22)
	5%	DB	89.8	87.4	84.5	80.8	74.6	69.4	70.0	76.7	80.5	84.1	88.0	89.9	(23)
		MCWB	71.3	72.6	69.8	65.8	61.6	55.8	55.0	58.3	60.2	63.9	66.6	69.3	(24)
	10%	DB	86.3	84.0	81.5	77.0	70.1	65.7	65.5	71.4	75.3	79.2	84.2	86.4	(25)
		MCWB	70.5	71.2	68.5	63.9	59.4	54.1	52.5	55.3	57.5	61.7	65.0	68.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.7	79.4	77.7	74.1	70.1	66.2	64.4	67.5	68.7	73.2	74.6	77.3	(27)
		MCDB	90.2	87.7	87.8	82.8	78.3	74.4	77.5	83.6	85.2	85.5	88.2	90.7	(28)
	2%	WB	76.1	76.7	74.6	71.0	66.7	61.9	60.8	63.5	65.5	69.3	71.7	74.7	(29)
		MCDB	86.2	85.7	83.2	78.7	74.0	68.8	70.0	77.8	78.8	84.0	83.8	86.6	(30)
	5%	WB	74.1	74.4	72.2	68.5	64.5	58.9	57.9	60.2	62.8	66.9	69.7	72.8	(31)
		MCDB	84.5	82.9	80.2	75.5	71.5	65.0	65.7	72.2	75.6	78.8	82.2	84.2	(32)
	10%	WB	72.4	72.5	70.2	66.6	62.1	56.3	55.1	56.7	59.9	64.4	67.4	70.8	(33)
		MCDB	82.4	80.6	77.6	74.0	68.2	62.6	62.6	68.1	71.6	75.2	79.6	81.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.0	19.3	19.9	20.2	20.1	23.1	23.6	25.5	24.8	23.1	23.1	22.1	(35)
		MCDBR	26.3	24.7	24.6	26.5	26.0	29.9	30.9	33.5	32.5	30.7	29.5	27.8	(36)
	5% WB	MCWBR	11.1	11.6	11.5	12.2	13.3	16.7	16.9	16.4	15.2	13.7	12.3	11.2	(37)
		MCWBR	21.6	20.9	20.6	20.3	20.7	22.8	25.4	29.3	27.1	25.7	24.5	22.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.390	0.373	0.366	0.352	0.332	0.317	0.321	0.358	0.415	0.396	0.381	0.388	(40)
		taud	2.386	2.446	2.464	2.469	2.472	2.505	2.458	2.341	2.173	2.294	2.370	2.380	(41)
	Ebn at Noon		301	300	292	279	268	266	269	272	271	290	302	303	(42)
		Edh at Noon	41	37	34	31	27	25	27	34	45	43	41	41	(43)
(44) All-Sky Solar Radiation	RadAvg		2219	1903	1620	1223	949	887	985	1298	1639	1902	2186	2249	(44)
	RadStd		153	148	142	151	94	95	69	96	136	153	140	142	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	-1.21	-2.50	+1.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	-1.21	-2.50	+1.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page