

CORDOBA, Argentina

WMO: 873440

Lat: 31.2967S

Lon: 64.2119W

Elev: 474

StdP: 95.76

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.7	1.1	-10.6	1.6	11.1	-8.1	2.0	10.3	12.2	18.5	11.1	19.0	2.2	290	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	35.0	21.5	33.2	21.1	31.9	20.9	24.9	30.8	23.8	29.4	22.9	28.3	6.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.0	27.5	22.1	17.8	26.6	21.2	16.8	25.8	78.8	31.1	74.3	29.6	70.7	28.4	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.9	8.8	-3.8	38.5	1.8	1.9	-5.1	39.9	-6.1	41.0	-7.1	42.1	-8.5	43.5		
(5)			-5.0	26.8	1.8	1.0	-6.2	27.5	-7.3	28.1	-8.3	28.7	-9.6	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	23.6	22.2	20.7	17.9	14.5	11.6	11.0	13.1	15.5	18.5	21.0	23.1		
	DBStd	5.63	2.76	2.95	3.13	3.76	3.78	3.44	3.99	4.43	4.23	3.81	3.48	3.04		
	HDD10.0	86	0	0	0	1	6	22	35	17	5	0	0	0		
	HDD18.3	973	1	4	13	53	131	204	231	172	103	44	14	3		
	CDD10.0	2894	421	343	333	237	144	69	66	114	171	263	330	405		
	CDD18.3	741	163	113	87	39	11	1	3	11	19	49	94	149		
	CDH23.3	7284	1541	948	719	338	98	24	45	188	299	574	1005	1506		
	CDH26.7	2846	648	354	234	97	18	3	11	71	106	223	420	660		
(14) Wind	WSAvg	3.7	3.6	3.3	3.4	3.3	3.2	3.2	3.4	4.0	4.3	4.2	4.3	3.9		
(15) Precipitation	PrecAvg	810	122	123	116	57	23	9	10	9	35	73	107	139		
	PrecMax	1317	237	417	295	200	133	51	124	51	153	236	281	355		
	PrecMin	485	45	20	3	3	0	0	0	0	6	34	22	22		
	PrecStd	174	50	71	75	47	26	12	19	13	39	46	47	64		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.3	34.8	33.8	32.2	29.0	26.2	28.1	32.8	34.5	35.5	36.3	36.9		
		MCWB	22.1	22.8	22.8	20.9	18.9	16.5	16.9	17.8	18.9	19.8	20.5	22.5		
	2%	DB	34.0	32.4	31.1	29.2	26.1	23.1	23.9	28.2	29.6	31.9	33.2	34.4		
		MCWB	22.4	23.0	21.8	19.6	18.1	14.5	13.9	16.0	16.7	19.0	19.8	21.6		
	5%	DB	32.1	30.8	29.2	27.1	23.7	20.8	21.1	24.8	26.9	29.0	31.1	32.2		
		MCWB	21.9	22.6	21.0	18.8	16.5	13.2	12.8	14.6	15.7	17.7	19.2	20.7		
	10%	DB	30.2	28.9	27.5	25.0	21.2	18.7	18.6	21.9	24.1	26.2	29.0	30.2		
		MCWB	21.4	21.8	20.3	17.7	15.2	12.3	11.4	13.0	14.2	16.5	18.4	20.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	26.3	25.4	23.4	21.1	19.0	18.0	19.7	20.4	22.9	23.6	25.2		
		MCDB	32.3	30.9	31.0	28.2	25.7	23.6	25.3	28.7	29.5	29.7	31.2	32.6		
	2%	WB	24.5	24.8	23.7	21.7	19.3	16.6	16.0	17.5	18.6	20.7	22.1	23.7		
		MCDB	30.1	29.8	28.5	26.0	23.3	20.5	21.1	25.4	26.0	28.9	28.8	30.3		
	5%	WB	23.4	23.6	22.3	20.3	18.0	14.9	14.4	15.6	17.1	19.4	20.9	22.7		
		MCDB	29.2	28.3	26.8	24.2	21.9	18.4	18.7	22.3	24.2	26.0	27.9	29.0		
	10%	WB	22.5	22.5	21.2	19.2	16.7	13.5	12.8	13.7	15.5	18.0	19.7	21.6		
		MCDB	28.0	27.0	25.4	23.4	20.1	17.0	17.0	20.0	22.0	24.0	26.4	27.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	10.7	11.0	11.2	11.1	12.8	13.1	14.2	13.8	12.8	12.8	12.3		
		MCDBR	14.6	13.7	13.7	14.7	14.5	16.6	17.2	18.6	18.1	17.1	16.4	15.4		
	5% WB	MCWBR	6.1	6.4	6.4	6.8	7.4	9.3	9.4	9.1	8.4	7.6	6.8	6.2		
		MCWBR	12.0	11.6	11.4	11.3	11.5	12.7	14.1	16.3	15.1	14.3	13.6	12.6		
(40) Clear-Sky Solar Irradiance	taub		0.390	0.373	0.366	0.352	0.332	0.317	0.321	0.358	0.415	0.396	0.381	0.388		
	taud		2.386	2.446	2.464	2.469	2.472	2.505	2.458	2.341	2.173	2.294	2.370	2.380		
	Ebn at Noon		950	947	919	878	846	837	849	856	854	913	952	955		
	Edh at Noon		128	117	108	97	86	78	86	108	142	135	130	130		
(44) All-Sky Solar Radiation	RadAvg		6.99	6.00	5.11	3.85	2.99	2.80	3.10	4.09	5.17	6.00	6.89	7.09		
	RadStd		0.48	0.47	0.45	0.47	0.30	0.30	0.22	0.30	0.43	0.48	0.44	0.45		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	-0.67	-1.39	+0.67	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	-0.67	-1.39	+0.67	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page