

PILAR, Argentina

WMO: 873490

Lat: 31.6681S

Lon: 63.8819W

Elev: 1109

StdP: 14.12

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.9	34.9	16.4	13.1	50.1	19.9	15.6	47.8	26.1	64.5	21.9	57.3	1.9	230	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	94.3	71.0	91.2	70.7	88.7	70.5	77.6	86.2	75.8	84.2	74.3	82.8	10.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.2	137.7	82.2	73.4	129.6	80.6	71.8	122.5	79.3	42.1	85.7	40.3	84.4	38.7	82.7	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.1	16.2	DB	27.0	102.1	3.0	3.4	24.8	104.5	23.0	106.5	21.3	108.4	19.1	110.9	(4)
(5)			WB	25.3	79.9	2.8	1.8	23.3	81.2	21.6	82.3	20.1	83.3	18.1	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	76.0	73.2	69.3	64.2	58.0	52.8	51.6	54.9	59.9	65.2	70.5	74.5	(6)
(7)		DBStd	10.36	4.99	5.33	5.58	6.47	6.32	6.02	6.68	6.98	7.38	6.66	6.01	5.65	(7)
(8)		HDD50	138	0	0	0	1	7	37	57	27	9	0	0	0	(8)
(9)		HDD65	1743	1	6	22	90	233	368	417	323	184	78	18	3	(9)
(10)		CDD50	5300	805	651	599	428	255	121	109	180	306	472	616	758	(10)
(11)		CDD65	1428	341	237	156	67	16	2	3	11	31	84	184	296	(11)
(12)		CDH74	12467	3136	1736	1073	465	73	18	32	144	403	787	1741	2859	(12)
(13)		CDH80	4620	1298	556	294	108	8	1	5	38	130	257	672	1253	(13)
(14)	Wind	WSAvg	5.9	5.3	4.3	4.6	4.7	5.1	5.6	5.9	7.2	7.1	7.0	7.3	6.5	(14)
(15)	Precipitation	PrecAvg	28.9	4.8	4.1	3.9	2.2	0.8	0.4	0.5	0.3	1.4	2.7	3.7	4.8	(15)
(16)		PrecMax	46.5	11.1	13.6	9.8	7.8	3.7	2.7	4.6	1.6	5.8	8.4	9.7	11.8	(16)
(17)		PrecMin	14.2	1.0	1.3	0.4	0.0	0.0	0.0	0.0	0.0	0.4	0.6	1.0	(17)	
(18)		PrecStd	7.0	2.4	2.2	2.3	1.7	0.9	0.6	0.9	0.4	1.4	1.9	2.0	2.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.0	93.1	90.5	88.0	80.3	76.3	78.3	85.3	91.1	92.5	95.4	98.8	(19)
(20)			MCWB	73.6	73.3	73.4	70.5	65.9	62.5	62.3	64.5	65.3	68.5	68.8	72.1	(20)
(21)		2%	DB	93.5	89.1	86.4	82.6	75.4	70.5	71.1	78.0	82.9	86.8	90.9	94.1	(21)
(22)			MCWB	71.5	75.0	73.0	66.9	63.7	58.3	58.0	60.0	61.9	65.8	67.3	71.2	(22)
(23)		5%	DB	90.2	86.1	83.4	79.4	71.8	67.0	67.0	72.0	78.2	82.4	87.2	90.4	(23)
(24)			MCWB	72.2	74.1	71.1	65.5	61.1	56.7	55.2	56.2	60.1	64.3	66.7	70.0	(24)
(25)		10%	DB	87.0	83.3	80.1	75.6	68.3	63.8	63.3	67.6	73.7	78.1	83.4	86.9	(25)
(26)			MCWB	71.4	72.5	69.1	63.7	60.8	54.2	53.8	53.9	57.8	62.0	65.5	69.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	79.7	77.7	73.6	69.3	65.5	64.5	67.8	68.8	72.1	74.0	77.9	(27)
(28)			MCD B	89.0	86.5	86.2	80.2	73.9	71.8	72.4	81.5	81.4	83.8	84.9	90.3	(28)
(29)		2%	WB	77.2	77.8	75.0	70.8	66.9	62.6	61.4	63.0	65.2	69.3	71.3	75.4	(29)
(30)			MCD B	85.5	85.1	82.9	78.6	71.8	69.3	68.7	71.6	77.8	83.0	83.5	86.8	(30)
(31)		5%	WB	75.3	75.9	72.9	68.6	64.7	59.2	58.6	59.6	62.4	66.5	69.2	73.2	(31)
(32)			MCD B	84.4	82.6	80.3	73.8	69.5	63.8	63.7	68.0	73.8	77.5	81.5	84.9	(32)
(33)		10%	WB	73.8	74.2	71.1	66.7	62.3	56.4	56.2	56.1	60.0	64.4	67.4	71.2	(33)
(34)			MCD B	83.2	80.4	77.8	73.0	66.9	61.5	61.2	65.4	70.1	73.6	79.1	82.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.1	16.6	18.0	18.0	17.7	20.2	20.3	22.7	22.5	20.7	21.5	20.6	(35)
(36)			MCDBR	24.2	20.5	21.7	24.1	22.5	24.8	25.5	29.2	29.3	27.0	27.7	25.9	(36)
(37)			MCWBR	8.6	8.9	9.4	10.5	11.2	13.8	14.3	14.9	13.4	11.3	9.9	8.7	(37)
(38)		5% WB	MCD BR	18.9	17.0	18.4	18.1	16.2	19.4	20.1	24.5	24.7	22.6	22.7	21.5	(38)
(39)			MCWBR	9.0	9.1	9.4	9.5	9.0	12.6	12.7	14.6	12.7	12.0	10.2	9.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.393	0.378	0.371	0.356	0.339	0.319	0.328	0.366	0.421	0.401	0.384	0.389	(40)	
(41)		taud	2.370	2.421	2.442	2.452	2.444	2.496	2.432	2.309	2.148	2.274	2.355	2.370	(41)	
(42)		Ebn at Noon	300	298	290	277	265	264	266	268	268	288	301	303	(42)	
(43)		Edh at Noon	41	38	35	31	28	25	28	35	46	43	42	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2244	1928	1645	1222	931	866	953	1269	1616	1882	2187	2277	(44)	
(45)		RadStd	149	153	140	158	90	99	74	100	139	152	137	141	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (4 neighbors)	N/A	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page