

PILAR, Argentina

WMO: 873490

Lat: 31.6681S

Lon: 63.8819W

Elev: 338

StdP: 97.33

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.0	1.6	-8.7	1.9	10.1	-6.7	2.2	8.8	11.7	18.1	9.8	14.1	0.8	230	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.6	34.6	21.6	32.9	21.5	31.5	21.4	25.3	30.1	24.3	29.0	23.5	28.2	4.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.7	27.9	23.0	18.5	27.0	22.1	17.5	26.3	80.0	29.9	75.7	29.1	72.2	28.2	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.6	7.3	-2.8	38.9	1.7	1.9	-4.0	40.3	-5.0	41.4	-5.9	42.4	-7.1	43.8		
(5)			-3.7	26.6	1.5	1.0	-4.9	27.3	-5.8	27.9	-6.6	28.5	-7.7	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	24.4	22.9	20.7	17.9	14.4	11.6	10.9	12.7	15.5	18.5	21.4	23.6	(6)
(7)		DBStd	5.76	2.77	2.96	3.10	3.59	3.51	3.34	3.71	3.88	4.10	3.70	3.34	3.14	(7)
(8)		HDD10.0	77	0	0	0	1	4	21	32	15	5	0	0	0	(8)
(9)		HDD18.3	968	1	3	12	50	129	204	232	179	102	43	10	2	(9)
(10)		CDD10.0	2944	447	362	333	238	142	67	61	100	170	262	342	421	(10)
(11)		CDD18.3	793	189	132	87	37	9	1	2	6	17	47	102	164	(11)
(12)		CDH23.3	6926	1742	964	596	258	41	10	18	80	224	437	967	1588	(12)
(13)		CDH26.7	2567	721	309	163	60	4	1	3	21	72	143	373	696	(13)
(14)	Wind	WSAvg	2.6	2.3	1.9	2.1	2.1	2.3	2.5	2.7	3.2	3.1	3.3	2.9	(14)	
(15)	Precipitation	PrecAvg	735	123	104	98	57	21	11	13	8	36	69	95	123	(15)
(16)		PrecMax	1180	282	346	250	198	94	69	117	41	147	214	246	300	(16)
(17)		PrecMin	360	25	33	10	0	0	0	0	0	0	10	16	25	(17)
(18)		PrecStd	177	61	56	59	42	22	16	24	11	36	47	52	66	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	33.9	32.5	31.1	26.9	24.6	25.7	29.6	32.8	33.6	35.2	37.1	(19)
(20)			MCWB	23.1	23.0	23.0	21.4	18.8	16.9	16.9	18.1	18.5	20.3	20.4	22.3	(20)
(21)		2%	DB	34.2	31.7	30.2	28.1	24.1	21.4	21.7	25.6	28.3	30.5	32.7	34.5	(21)
(22)			MCWB	22.0	23.9	22.8	19.4	17.6	14.6	14.5	15.6	16.6	18.8	19.6	21.8	(22)
(23)		5%	DB	32.3	30.1	28.5	26.3	22.1	19.5	19.5	22.2	25.6	28.0	30.7	32.4	(23)
(24)			MCWB	22.4	23.4	21.7	18.6	16.2	13.7	12.9	13.5	15.6	17.9	19.3	21.1	(24)
(25)		10%	DB	30.6	28.5	26.7	24.2	20.2	17.7	17.4	19.8	23.2	25.6	28.6	30.5	(25)
(26)			MCWB	21.9	22.5	20.6	17.6	16.0	12.3	12.1	12.2	14.3	16.7	18.6	20.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.5	25.4	23.1	20.7	18.6	18.0	19.9	20.4	22.3	23.3	25.5	(27)
(28)			MCDWB	31.7	30.3	30.1	26.8	23.3	22.1	22.5	27.5	27.5	28.8	29.4	32.4	(28)
(29)		2%	WB	25.1	25.5	23.9	21.6	19.4	17.0	16.4	17.2	18.4	20.7	21.9	24.1	(29)
(30)			MCDWB	29.7	29.5	28.3	25.9	22.1	20.7	20.4	22.0	25.4	28.3	28.6	30.5	(30)
(31)		5%	WB	24.1	24.4	22.7	20.3	18.2	15.1	14.8	15.4	16.9	19.2	20.7	22.9	(31)
(32)			MCDWB	29.1	28.1	26.8	23.2	20.8	17.7	17.6	20.0	23.2	25.3	27.5	29.4	(32)
(33)		10%	WB	23.2	23.4	21.7	19.3	16.8	13.5	13.5	13.4	15.5	18.0	19.7	21.8	(33)
(34)			MCDWB	28.5	26.9	25.4	22.8	19.4	16.4	16.2	18.6	21.2	23.1	26.2	27.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.6	9.2	10.0	10.0	9.9	11.2	11.3	12.6	12.5	11.5	12.0	11.5	(35)
(36)			MCDBR	13.5	11.4	12.0	13.4	12.5	13.8	14.2	16.2	16.3	15.0	15.4	14.4	(36)
(37)			MCWBR	4.8	4.9	5.2	5.8	6.2	7.7	7.9	8.3	7.5	6.3	5.5	4.9	(37)
(38)		5% WB	MCDWB	10.5	9.5	10.2	10.0	9.0	10.8	11.2	13.6	13.7	12.6	12.6	11.9	(38)
(39)			MCWBR	5.0	5.0	5.2	5.3	5.0	7.0	7.1	8.1	7.1	6.7	5.7	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.393	0.378	0.371	0.356	0.339	0.319	0.328	0.366	0.421	0.401	0.384	0.389	(40)	
(41)		taud	2.370	2.421	2.442	2.452	2.444	2.496	2.432	2.309	2.148	2.274	2.355	2.370	(41)	
(42)		Ebn at Noon	946	941	913	872	834	832	837	845	846	908	949	954	(42)	
(43)		Edh at Noon	130	120	110	98	88	79	87	111	145	137	132	131	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.08	6.08	5.19	3.85	2.94	2.73	3.00	4.00	5.09	5.93	6.89	7.18	(44)	
(45)		RadStd	0.47	0.48	0.44	0.50	0.28	0.31	0.23	0.31	0.44	0.48	0.43	0.44	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page